

**ASBESTOS ANALYSIS BY POLARIZED LIGHT MICROSCOPY**

Method: EPA/600/R-93/116

Luse Environmental Services

3990 Enterprise Court

Aurora, IL 60504

Phone: (630) 862-2600

Fax: (630) 862-2673

Reference:

Location: 3501 S Pulaski Road

Batch No.: 346788

Customer No.: 898

Date Received: 04/13/2020

Date Analyzed: 04/13/2020

Date Reported: 04/13/2020

Turn Around Time: 24 Hour

Laboratory Sample	Customer Sample Number	Asbestos Components (%)	Non-Asbestos Components (%)
346788001	1	Chrysotile 10-15%	Binder 85-90%


ND = Asbestos Not Detected (Not Present)    NA = Not Analyzed    NS = Not Submitted

Components of inhomogeneous samples are analyzed per our Standard Operating Procedure, or per customer request.

The use of the NVLAP logo does not imply endorsement by NVLAP or any agency of the US Government.

*The information contained in this report and any attachments is confidential information intended only for the use of the individual or entities named above. The results of this report relate only to the samples tested. If you have received this report in error, please notify us immediately by phone. This report shall not be reproduced, except in its entirety, unless written approval has been obtained from the laboratory. This report remains property of STAT Analysis until payment is received in full (see invoice).*

Analyzed by Name:


  
Henry Robateau / Microscopist

CHAIN OF CUSTODY RECORD

Page: \_\_\_\_\_ of \_\_\_\_\_

Client: LUSE ENVIRON. SERVICES  
 Street Address: 3990 Enterprise Court  
 City, State, Zip: Aurora, IL 60504  
 Phone: 630 862 2446  
 Fax:  
 e-mail/Alt. Fax: JIMCHOI@LUSE.COM  
 Project Number: 3501 S. Pulaski Road  
 Project Name:  
 Project Location:  
 Project Manager:  
 P.O. Number:

Turn Around: Immediate:  4 Hrs:  8 Hrs:  24 Hrs:  1 Day:  2 Days:  3 Days:  5 Days:   
 Date Due: \_\_\_\_\_ Time Due: \_\_\_\_\_  
**OFFICE USE ONLY BELOW:**  
 Batch No.: 346788  
 Samples Acceptable: Yes:  No:   
 Checked by (Initial/Date): [Signature] 4/13/20  
 QC by (Initial/Date): [Signature] 4/14/20  
 Reported By (Initial/Date/Time/Method):

Client Sample Number/Description	Date Taken	Time		Rate (ipm)	Volume (Liters)	Area Wiped (ft <sup>2</sup> )	Laboratory Sample No.	Analysis Options																	
		On	Off					PCM Asbestos	PLM Asbestos (Bulk)	PLM Point Count	PLM Gravimetric	TEM Air Asbestos	TEM Bulk Asbestos	TEM Gravimetric Asb.	TEM Microvac Asb.	TEM Water	Other:								
① Coating on Galvanized Sidewalk	4/14/20		N/A																						

Comments: Please send results to: John. Singler @ city of Chicago. org  
 CALL DAVID GRAHAM for further instructions 312 745 4034  
 ON Sampling

Note: Not all turn around times are available for all analysis.

Relinquished by: [Signature] Singler Date/Time: 4/14/20 10:00  
 Received by: [Signature] Date/Time: 4/13/20 11:00  
 Relinquished by: \_\_\_\_\_ Date/Time: \_\_\_\_\_  
 Received by: \_\_\_\_\_ Date/Time: \_\_\_\_\_