


CITY OF CHICAGO
DEPARTMENT OF BUILDINGS

CODE MEMORANDUM

To: Department of Buildings Plan Examiners and Inspectors

From: Judith Frydland
Commissioner 

Date: February 8, 2016

Re: **Electrical Administrative Reliefs No Longer Required for a Building Permit**

The Department of Buildings will no longer require the following electrical Administrative Reliefs for the issuance of a building permit.

- | | |
|------------------------------------|-----------------|
| 1) Special Switchboard Drawings | 18-27-384.11(b) |
| 2) Voltage Drop Coordination Study | 18-27-210.9 |
| 3) Emergency Generator Drawings | 18-27-701.7 |
| 4) Emergency Lighting Drawings | 18-27-700.3 |
| 5) 480/277 Volt Maintenance | 18-27-210.6 |
| 6) Selective Coordination Study | 18-27-517.35(e) |

These drawings or studies shall be provided at the job site during the permit construction phase of the project for review by the Department of Buildings Electrical Inspectors.