



CHICAGO CODE CLARIFICATIONS

Title 14B, Section 903.3.1.3 – NFPA 13D Sprinkler Systems

Where NFPA 13D sprinkler systems are required per Title 14B, Section 903.3.1.3, the following clarifications apply:

A. Scope:

- a. Notwithstanding other code sections, automatic sprinkler systems designed per NFPA 13D shall only apply to one and two-family dwellings and manufactured homes.

B. Garages:

- a. Sprinkler protection is required in all attached parking garages.

C. Design area:

- a. NFPA 13D sprinkler systems are required to have a 2-head design area.

- D. The Chicago Fire Prevention Bureau reserves the right to make any changes necessary to these requirements.