



CITY OF CHICAGO

DEPARTMENT OF BUILDINGS

MEMORANDUM

To: The Honorable Jason Ervin
Chairman, Committee on the Budget and Government Operations

From: Matthew Beaudet
Commissioner
Department

CC: Elizabeth Beatty
Mayor's Office of Intergovernmental Affairs

Date: **November 8, 2023**

Re: Request for Information from Annual Appropriation Committee Hearing

ID#: 67-01

The following information is provided in response to questions posed at our department's hearing on October 25, 2023, to discuss the proposed 2024 budget.

Aldermen Villegas and Scott asked for a list of buildings that are in queue for demolition (see below).

The department has a list of buildings that have an order from Circuit Court that gives the department authority to demolish a building. The department prioritizes buildings with the following dangerous and hazardous conditions:

1. Foundations that have been undermined.
2. Lack of or inadequate lateral support of exterior walls.
3. Floor systems that are structurally compromised.
4. Roofing systems structurally compromised including missing roofing.
5. Center support beams that are structurally compromised.
6. Exterior and interior stair systems and/or porches structurally compromised.
7. Chronic nuisance due to ongoing criminal activity

Buildings with an order from Circuit Court that do not have any of the conditions listed above are not prioritized as we want to preserve as much of our housing stock located on the south and west sides of the City. These areas have been decimated due to all the demolition activity that occurred over the past 10 years. As a department we are committed to stabilizing the community and the courts are allowing people to file motions to stay the demolition, so they are able reinvest in their properties.

As always, please let me know if you have any further questions.

Display Address	Ward	Census Tract	Police District
6140 N PULASKI RD CHICAGO IL 60646-	39	130200	17



CITY OF CHICAGO

DEPARTMENT OF BUILDINGS

MEMORANDUM

To: The Honorable Jason Ervin
Chairman, Committee on the Budget and Government Operations

From: Matthew Beaudet
Commissioner
Department

CC: Elizabeth Beatty
Mayor's Office of Intergovernmental Affairs

Date: **November 8, 2023**

Re: Request for Information from Annual Appropriation Committee Hearing

ID#: 67-02

The following information is provided in response to questions posed at our department's hearing on October 25, 2023, to discuss the proposed 2024 budget.

Ald. Hadden asked for breakdown by ward for calls regarding the cooling and heating ordinance. Please see below.

As always, please let me know if you have any further questions.



WARD	No Heat	No AC - Senior Buildings
1	8	2
2	15	10
3	62	32
4	52	35
5	62	18
6	81	18
7	63	2
8	69	9
9	35	7
10	12	2
11	9	1
12	17	1
13	9	0
14	16	5
15	22	2
16	51	14
17	53	7
18	11	10
19	11	0
20	65	21
21	20	11
22	13	4
23	9	12

24	49	5
25	20	0
26	14	1
27	50	25
28	51	19
29	52	2
30	20	3
31	17	3
32	13	2
33	17	2
34	11	15
35	23	2
36	21	3
37	38	2
38	12	0
39	23	6
40	22	3
41	8	2
42	28	23
43	22	5
44	34	5
45	17	2
46	49	12
47	23	1
48	52	8
49	63	15
50	33	1
SUM	1547	390



CITY OF CHICAGO

DEPARTMENT OF BUILDINGS

MEMORANDUM

To: The Honorable Jason Ervin
Chairman, Committee on the Budget and Government Operations

From: Matthew Beudet
Commissioner
Department

CC: Elizabeth Beatty
Mayor's Office of Intergovernmental Affairs

Date: **November 8, 2023**

Re: Request for Information from Annual Appropriation Committee Hearing

ID#: 67-03

The following information is provided in response to questions posed at our department's hearing on October 25, 2023, to discuss the proposed 2024 budget.

Alderman Vasquez asked for a map of active court cases for heat. This information is being provided to the department by the Department of Law (DOL). Please see the information below from the DOL.

In 2022 heat season, DOL filed 139 heat cases in court. We coordinated with the Department of Buildings to resolve 105 referrals outside of the court process.

In spring of 2023, DOL filed 111 heat cases. We have not received referrals for Fall 2023.

As always, please let me know if you have any further questions.



CITY OF CHICAGO

DEPARTMENT OF BUILDINGS

MEMORANDUM

To: The Honorable Jason Ervin
Chairman, Committee on the Budget and Government Operations

From: Matthew Beaudet
Commissioner
Department

CC: Elizabeth Beatty
Mayor's Office of Intergovernmental Affairs

Date: **November 8, 2023**

Re: Request for Information from Annual Appropriation Committee Hearing

ID#: 67-04 Ten Year Trend

The following information is provided in response to questions posed at our department's hearing on October 25, 2023, to discuss the proposed 2024 budget.

Alderman Lawson asked for the ten-year trend for permits volume and value. Please see attached PDF.

As always, please let me know if you have any further questions.

Plan-Based Building Permits Issued January through September, by ward, 2014-2023 and variance from prior years average

2023 Wards	2014		2015		2016		2017		2018		2019		2020		2021		2022		2023		2023 Variance from Prior Year Average	
	Count	Reported Cost	Count	Reported Cost	Count	Reported Cost	Count	Reported Cost	Count	Reported Cost	Count	Reported Cost	Count	Reported Cost	Count	Reported Cost	Count	Reported Cost	Count	Reported Cost	Count	Reported Cost
Ward 1	340	\$143,290,053	248	\$421,752,750	343	\$114,533,032	385	\$204,665,377	318	\$118,891,552	283	\$155,096,333	222	\$61,946,428	193	\$36,830,014	253	\$96,585,429	184	\$60,861,451	-35.9%	-59.5%
Ward 2	260	\$590,302,201	284	\$547,673,450	252	\$1,240,964,039	248	\$322,056,484	208	\$144,452,438	207	\$183,805,727	153	\$113,310,033	156	\$90,979,764	153	\$98,615,057	136	\$238,755,819	-36.3%	-35.5%
Ward 3	142	\$87,013,608	135	\$85,062,150	178	\$610,582,510	162	\$263,204,834	178	\$115,445,928	188	\$120,397,531	129	\$40,266,821	143	\$50,098,535	164	\$100,747,129	111	\$139,195,995	-29.6%	-14.9%
Ward 4	193	\$156,883,517	179	\$254,381,214	156	\$79,024,775	231	\$346,189,911	223	\$98,407,148	218	\$93,739,985	149	\$82,030,125	154	\$148,053,237	165	\$71,756,006	170	\$342,433,188	-8.3%	131.6%
Ward 5	166	\$77,267,133	140	\$150,850,149	141	\$45,647,376	168	\$164,801,742	171	\$159,538,088	179	\$70,401,218	117	\$49,184,609	131	\$56,247,546	139	\$59,495,735	152	\$115,841,079	1.2%	25.1%
Ward 6	107	\$6,492,463	101	\$19,582,178	130	\$5,608,661	139	\$6,152,500	153	\$98,021,423	208	\$12,387,196	167	\$50,072,616	147	\$26,332,518	151	\$27,978,519	149	\$77,630,577	2.9%	176.6%
Ward 7	64	\$17,913,665	85	\$62,952,558	70	\$6,023,819	77	\$8,675,841	98	\$19,201,737	92	\$15,663,835	102	\$92,898,120	99	\$22,219,836	112	\$23,661,022	74	\$97,839,885	-16.6%	227.1%
Ward 8	99	\$49,300,620	88	\$8,800,400	105	\$5,400,919	131	\$10,967,939	131	\$16,881,712	119	\$12,993,877	125	\$19,194,988	124	\$14,919,900	128	\$43,471,350	103	\$61,219,376	-11.7%	202.8%
Ward 9	59	\$7,042,340	68	\$3,842,300	67	\$37,772,350	73	\$26,381,257	74	\$57,558,257	86	\$28,550,785	74	\$88,284,553	81	\$20,785,567	87	\$16,316,130	64	\$12,080,629	-13.9%	-62.1%
Ward 10	47	\$3,944,927	78	\$64,712,091	54	\$14,576,495	68	\$53,052,869	61	\$16,571,469	79	\$36,506,648	59	\$54,908,755	62	\$74,430,182	57	\$15,938,619	44	\$37,286,693	-29.9%	0.3%
Ward 11	184	\$55,684,251	180	\$54,063,225	163	\$19,636,862	166	\$22,268,631	171	\$35,566,076	189	\$49,379,194	143	\$57,147,709	147	\$80,496,904	148	\$65,217,071	128	\$81,488,045	-22.7%	66.9%
Ward 12	72	\$9,447,428	84	\$263,833,182	116	\$68,462,000	98	\$23,504,726	99	\$52,797,169	100	\$15,819,511	72	\$16,587,817	75	\$28,922,512	83	\$53,538,442	59	\$38,987,576	-33.5%	-34.2%
Ward 13	59	\$6,120,420	53	\$49,959,832	63	\$7,755,700	57	\$11,216,158	90	\$99,867,377	69	\$149,442,340	63	\$26,444,571	40	\$9,398,304	48	\$14,593,319	56	\$33,358,804	-7.0%	-19.9%
Ward 14	45	\$14,218,000	64	\$34,869,992	59	\$46,264,948	64	\$28,215,606	72	\$47,135,982	80	\$26,081,470	65	\$17,664,436	47	\$17,432,310	50	\$37,716,372	48	\$43,623,173	-20.9%	45.6%
Ward 15	66	\$15,549,950	67	\$3,613,585	91	\$5,205,629	75	\$4,818,306	86	\$5,038,700	95	\$6,024,646	78	\$15,771,825	80	\$73,537,430	83	\$11,542,642	58	\$9,627,641	-27.6%	-38.6%
Ward 16	106	\$19,334,885	122	\$9,057,400	139	\$19,523,699	98	\$16,362,689	103	\$8,505,251	124	\$11,132,042	125	\$22,334,556	134	\$12,300,998	134	\$46,471,145	120	\$64,704,537	-0.5%	252.9%
Ward 17	103	\$14,987,908	102	\$4,725,100	117	\$4,342,950	95	\$5,362,395	99	\$9,585,674	126	\$8,929,555	108	\$15,786,291	127	\$30,367,330	125	\$34,791,081	104	\$10,282,094	-6.6%	-28.2%
Ward 18	46	\$7,466,042	40	\$3,227,403	63	\$7,448,835	57	\$10,309,853	66	\$35,934,879	64	\$7,260,851	60	\$19,611,854	52	\$6,619,115	59	\$19,824,342	58	\$26,123,425	3.0%	99.7%
Ward 19	110	\$14,210,648	107	\$3,203,054	119	\$20,879,159	133	\$19,793,762	152	\$49,852,678	141	\$19,406,309	113	\$34,577,415	103	\$16,658,839	125	\$32,996,430	94	\$24,716,405	-23.3%	-6.8%
Ward 20	120	\$60,122,477	144	\$35,287,123	176	\$56,956,993	160	\$37,362,082	166	\$155,498,794	180	\$20,161,448	153	\$83,690,250	170	\$64,425,637	178	\$55,329,390	150	\$99,826,461	-6.7%	57.9%
Ward 21	81	\$14,280,004	89	\$13,286,083	104	\$16,499,517	81	\$20,241,967	121	\$24,530,810	114	\$36,275,037	121	\$36,727,613	109	\$33,318,809	134	\$33,588,301	83	\$14,500,027	-21.7%	-43.0%
Ward 22	45	\$3,023,787	63	\$9,593,814	62	\$41,909,650	73	\$29,739,081	77	\$34,977,568	71	\$98,593,735	74	\$79,486,841	62	\$20,160,663	50	\$55,684,416	38	\$14,756,948	-40.7%	-64.4%
Ward 23	52	\$4,812,481	55	\$4,850,626	64	\$5,803,490	65	\$14,144,321	68	\$8,983,727	68	\$8,386,851	55	\$4,715,501	39	\$9,420,700	59	\$15,402,775	43	\$5,192,179	-26.3%	-38.9%
Ward 24	130	\$45,456,204	136	\$43,047,899	129	\$15,246,260	144	\$15,964,274	133	\$11,177,481	173	\$109,598,122	168	\$31,777,671	149	\$17,638,425	176	\$107,461,088	125	\$56,100,652	-15.9%	27.1%
Ward 25	107	\$12,204,039	134	\$16,174,297	182	\$95,360,351	214	\$59,892,017	241	\$61,463,445	220	\$54,641,934	163	\$38,303,119	120	\$38,347,691	145	\$39,228,361	140	\$65,340,665	-17.4%	41.5%
Ward 26	207	\$45,582,209	191	\$36,169,924	176	\$21,517,815	209	\$66,649,458	206	\$44,950,545	170	\$26,578,190	155	\$20,186,251	142	\$29,527,611	118	\$22,616,590	121	\$97,547,673	-30.8%	179.8%
Ward 27	288	\$549,597,437	350	\$1,018,604,042	424	\$536,549,154	395	\$551,336,204	419	\$541,336,204	454	\$628,827,006	306	\$327,739,149	361	\$523,225,062	458	\$743,828,586	324	\$938,015,530	-15.6%	55.7%
Ward 28	181	\$64,528,304	183	\$34,217,670	191	\$147,977,047	216	\$114,838,984	216	\$60,383,636	229	\$286,669,553	211	\$445,461,972	204	\$222,070,984	269	\$268,663,785	168	\$130,386,518	-20.4%	-28.7%
Ward 29	100	\$7,267,303	76	\$3,036,445	107	\$30,206,460	118	\$33,830,707	99	\$9,650,512	126	\$34,733,432	95	\$27,837,037	114	\$31,114,953	96	\$21,126,466	82	\$49,858,244	-20.7%	125.7%
Ward 30	133	\$110,406,042	126	\$14,462,444	156	\$29,770,748	129	\$14,322,856	108	\$20,773,430	93	\$13,692,395	97	\$62,660,895	88	\$49,110,174	109	\$33,336,722	108	\$25,082,098	-6.4%	-35.2%
Ward 31	77	\$14,431,706	91	\$7,632,320	99	\$8,270,550	84	\$25,854,645	80	\$28,300,830	77	\$14,151,202	78	\$23,780,321	58	\$10,208,201	67	\$15,940,303	68	\$42,625,252	-13.9%	158.2%
Ward 32	330	\$85,861,061	314	\$103,490,111	361	\$167,551,132	345	\$197,675,533	279	\$116,710,647	307	\$92,423,794	224	\$114,367,025	250	\$94,507,986	228	\$68,287,862	200	\$85,712,646	-31.8%	-25.9%
Ward 33	171	\$18,917,489	140	\$13,278,017	145	\$17,900,167	189	\$24,856,221	148	\$88,880,519	126	\$16,413,140	93	\$16,429,231	130	\$29,626,286	122	\$24,991,695	95	\$29,987,895	-32.4%	7.4%
Ward 34	490	\$491,262,674	416	\$534,921,922	477	\$488,349,905	495	\$1,121,104,458	479	\$988,167,345	473	\$829,826,946	312	\$784,351,330	256	\$534,348,867	302	\$423,792,277	206	\$402,075,746	-49.9%	-41.6%
Ward 35	174	\$21,586,974	187	\$22,196,810	172	\$20,257,633	214	\$27,210,757	210	\$64,240,722	191	\$79,480,443	148	\$63,668,494	154	\$26,952,387	154	\$38,893,120	134	\$63,757,152	-24.8%	57.4%
Ward 36	151	\$31,550,441	161	\$36,924,560	161	\$31,533,080	164	\$19,373,931	176	\$37,799,604	160	\$66,624,520	135	\$32,549,640	111	\$44,300,758	111	\$34,128,808	105	\$48,806,961	-28.9%	31.2%
Ward 37	105	\$22,698,719	105	\$4,875,550	123	\$7,041,190	111	\$7,674,938	146	\$9,968,120	131	\$19,626,145	105	\$10,425,401	95	\$189,870,183	138	\$41,893,088	104	\$44,642,371	-11.6%	27.9%
Ward 38	99	\$7,414,996	93	\$20,998,990	123	\$12,159,350	105	\$19,959,534	114	\$66,598,168	102	\$25,297,622	82	\$22,537,529	58	\$5,393,170	67	\$19,522,701	46	\$5,682,234	-50.9%	-74.4%
Ward 39	123	\$18,675,002	103	\$134,560,488	153	\$16,270,951	168	\$29,240,610	168	\$43,707,121	143	\$80,953,855	114	\$21,062,141	128	\$82,043,243	106	\$33,652,701	94	\$27,181,951	-29.9%	-46.8%
Ward 40	160	\$31,591,250	156	\$29,491,690	132	\$24,365,146	148	\$29,664,163	178	\$38,204,673	157	\$25,360,870	109	\$31,434,180	118	\$30,540,994	141	\$67,706,924	141	\$48,894,719	-2.3%	42.7%
Ward 41	142	\$84,393,081	142	\$95,142,002	177	\$365,160,737	177	\$422,246,494	205	\$208,552,267	195	\$306,536,510	165	\$211,476,818	134	\$111,981,380	157	\$146,446,190	126	\$189,481,199	-24.1%	-12.6%
Ward 42	813	\$1,066,252,653	853	\$1,228,375,094	931	\$1,452,148,891	883	\$862,149,392	969	\$1,694,635,363	856	\$778,619,100	588	\$2,147,152,375	522	\$623,906,036	599	\$655,002,898	571	\$601,129,969	-26.7%	-48.5%
Ward 43	262	\$93,503,529	258	\$210,230,563	236	\$473,418,097	266	\$227,969,594	244	\$80,400,441	231	\$206,180,905	169	\$107,911,734	221	\$115,890,690	234	\$163,778,851	183	\$85,226,319	-22.3%	-54.3%
Ward 44	194	\$74,947,098	209	\$230,728,887	219	\$272,787,316	231	\$112,577,990	218	\$77,796,396	161	\$63,774,986	161	\$101,888,314	150	\$48,917,077	156	\$66,005,339	143	\$159,639,006	-24.2%	36.9%
Ward 45	127	\$27,188,792	127	\$32,662,494	144	\$16,897,484	158	\$16,358,150	154	\$104,583,426	155	\$30,539,287	117	\$28,979,610	131	\$114,529,215	121	\$57,609,707	104	\$31,463,789	-24.1%	-34.0%
Ward 46	80	\$16,832,236	86	\$64,576,358	80	\$34,239,651	84	\$157,553,845	127	\$85,186,680	83	\$43,882,317	65	\$83,320,74								



CITY OF CHICAGO



DEPARTMENT OF BUILDINGS

MEMORANDUM

To: The Honorable Jason Ervin
Chairman, Committee on the Budget and Government Operations

From: Matthew Beaudet
Commissioner
Department

CC: Elizabeth Beatty
Mayor's Office of Intergovernmental Affairs

Date: **November 8, 2023**

Re: Request for Information from Annual Appropriation Committee Hearing

ID#: 67-05

The following information is provided in response to questions posed at our department's hearing on October 25, 2023, to discuss the proposed 2024 budget.

Alderman Lawson asked for the ten-year trend for time to permit. Please see attached.

As always, please let me know if you have any further questions.

Average Permit Application Timing for Plan-Based Building Permits (Excl. Developer Services)

Time Period	Average Time with DOB	Average Time with Applicant	Average Time to Permit
2017	26.09	41.02	67.11
2018	24.23	38.56	62.79
2019	28.95	39.09	68.04
2020	27.49	43.89	71.38
2021	32.21	43.12	75.33
2022	37.97	45.37	83.34
2023 Q1-Q3	38.59	52.77	91.36
Jan	41.42	65.07	106.49
Feb	42.57	58.78	101.35
Mar	42.13	59.48	101.62
Apr	39.83	51.37	91.20
May	38.73	51.35	90.08
Jun	34.68	50.76	85.44
Jul	38.36	49.60	87.96
Aug	35.64	43.17	78.82
Sep	34.51	48.33	82.84

* Time to permit was not tracked with a consistent method prior to 2017



CITY OF CHICAGO

DEPARTMENT OF BUILDINGS

MEMORANDUM

To: The Honorable Jason Ervin
Chairman, Committee on the Budget and Government Operations

From: Matthew Beaudet
Commissioner
Department

CC: Elizabeth Beatty
Mayor's Office of Intergovernmental Affairs

Date: **November 8, 2023**

Re: Request for Information from Annual Appropriation Committee Hearing

ID#: 67-06

The following information is provided in response to questions posed at our department's hearing on October 25, 2023, to discuss the proposed 2024 budget.

Alderman Lopez asked for a list of all vacant registered buildings by ward. Please see attached.

As always, please let me know if you have any further questions.

Address	Ward	Police District	Community Area	Category Type	E-mail Address	Issuance Date	Expires
7125 S GREENWOOD AVE	05	03	69	GOVERNMENT ENTITY	info@cookcountylandbank.org	12/09/2019	12/9/2023
7440 S SOUTH CHICAGO AVE	05	03	69	GOVERNMENT ENTITY	info@cookcountylandbank.org	10/06/2021	10/6/2023
1216 E 71ST PL	05	03	69	GOVERNMENT ENTITY	info@cookcountylandbank.org	07/05/2022	1/5/2024
7212 S SOUTH CHICAGO AVE	05	03	69	GOVERNMENT ENTITY	info@cookcountylandbank.org	12/06/2022	12/6/2023
514 W 66TH PL	06	07	68	GOVERNMENT ENTITY	info@cookcountylandbank.org	08/24/2017	2/24/2024
7245 S PRINCETON AVE	06	07	69	GOVERNMENT ENTITY	info@cookcountylandbank.org	12/11/2017	12/11/2023
657 E 75TH ST	06	06	69	GOVERNMENT ENTITY	info@cookcountylandbank.org	09/18/2018	3/18/2024
6711 S PARNELL AVE	06	07	68	GOVERNMENT ENTITY	info@cookcountylandbank.org	02/01/2019	2/1/2024
160 W 70TH ST	06	07	69	GOVERNMENT ENTITY	info@cookcountylandbank.org	08/07/2019	2/7/2024
6740 S PERRY AVE	06	07	69	GOVERNMENT ENTITY	info@cookcountylandbank.org	08/07/2019	2/7/2024
6837 S EVANS AVE	06	03	42	GOVERNMENT ENTITY	info@cookcountylandbank.org	08/07/2019	2/7/2024
7946 S PARNELL AVE	06	06	44	GOVERNMENT ENTITY	info@cookcountylandbank.org	08/07/2019	2/7/2024
6813 S STATE ST	06	03	69	GOVERNMENT ENTITY	info@cookcountylandbank.org	08/07/2019	2/7/2024
7411 S DREXEL AVE	06	03	69	GOVERNMENT ENTITY	info@cookcountylandbank.org	11/01/2019	11/1/2023
6642 S MICHIGAN AVE	06	03	69	GOVERNMENT ENTITY	info@cookcountylandbank.org	10/24/2019	10/24/2023
524 E 70TH ST	06	03	69	GOVERNMENT ENTITY	info@cookcountylandbank.org	10/24/2019	10/24/2023
7603 S RHODES AVE	06	06	69	GOVERNMENT ENTITY	info@cookcountylandbank.org	10/24/2019	10/24/2023
115 E 71ST ST	06	03	69	GOVERNMENT ENTITY	info@cookcountylandbank.org	10/24/2019	10/24/2023
7019 S YALE AVE	06	07	69	GOVERNMENT ENTITY	info@cookcountylandbank.org	10/24/2019	10/24/2023
555 E 67TH ST	06	03	42	GOVERNMENT ENTITY	info@cookcountylandbank.org	12/20/2019	12/20/2023
426 W 66TH PL	06	07	68	GOVERNMENT ENTITY	info@cookcountylandbank.org	01/08/2020	1/8/2024
656 W MARQUETTE RD	06	07	68	GOVERNMENT ENTITY	info@cookcountylandbank.org	06/24/2020	12/24/2023
8223 S EMERALD AVE	06	06	71	GOVERNMENT ENTITY	info@cookcountylandbank.org	12/13/2021	12/13/2023
7134 S HARVARD AVE	06	07	69	GOVERNMENT ENTITY	info@cookcountylandbank.org	12/27/2021	1/14/2024
7948 S PARNELL AVE	06	06	44	GOVERNMENT ENTITY	info@cookcountylandbank.org	02/07/2022	2/7/2024
100 W 72ND ST	06	07	69	GOVERNMENT ENTITY	info@cookcountylandbank.org	02/22/2022	2/22/2024
7104 S CHAMPLAIN AVE	06	03	69	GOVERNMENT ENTITY	info@cookcountylandbank.org	02/22/2022	1/12/2024
8049 S VINCENNES AVE	06	06	44	GOVERNMENT ENTITY	info@cookcountylandbank.org	04/11/2022	10/11/2023
6752 S LOWE AVE	06	07	68	GOVERNMENT ENTITY	info@cookcountylandbank.org	06/30/2022	12/30/2023
712 E 72ND ST	06	03	69	GOVERNMENT ENTITY	info@cookcountylandbank.org	08/29/2022	2/28/2024
333 W 70TH ST	06	07	69	GOVERNMENT ENTITY	info@cookcountylandbank.org	08/31/2022	2/28/2024
7210 S LOWE AVE	06	07	68	GOVERNMENT ENTITY	info@cookcountylandbank.org	10/04/2022	10/4/2023
7359 S EMERALD AVE	06	07	68	GOVERNMENT ENTITY	info@cookcountylandbank.org	10/04/2022	10/4/2023
7337 S HARVARD AVE	06	07	69	GOVERNMENT ENTITY	info@cookcountylandbank.org	10/04/2022	10/4/2023
7253 S EMERALD AVE	06	07	68	GOVERNMENT ENTITY	info@cookcountylandbank.org	10/04/2022	10/4/2023
7233 S EMERALD AVE	06	07	68	GOVERNMENT ENTITY	info@cookcountylandbank.org	10/04/2022	10/4/2023
6844 S EMERALD AVE	06	07	68	GOVERNMENT ENTITY	info@cookcountylandbank.org	10/06/2022	10/6/2023
7418 S NORMAL AVE	06	07	68	GOVERNMENT ENTITY	info@cookcountylandbank.org	10/06/2022	10/6/2023

7419 S NORMAL AVE	06	07	68	GOVERNMENT ENTITY	info@cookcountylandbank.org	10/06/2022	10/6/2023
601 W 70TH ST	06	07	68	GOVERNMENT ENTITY	info@cookcountylandbank.org	03/22/2023	3/22/2024
8013 S EMERALD AVE	06	06	71	GOVERNMENT ENTITY	info@cookcountylandbank.org	09/01/2023	3/1/2024
7558 S HARVARD AVE	06	06	69	GOVERNMENT ENTITY	info@cookcountylandbank.org	09/14/2023	3/14/2024
7206 S EVANS AVE	06	03	69	GOVERNMENT ENTITY	info@cookcountylandbank.org	09/14/2023	3/14/2024
8831 S STATE ST	06	06	44	GOVERNMENT ENTITY	info@cookcountylandbank.org	09/14/2023	3/14/2024
6859 S CALUMET AVE	06	03	69	GOVERNMENT ENTITY	info@cookcountylandbank.org	09/14/2023	3/14/2024
6747 S PRAIRIE AVE	06	03	69	GOVERNMENT ENTITY	info@cookcountylandbank.org	09/14/2023	3/14/2024
7531 S NORMAL AVE	06	06	69	GOVERNMENT ENTITY	info@cookcountylandbank.org	09/20/2023	3/20/2024
2635 E 79TH ST	07	04	46	GOVERNMENT ENTITY	info@cookcountylandbank.org	02/02/2021	2/2/2024
7959 S ESCANABA AVE	07	04	46	GOVERNMENT ENTITY	info@cookcountylandbank.org	07/05/2022	1/5/2024
2129 E 97TH PL	07	04	51	GOVERNMENT ENTITY	info@cookcountylandbank.org	09/01/2023	3/1/2024
7714 S DREXEL AVE	08	06	69	GOVERNMENT ENTITY	info@cookcountylandbank.org	08/07/2019	2/7/2024
7525 S ELLIS AVE	08	06	69	GOVERNMENT ENTITY	info@cookcountylandbank.org	10/24/2019	10/24/2023
7535 S DREXEL AVE	08	06	69	GOVERNMENT ENTITY	info@cookcountylandbank.org	10/24/2019	10/24/2023
7527 S ELLIS AVE	08	06	69	GOVERNMENT ENTITY	info@cookcountylandbank.org	10/24/2019	10/24/2023
7643 S DREXEL AVE	08	06	69	GOVERNMENT ENTITY	info@cookcountylandbank.org	10/24/2019	10/24/2023
2053 E 79TH ST	08	04	46	GOVERNMENT ENTITY	info@cookcountylandbank.org	02/02/2021	2/2/2024
1216 E 95TH ST	08	04	47	GOVERNMENT ENTITY	info@cookcountylandbank.org	05/04/2021	11/4/2023
1716 E 79TH ST	08	04	43	GOVERNMENT ENTITY	info@cookcountylandbank.org	05/20/2021	1/21/2024
1225 E 79TH ST	08	04	45	GOVERNMENT ENTITY	info@cookcountylandbank.org	07/07/2021	1/7/2024
8321 S STONY ISLAND AVE	08	04	45	GOVERNMENT ENTITY	info@cookcountylandbank.org	07/19/2021	1/19/2024
1212 E 95TH ST	08	04	47	GOVERNMENT ENTITY	info@cookcountylandbank.org	12/13/2021	12/13/2023
9253 S COTTAGE GROVE AVE	08	06	44	GOVERNMENT ENTITY	info@cookcountylandbank.org	12/13/2021	12/13/2023
8950 S COTTAGE GROVE AVE	08	06	44	GOVERNMENT ENTITY	info@cookcountylandbank.org	12/13/2021	12/13/2023
7816 S DREXEL AVE	08	06	69	GOVERNMENT ENTITY	info@cookcountylandbank.org	02/22/2022	2/22/2024
9236 S COTTAGE GROVE AVE	08	06	44	GOVERNMENT ENTITY	info@cookcountylandbank.org	07/05/2022	1/5/2024
825 E 88TH PL	08	06	44	GOVERNMENT ENTITY	info@cookcountylandbank.org	07/05/2022	1/5/2024
9219 S WOODLAWN AVE	08	04	47	GOVERNMENT ENTITY	info@cookcountylandbank.org	07/26/2022	1/26/2024
7534 S MARYLAND AVE	08	06	69	GOVERNMENT ENTITY	info@cookcountylandbank.org	03/30/2023	2/21/2024
807 E 88TH ST	08	06	44	GOVERNMENT ENTITY	info@cookcountylandbank.org	05/31/2023	11/30/2023
2011 E 75TH ST	08	04	43	GOVERNMENT ENTITY	info@cookcountylandbank.org	09/01/2023	3/1/2024
7541 S DANTE AVE	08	04	43	GOVERNMENT ENTITY	info@cookcountylandbank.org	09/14/2023	3/14/2024
125 W 107TH ST	09	05	49	GOVERNMENT ENTITY	info@cookcountylandbank.org	10/31/2019	10/30/2023
23 W 115TH ST	09	05	53	GOVERNMENT ENTITY	info@cookcountylandbank.org	11/01/2019	11/1/2023
107 W 116TH ST	09	05	53	GOVERNMENT ENTITY	info@cookcountylandbank.org	11/01/2019	11/1/2023
114 W 119TH ST	09	05	53	GOVERNMENT ENTITY	info@cookcountylandbank.org	11/01/2019	11/1/2023
41 W 114TH PL	09	05	49	GOVERNMENT ENTITY	info@cookcountylandbank.org	11/18/2019	11/18/2023
11421 S PRINCETON AVE	09	05	49	GOVERNMENT ENTITY	info@cookcountylandbank.org	12/18/2019	12/18/2023
11436 S YALE AVE	09	05	49	GOVERNMENT ENTITY	info@cookcountylandbank.org	12/18/2019	12/18/2023

46 W 114TH PL	09	05	49	GOVERNMENT ENTITY	info@cookcountylandbank.org	12/20/2019	12/20/2023
10954 S MICHIGAN AVE	09	05	49	GOVERNMENT ENTITY	info@cookcountylandbank.org	05/08/2020	11/8/2023
11932 S PRAIRIE AVE	09	05	53	GOVERNMENT ENTITY	info@cookcountylandbank.org	05/08/2020	11/8/2023
11725 S MICHIGAN AVE	09	05	53	GOVERNMENT ENTITY	info@cookcountylandbank.org	05/04/2021	11/4/2023
437 E 103RD ST	09	05	49	GOVERNMENT ENTITY	info@cookcountylandbank.org	06/03/2021	12/3/2023
11439 S PERRY AVE	09	05	49	GOVERNMENT ENTITY	info@cookcountylandbank.org	07/07/2021	1/7/2024
10433 S MICHIGAN AVE	09	05	49	GOVERNMENT ENTITY	info@cookcountylandbank.org	07/07/2021	1/7/2024
11359 S MICHIGAN AVE	09	05	49	GOVERNMENT ENTITY	info@cookcountylandbank.org	07/07/2021	1/7/2024
201 W 119TH ST	09	05	53	GOVERNMENT ENTITY	info@cookcountylandbank.org	07/19/2021	1/19/2024
102 W 116TH ST	09	05	53	GOVERNMENT ENTITY	info@cookcountylandbank.org	07/19/2021	1/19/2024
126 E 127TH ST	09	05	53	GOVERNMENT ENTITY	info@cookcountylandbank.org	07/19/2021	1/19/2024
10432 S MARYLAND AVE	09	05	50	GOVERNMENT ENTITY	info@cookcountylandbank.org	12/13/2021	12/13/2023
10434 S MARYLAND AVE	09	05	50	GOVERNMENT ENTITY	info@cookcountylandbank.org	12/13/2021	12/13/2023
11336 S YALE AVE	09	05	49	GOVERNMENT ENTITY	info@cookcountylandbank.org	12/13/2021	12/13/2023
163 E 116TH ST	09	05	53	GOVERNMENT ENTITY	info@cookcountylandbank.org	12/13/2021	12/13/2023
11415 S MICHIGAN AVE	09	05	49	GOVERNMENT ENTITY	info@cookcountylandbank.org	12/13/2021	12/13/2023
11919 S PRAIRIE AVE	09	05	53	GOVERNMENT ENTITY	info@cookcountylandbank.org	12/13/2021	12/13/2023
47 W 103RD ST	09	05	49	GOVERNMENT ENTITY	info@cookcountylandbank.org	12/13/2021	12/13/2023
11355 S MICHIGAN AVE	09	05	49	GOVERNMENT ENTITY	info@cookcountylandbank.org	12/13/2021	12/13/2023
10549 S LAFAYETTE AVE	09	05	49	GOVERNMENT ENTITY	info@cookcountylandbank.org	02/07/2022	2/7/2024
111 W 110TH PL	09	05	49	GOVERNMENT ENTITY	info@cookcountylandbank.org	03/10/2022	3/10/2024
123 E 111TH ST	09	05	49	GOVERNMENT ENTITY	info@cookcountylandbank.org	06/30/2022	11/27/2023
20 E 113TH PL	09	05	49	GOVERNMENT ENTITY	info@cookcountylandbank.org	08/31/2022	2/28/2024
116 W 119TH ST	09	05	53	GOVERNMENT ENTITY	info@cookcountylandbank.org	09/29/2022	3/25/2024
12432 S NORMAL AVE	09	05	53	GOVERNMENT ENTITY	info@cookcountylandbank.org	10/13/2022	10/13/2023
11310 S PRAIRIE AVE	09	05	49	GOVERNMENT ENTITY	info@cookcountylandbank.org	02/27/2023	1/21/2024
11312 S PRAIRIE AVE	09	05	49	GOVERNMENT ENTITY	info@cookcountylandbank.org	03/30/2023	1/21/2024
12346 S MICHIGAN AVE	09	05	53	GOVERNMENT ENTITY	info@cookcountylandbank.org	05/24/2023	11/24/2023
116 W 114TH ST	09	05	49	GOVERNMENT ENTITY	info@cookcountylandbank.org	06/12/2023	12/12/2023
10051 S LOWE AVE	09	22	73	GOVERNMENT ENTITY	info@cookcountylandbank.org	08/28/2023	2/28/2024
10728 S EDBROOKE AVE	09	05	49	GOVERNMENT ENTITY	info@cookcountylandbank.org	09/01/2023	3/1/2024
206 W 112TH PL	09	05	49	GOVERNMENT ENTITY	info@cookcountylandbank.org	09/06/2023	3/6/2024
245 W 111TH ST	09	05	49	GOVERNMENT ENTITY	info@cookcountylandbank.org	09/06/2023	3/6/2024
144 E 116TH ST	09	05	53	GOVERNMENT ENTITY	info@cookcountylandbank.org	09/06/2023	3/6/2024
10753 S INDIANA AVE	09	05	49	GOVERNMENT ENTITY	info@cookcountylandbank.org	09/11/2023	3/11/2024
22 W 114TH ST	09	05	49	GOVERNMENT ENTITY	info@cookcountylandbank.org	09/11/2023	3/11/2024
10725 S STATE ST	09	05	49	GOVERNMENT ENTITY	info@cookcountylandbank.org	09/20/2023	3/20/2024
2936 E 87TH ST	10	04	46	GOVERNMENT ENTITY	info@cookcountylandbank.org	02/02/2021	2/2/2024
3217 E 92ND ST	10	04	46	GOVERNMENT ENTITY	info@cookcountylandbank.org	03/08/2021	3/8/2024
3219 E 92ND ST	10	04	46	GOVERNMENT ENTITY	info@cookcountylandbank.org	03/08/2021	3/8/2024

8854 S COMMERCIAL AVE	10	04	46	GOVERNMENT ENTITY	info@cookcountylandbank.org	05/04/2021	11/4/2023
8559 S MUSKEGON AVE	10	04	46	GOVERNMENT ENTITY	info@cookcountylandbank.org	12/13/2021	12/13/2023
3216 E 92ND ST	10	04	46	GOVERNMENT ENTITY	info@cookcountylandbank.org	12/13/2021	12/13/2023
9733 S AVENUE N	10	04	52	GOVERNMENT ENTITY	info@cookcountylandbank.org	02/07/2022	2/7/2024
3533 E 106TH ST	10	04	52	GOVERNMENT ENTITY	info@cookcountylandbank.org	03/10/2022	3/10/2024
8514 S BUFFALO AVE	10	04	46	GOVERNMENT ENTITY	info@cookcountylandbank.org	07/05/2022	1/5/2024
10840 S BUFFALO AVE	10	04	52	GOVERNMENT ENTITY	info@cookcountylandbank.org	07/14/2022	1/14/2024
9924 S AVENUE J	10	04	52	GOVERNMENT ENTITY	info@cookcountylandbank.org	03/21/2023	3/21/2024
9953 S AVENUE H	10	04	52	GOVERNMENT ENTITY	info@cookcountylandbank.org	07/31/2023	1/31/2024
9844 S AVENUE L	10	04	52	GOVERNMENT ENTITY	info@cookcountylandbank.org	09/11/2023	3/11/2024
5134 S KEDZIE AVE	14	08	63	GOVERNMENT ENTITY	info@cookcountylandbank.org	12/27/2021	12/27/2023
6342 S PAULINA ST	15	07	67	GOVERNMENT ENTITY	info@cookcountylandbank.org	12/20/2019	12/20/2023
6441 S MARSHFIELD AVE	15	07	67	GOVERNMENT ENTITY	info@cookcountylandbank.org	12/20/2019	12/20/2023
5741 S SEELEY AVE	15	07	67	GOVERNMENT ENTITY	info@cookcountylandbank.org	01/23/2020	1/23/2024
723 W 47TH ST	15	09	61	GOVERNMENT ENTITY	info@cookcountylandbank.org	05/20/2021	1/29/2024
1956 W 51ST ST	15	09	61	GOVERNMENT ENTITY	info@cookcountylandbank.org	10/06/2021	10/6/2023
6032 S PAULINA ST	15	07	67	GOVERNMENT ENTITY	info@cookcountylandbank.org	03/31/2022	9/30/2023
718 W 48TH ST	15	09	61	GOVERNMENT ENTITY	info@cookcountylandbank.org	08/31/2022	2/28/2024
1815 W 59TH ST	15	07	67	GOVERNMENT ENTITY	info@cookcountylandbank.org	09/20/2022	3/20/2024
4432 S HERMITAGE AVE	15	09	61	GOVERNMENT ENTITY	info@cookcountylandbank.org	12/28/2022	12/28/2023
4332 S HERMITAGE AVE	15	09	61	GOVERNMENT ENTITY	info@cookcountylandbank.org	01/11/2023	1/11/2024
5924 S BISHOP ST	16	07	67	GOVERNMENT ENTITY	info@cookcountylandbank.org	10/26/2017	10/26/2023
620 W 60TH ST	16	07	68	GOVERNMENT ENTITY	info@cookcountylandbank.org	10/24/2019	10/24/2023
6349 S ABERDEEN ST	16	07	68	GOVERNMENT ENTITY	info@cookcountylandbank.org	10/24/2019	10/24/2023
618 W 61ST ST	16	07	68	GOVERNMENT ENTITY	info@cookcountylandbank.org	10/24/2019	10/24/2023
6732 S WINCHESTER AVE	16	07	67	GOVERNMENT ENTITY	info@cookcountylandbank.org	11/07/2019	11/7/2023
713 W 59TH ST	16	07	68	GOVERNMENT ENTITY	info@cookcountylandbank.org	11/18/2019	11/18/2023
6754 S WOLCOTT AVE	16	07	67	GOVERNMENT ENTITY	info@cookcountylandbank.org	12/09/2019	12/9/2023
6731 S HONORE ST	16	07	67	GOVERNMENT ENTITY	info@cookcountylandbank.org	12/09/2019	12/9/2023
2046 W 68TH PL	16	07	67	GOVERNMENT ENTITY	info@cookcountylandbank.org	12/09/2019	12/9/2023
6643 S HONORE ST	16	07	67	GOVERNMENT ENTITY	info@cookcountylandbank.org	12/09/2019	12/9/2023
6139 S ABERDEEN ST	16	07	68	GOVERNMENT ENTITY	info@cookcountylandbank.org	12/20/2019	12/20/2023
1139 W 61ST ST	16	07	68	GOVERNMENT ENTITY	info@cookcountylandbank.org	12/20/2019	12/20/2023
2017 W 65TH ST	16	07	67	GOVERNMENT ENTITY	info@cookcountylandbank.org	12/20/2019	12/20/2023
5964 S LOWE AVE	16	07	68	GOVERNMENT ENTITY	info@cookcountylandbank.org	01/24/2020	1/24/2024
6829 S DAMEN AVE	16	07	67	GOVERNMENT ENTITY	info@cookcountylandbank.org	01/24/2020	1/24/2024
2033 W 68TH PL	16	07	67	GOVERNMENT ENTITY	info@cookcountylandbank.org	02/03/2020	2/3/2024
2447 W LITHUANIAN PLAZA CT	16	08	66	GOVERNMENT ENTITY	info@cookcountylandbank.org	07/22/2020	1/22/2024
6743 S HONORE ST	16	07	67	GOVERNMENT ENTITY	info@cookcountylandbank.org	07/28/2020	2/4/2024
2057 W 68TH ST	16	07	67	GOVERNMENT ENTITY	info@cookcountylandbank.org	07/28/2020	2/4/2024

6522 S WINCHESTER AVE	16	07	67	GOVERNMENT ENTITY	info@cookcountylandbank.org	03/02/2021	12/2/2023
6728 S ASHLAND AVE	16	07	67	GOVERNMENT ENTITY	info@cookcountylandbank.org	05/06/2021	11/6/2023
6734 S ASHLAND AVE	16	07	67	GOVERNMENT ENTITY	info@cookcountylandbank.org	05/06/2021	11/6/2023
6726 S ASHLAND AVE	16	07	67	GOVERNMENT ENTITY	info@cookcountylandbank.org	05/06/2021	11/6/2023
818 W 71ST ST	16	07	68	GOVERNMENT ENTITY	info@cookcountylandbank.org	06/01/2021	12/1/2023
6142 S ASHLAND AVE	16	07	67	GOVERNMENT ENTITY	info@cookcountylandbank.org	06/03/2021	12/3/2023
5532 S RACINE AVE	16	07	67	GOVERNMENT ENTITY	info@cookcountylandbank.org	07/07/2021	1/7/2024
5640 S GREEN ST	16	07	68	GOVERNMENT ENTITY	info@cookcountylandbank.org	10/06/2021	10/6/2023
5149 S HERMITAGE AVE	16	09	61	GOVERNMENT ENTITY	info@cookcountylandbank.org	10/06/2021	10/6/2023
5157 S DAMEN AVE	16	09	61	GOVERNMENT ENTITY	info@cookcountylandbank.org	10/06/2021	10/6/2023
5320 S HONORE ST	16	09	61	GOVERNMENT ENTITY	info@cookcountylandbank.org	10/06/2021	10/6/2023
5355 S WOOD ST	16	09	61	GOVERNMENT ENTITY	info@cookcountylandbank.org	10/06/2021	10/6/2023
5400 S WOOD ST	16	09	61	GOVERNMENT ENTITY	info@cookcountylandbank.org	10/06/2021	10/6/2023
5409 S PAULINA ST	16	09	61	GOVERNMENT ENTITY	info@cookcountylandbank.org	10/06/2021	10/6/2023
5644 S GREEN ST	16	07	68	GOVERNMENT ENTITY	info@cookcountylandbank.org	10/06/2021	10/6/2023
6600 S CAMPBELL AVE	16	08	66	GOVERNMENT ENTITY	info@cookcountylandbank.org	12/27/2021	12/27/2023
5609 S LOOMIS BLVD	16	07	67	GOVERNMENT ENTITY	info@cookcountylandbank.org	12/27/2021	12/27/2023
5617 S LOOMIS BLVD	16	07	67	GOVERNMENT ENTITY	info@cookcountylandbank.org	12/27/2021	12/27/2023
6119 S BISHOP ST	16	07	67	GOVERNMENT ENTITY	info@cookcountylandbank.org	12/27/2021	12/27/2023
5119 S WINCHESTER AVE	16	09	61	GOVERNMENT ENTITY	info@cookcountylandbank.org	02/22/2022	2/22/2024
6029 S LAFLIN ST	16	07	67	GOVERNMENT ENTITY	info@cookcountylandbank.org	02/22/2022	2/22/2024
6208 S BISHOP ST	16	07	67	GOVERNMENT ENTITY	info@cookcountylandbank.org	02/22/2022	2/22/2024
6235 S BISHOP ST	16	07	67	GOVERNMENT ENTITY	info@cookcountylandbank.org	02/22/2022	2/22/2024
1125 W 59TH ST	16	07	68	GOVERNMENT ENTITY	info@cookcountylandbank.org	02/22/2022	2/22/2024
5530 S MARSHFIELD AVE	16	07	67	GOVERNMENT ENTITY	info@cookcountylandbank.org	02/22/2022	2/22/2024
5748 S MARSHFIELD AVE	16	07	67	GOVERNMENT ENTITY	info@cookcountylandbank.org	02/22/2022	2/22/2024
6506 S MORGAN ST	16	07	68	GOVERNMENT ENTITY	info@cookcountylandbank.org	03/10/2022	10/5/2023
2119 W 54TH PL	16	09	61	GOVERNMENT ENTITY	info@cookcountylandbank.org	03/22/2022	3/22/2024
6140 S ADA ST	16	07	67	GOVERNMENT ENTITY	info@cookcountylandbank.org	03/29/2022	3/29/2024
5211 S BISHOP ST	16	09	61	GOVERNMENT ENTITY	info@cookcountylandbank.org	03/31/2022	9/30/2023
5708 S JUSTINE ST	16	07	67	GOVERNMENT ENTITY	info@cookcountylandbank.org	05/02/2022	11/2/2023
5156 S BISHOP ST	16	09	61	GOVERNMENT ENTITY	info@cookcountylandbank.org	05/02/2022	11/2/2023
5305 S CARPENTER ST	16	09	61	GOVERNMENT ENTITY	info@cookcountylandbank.org	05/02/2022	11/2/2023
6056 S WOLCOTT AVE	16	07	67	GOVERNMENT ENTITY	info@cookcountylandbank.org	05/23/2022	11/23/2023
5355 S ABERDEEN ST	16	09	61	GOVERNMENT ENTITY	info@cookcountylandbank.org	05/31/2022	11/30/2023
6118 S THROOP ST	16	07	67	GOVERNMENT ENTITY	info@cookcountylandbank.org	06/21/2022	12/21/2023
5629 S MORGAN ST	16	07	68	GOVERNMENT ENTITY	info@cookcountylandbank.org	07/26/2022	1/26/2024
5545 S SANGAMON ST	16	07	68	GOVERNMENT ENTITY	info@cookcountylandbank.org	07/26/2022	1/26/2024
739 W 54TH PL	16	09	61	GOVERNMENT ENTITY	info@cookcountylandbank.org	08/31/2022	2/28/2024
2717 W 59TH ST	16	08	66	GOVERNMENT ENTITY	info@cookcountylandbank.org	08/31/2022	2/28/2024

5419 S ABERDEEN ST	16	09	61	GOVERNMENT ENTITY	info@cookcountylandbank.org	08/31/2022	2/28/2024
1334 W 56TH ST	16	07	67	GOVERNMENT ENTITY	info@cookcountylandbank.org	08/31/2022	2/28/2024
900 W 59TH ST	16	07	68	GOVERNMENT ENTITY	info@cookcountylandbank.org	08/31/2022	2/28/2024
6518 S ABERDEEN ST	16	07	68	GOVERNMENT ENTITY	info@cookcountylandbank.org	09/20/2022	3/20/2024
6823 S ABERDEEN ST	16	07	68	GOVERNMENT ENTITY	info@cookcountylandbank.org	10/04/2022	10/4/2023
6339 S ELIZABETH ST	16	07	67	GOVERNMENT ENTITY	info@cookcountylandbank.org	10/06/2022	10/6/2023
6501 S BISHOP ST	16	07	67	GOVERNMENT ENTITY	info@cookcountylandbank.org	10/06/2022	10/6/2023
5759 S SANGAMON ST	16	07	68	GOVERNMENT ENTITY	info@cookcountylandbank.org	11/30/2022	11/30/2023
5531 S ELIZABETH ST	16	07	67	GOVERNMENT ENTITY	info@cookcountylandbank.org	12/28/2022	12/28/2023
5928 S GREEN ST	16	07	68	GOVERNMENT ENTITY	info@cookcountylandbank.org	02/16/2023	2/16/2024
724 W 59TH ST	16	07	68	GOVERNMENT ENTITY	info@cookcountylandbank.org	03/29/2023	3/29/2024
6924 S GREEN ST	16	07	68	GOVERNMENT ENTITY	info@cookcountylandbank.org	03/30/2023	9/30/2023
1325 W 73RD PL	17	07	67	GOVERNMENT ENTITY	info@cookcountylandbank.org	08/05/2019	2/5/2024
1273 W 74TH PL	17	07	67	GOVERNMENT ENTITY	info@cookcountylandbank.org	08/05/2019	2/5/2024
1276 W 72ND PL	17	07	67	GOVERNMENT ENTITY	info@cookcountylandbank.org	09/16/2019	3/16/2024
7042 S MARSHFIELD AVE	17	07	67	GOVERNMENT ENTITY	info@cookcountylandbank.org	10/24/2019	10/24/2023
7633 S MORGAN ST	17	06	71	GOVERNMENT ENTITY	info@cookcountylandbank.org	10/24/2019	10/24/2023
1305 W 72ND PL	17	07	67	GOVERNMENT ENTITY	info@cookcountylandbank.org	10/30/2019	10/30/2023
1249 W 72ND PL	17	07	67	GOVERNMENT ENTITY	info@cookcountylandbank.org	10/30/2019	10/30/2023
2010 W 70TH PL	17	07	67	GOVERNMENT ENTITY	info@cookcountylandbank.org	11/07/2019	11/7/2023
6820 S HONORE ST	17	07	67	GOVERNMENT ENTITY	info@cookcountylandbank.org	11/07/2019	11/7/2023
6839 S WOOD ST	17	07	67	GOVERNMENT ENTITY	info@cookcountylandbank.org	11/07/2019	11/7/2023
6837 S WOLCOTT AVE	17	07	67	GOVERNMENT ENTITY	info@cookcountylandbank.org	12/20/2019	12/20/2023
1240 W 72ND ST	17	07	67	GOVERNMENT ENTITY	info@cookcountylandbank.org	01/09/2020	2/7/2024
1508 W 73RD ST	17	07	67	GOVERNMENT ENTITY	info@cookcountylandbank.org	01/09/2020	1/9/2024
1322 W 73RD PL	17	07	67	GOVERNMENT ENTITY	info@cookcountylandbank.org	01/09/2020	1/9/2024
7114 S HERMITAGE AVE	17	07	67	GOVERNMENT ENTITY	info@cookcountylandbank.org	01/09/2020	1/9/2024
7012 S WINCHESTER AVE	17	07	67	GOVERNMENT ENTITY	info@cookcountylandbank.org	01/31/2020	2/7/2024
6830 S LOOMIS BLVD	17	07	67	GOVERNMENT ENTITY	info@cookcountylandbank.org	01/31/2020	1/31/2024
6837 S BISHOP ST	17	07	67	GOVERNMENT ENTITY	info@cookcountylandbank.org	01/31/2020	1/31/2024
7131 S MARSHFIELD AVE	17	07	67	GOVERNMENT ENTITY	info@cookcountylandbank.org	05/08/2020	11/8/2023
6916 S MARSHFIELD AVE	17	07	67	GOVERNMENT ENTITY	info@cookcountylandbank.org	06/24/2020	12/24/2023
7344 S MARSHFIELD AVE	17	07	67	GOVERNMENT ENTITY	info@cookcountylandbank.org	07/22/2020	2/4/2024
7032 S WOLCOTT AVE	17	07	67	GOVERNMENT ENTITY	info@cookcountylandbank.org	07/22/2020	2/4/2024
8204 S HALSTED ST	17	06	71	GOVERNMENT ENTITY	info@cookcountylandbank.org	06/03/2021	12/3/2023
7022 S WINCHESTER AVE	17	07	67	GOVERNMENT ENTITY	info@cookcountylandbank.org	07/07/2021	1/7/2024
1838 W 69TH ST	17	07	67	GOVERNMENT ENTITY	info@cookcountylandbank.org	07/07/2021	1/7/2024
1655 W 79TH ST	17	06	71	GOVERNMENT ENTITY	info@cookcountylandbank.org	12/13/2021	12/13/2023
8206 S HALSTED ST	17	06	71	GOVERNMENT ENTITY	info@cookcountylandbank.org	12/13/2021	12/13/2023
7356 S ASHLAND AVE	17	07	67	GOVERNMENT ENTITY	info@cookcountylandbank.org	12/27/2021	1/14/2024

8427 S SANGAMON ST	17	06	71	GOVERNMENT ENTITY	info@cookcountylandbank.org	02/07/2022	2/7/2024
6737 S LOOMIS BLVD	17	07	67	GOVERNMENT ENTITY	info@cookcountylandbank.org	02/22/2022	2/22/2024
7133 S RACINE AVE	17	07	68	GOVERNMENT ENTITY	info@cookcountylandbank.org	03/03/2022	2/23/2024
6915 S BISHOP ST	17	07	67	GOVERNMENT ENTITY	info@cookcountylandbank.org	05/02/2022	11/2/2023
6735 S LOOMIS BLVD	17	07	67	GOVERNMENT ENTITY	info@cookcountylandbank.org	05/23/2022	11/23/2023
7354 S ASHLAND AVE	17	07	67	GOVERNMENT ENTITY	info@cookcountylandbank.org	06/21/2022	1/14/2024
7311 S ABERDEEN ST	17	07	68	GOVERNMENT ENTITY	info@cookcountylandbank.org	08/31/2022	2/28/2024
7318 S ABERDEEN ST	17	07	68	GOVERNMENT ENTITY	info@cookcountylandbank.org	08/31/2022	2/28/2024
7301 S ABERDEEN ST	17	07	68	GOVERNMENT ENTITY	info@cookcountylandbank.org	09/20/2022	3/20/2024
944 W 73RD ST	17	07	68	GOVERNMENT ENTITY	info@cookcountylandbank.org	09/20/2022	3/20/2024
7412 S ABERDEEN ST	17	07	68	GOVERNMENT ENTITY	info@cookcountylandbank.org	10/04/2022	10/4/2023
7324 S SANGAMON ST	17	07	68	GOVERNMENT ENTITY	info@cookcountylandbank.org	10/04/2022	10/4/2023
7320 S HALSTED ST	17	07	68	GOVERNMENT ENTITY	info@cookcountylandbank.org	10/04/2022	10/4/2023
7328 S HALSTED ST	17	07	68	GOVERNMENT ENTITY	info@cookcountylandbank.org	10/04/2022	10/4/2023
7243 S ASHLAND AVE	17	07	67	GOVERNMENT ENTITY	info@cookcountylandbank.org	10/13/2022	10/13/2023
6810 S THROOP ST	17	07	67	GOVERNMENT ENTITY	info@cookcountylandbank.org	12/28/2022	12/28/2023
1275 W 74TH ST	17	07	67	GOVERNMENT ENTITY	info@cookcountylandbank.org	04/21/2023	10/21/2023
8315 S GREEN ST	17	06	71	GOVERNMENT ENTITY	info@cookcountylandbank.org	05/22/2023	11/22/2023
6942 S RACINE AVE	17	07	67	GOVERNMENT ENTITY	info@cookcountylandbank.org	05/31/2023	11/30/2023
8536 S MORGAN ST	17	06	71	GOVERNMENT ENTITY	info@cookcountylandbank.org	08/28/2023	2/28/2024
7646 S EMERALD AVE	17	06	71	GOVERNMENT ENTITY	info@cookcountylandbank.org	09/11/2023	3/11/2024
2444 W 71ST ST	17	08	66	GOVERNMENT ENTITY	info@cookcountylandbank.org	09/12/2023	3/12/2024
2315 W 72ND ST	18	08	66	GOVERNMENT ENTITY	info@cookcountylandbank.org	04/07/2020	3/27/2024
1722 W 87TH ST	18	06	71	GOVERNMENT ENTITY	info@cookcountylandbank.org	07/07/2021	1/7/2024
1720 W 87TH ST	18	06	71	GOVERNMENT ENTITY	info@cookcountylandbank.org	12/13/2021	12/13/2023
1925 W 87TH ST	19	22	71	GOVERNMENT ENTITY	info@cookcountylandbank.org	02/02/2021	2/2/2024
6300 S COTTAGE GROVE AVE	20	03	42	GOVERNMENT ENTITY	info@cookcountylandbank.org	12/12/2017	12/12/2023
6647 S LANGLEY AVE	20	03	42	GOVERNMENT ENTITY	info@cookcountylandbank.org	11/18/2019	11/18/2023
516 W 62ND ST	20	07	68	GOVERNMENT ENTITY	info@cookcountylandbank.org	01/08/2020	1/8/2024
433 W 62ND ST	20	07	68	GOVERNMENT ENTITY	info@cookcountylandbank.org	02/26/2020	2/26/2024
543 W 61ST ST	20	07	68	GOVERNMENT ENTITY	info@cookcountylandbank.org	02/26/2020	2/26/2024
1746 W 51ST ST	20	09	61	GOVERNMENT ENTITY	info@cookcountylandbank.org	05/06/2021	11/6/2023
4857 S ADA ST	20	09	61	GOVERNMENT ENTITY	info@cookcountylandbank.org	07/07/2021	1/7/2024
4845 S PRINCETON AVE	20	09	37	GOVERNMENT ENTITY	info@cookcountylandbank.org	07/07/2021	1/7/2024
4404 S WENTWORTH AVE	20	09	37	GOVERNMENT ENTITY	info@cookcountylandbank.org	10/06/2021	10/6/2023
6321 S RHODES AVE	20	03	42	GOVERNMENT ENTITY	info@cookcountylandbank.org	10/06/2021	10/6/2023
5035 S MARSHFIELD AVE	20	09	61	GOVERNMENT ENTITY	info@cookcountylandbank.org	12/27/2021	12/27/2023
4810 S LOOMIS BLVD	20	09	61	GOVERNMENT ENTITY	info@cookcountylandbank.org	02/22/2022	2/22/2024
6545 S LANGLEY AVE	20	03	42	GOVERNMENT ENTITY	info@cookcountylandbank.org	03/03/2022	12/16/2023
5357 S SHIELDS AVE	20	09	37	GOVERNMENT ENTITY	info@cookcountylandbank.org	06/30/2022	12/30/2023

302 W 51ST ST	20	09	37	GOVERNMENT ENTITY	info@cookcountylandbank.org	07/26/2022	1/26/2024
5016 S ABERDEEN ST	20	09	61	GOVERNMENT ENTITY	info@cookcountylandbank.org	08/31/2022	2/28/2024
822 W 51ST PL	20	09	61	GOVERNMENT ENTITY	info@cookcountylandbank.org	08/31/2022	2/28/2024
6606 S RHODES AVE	20	03	42	GOVERNMENT ENTITY	info@cookcountylandbank.org	12/28/2022	12/28/2023
5203 S CARPENTER ST	20	09	61	GOVERNMENT ENTITY	info@cookcountylandbank.org	03/30/2023	9/30/2023
5230 S LOOMIS BLVD	20	09	61	GOVERNMENT ENTITY	info@cookcountylandbank.org	09/06/2023	3/6/2024
417 W 104TH ST	21	22	49	GOVERNMENT ENTITY	info@cookcountylandbank.org	02/09/2018	2/9/2024
8837 S MORGAN ST	21	22	71	GOVERNMENT ENTITY	info@cookcountylandbank.org	01/02/2019	1/2/2024
11653 S SANGAMON ST	21	05	53	GOVERNMENT ENTITY	info@cookcountylandbank.org	10/31/2019	10/30/2023
11346 S HARVARD AVE	21	05	49	GOVERNMENT ENTITY	info@cookcountylandbank.org	10/31/2019	10/30/2023
310 W 109TH ST	21	05	49	GOVERNMENT ENTITY	info@cookcountylandbank.org	10/31/2019	10/30/2023
11345 S CARPENTER ST	21	22	75	GOVERNMENT ENTITY	info@cookcountylandbank.org	10/31/2019	10/30/2023
625 W 119TH ST	21	05	53	GOVERNMENT ENTITY	info@cookcountylandbank.org	11/01/2019	11/1/2023
12019 S NORMAL AVE	21	05	53	GOVERNMENT ENTITY	info@cookcountylandbank.org	01/30/2020	1/30/2024
11753 S LOWE AVE	21	05	53	GOVERNMENT ENTITY	info@cookcountylandbank.org	01/30/2020	1/30/2024
12024 S NORMAL AVE	21	05	53	GOVERNMENT ENTITY	info@cookcountylandbank.org	06/24/2020	12/24/2023
10814 S HALSTED ST	21	22	75	GOVERNMENT ENTITY	info@cookcountylandbank.org	02/02/2021	2/2/2024
10558 S WENTWORTH AVE	21	05	49	GOVERNMENT ENTITY	info@cookcountylandbank.org	05/04/2021	11/4/2023
12115 S UNION AVE	21	05	53	GOVERNMENT ENTITY	info@cookcountylandbank.org	05/04/2021	11/4/2023
12109 S UNION AVE	21	05	53	GOVERNMENT ENTITY	info@cookcountylandbank.org	05/04/2021	11/4/2023
12148 S NORMAL AVE	21	05	53	GOVERNMENT ENTITY	info@cookcountylandbank.org	05/04/2021	11/4/2023
11726 S NORMAL AVE	21	05	53	GOVERNMENT ENTITY	info@cookcountylandbank.org	07/07/2021	1/7/2024
10750 S GLENROY AVE	21	22	75	GOVERNMENT ENTITY	info@cookcountylandbank.org	07/19/2021	1/19/2024
11533 S VINCENNES AVE	21	22	75	GOVERNMENT ENTITY	info@cookcountylandbank.org	12/13/2021	12/13/2023
9838 S THROOP ST	21	22	73	GOVERNMENT ENTITY	info@cookcountylandbank.org	12/13/2021	12/13/2023
1472 W 113TH PL	21	22	75	GOVERNMENT ENTITY	info@cookcountylandbank.org	12/13/2021	12/13/2023
11913 S NORMAL AVE	21	05	53	GOVERNMENT ENTITY	info@cookcountylandbank.org	12/13/2021	12/13/2023
1428 W 110TH PL	21	22	75	GOVERNMENT ENTITY	info@cookcountylandbank.org	12/13/2021	12/13/2023
1320 W 110TH PL	21	22	75	GOVERNMENT ENTITY	info@cookcountylandbank.org	12/13/2021	12/13/2023
10231 S UNION AVE	21	22	73	GOVERNMENT ENTITY	info@cookcountylandbank.org	02/07/2022	2/7/2024
11156 S ASHLAND AVE	21	22	75	GOVERNMENT ENTITY	info@cookcountylandbank.org	02/08/2022	2/8/2024
11336 S ABERDEEN ST	21	22	75	GOVERNMENT ENTITY	info@cookcountylandbank.org	02/08/2022	2/8/2024
12014 S EGGLESTON AVE	21	05	53	GOVERNMENT ENTITY	info@cookcountylandbank.org	04/29/2022	10/29/2023
311 W 108TH PL	21	05	49	GOVERNMENT ENTITY	info@cookcountylandbank.org	04/29/2022	10/29/2023
11518 S WALLACE ST	21	05	53	GOVERNMENT ENTITY	info@cookcountylandbank.org	04/29/2022	10/29/2023
321 W 110TH ST	21	05	49	GOVERNMENT ENTITY	info@cookcountylandbank.org	04/29/2022	10/29/2023
1030 W 111TH ST	21	22	75	GOVERNMENT ENTITY	info@cookcountylandbank.org	06/30/2022	11/27/2023
1100 W 111TH PL	21	22	75	GOVERNMENT ENTITY	info@cookcountylandbank.org	08/31/2022	2/28/2024
1104 W 111TH PL	21	22	75	GOVERNMENT ENTITY	info@cookcountylandbank.org	08/31/2022	2/28/2024
8735 S NORMAL AVE	21	22	71	GOVERNMENT ENTITY	info@cookcountylandbank.org	12/28/2022	12/28/2023

1341 W 107TH ST	21	22	75	GOVERNMENT ENTITY	info@cookcountylandbank.org	03/20/2023	3/20/2024
1148 W 90TH ST	21	22	73	GOVERNMENT ENTITY	info@cookcountylandbank.org	05/31/2023	11/30/2023
10752 S WENTWORTH AVE	21	05	49	GOVERNMENT ENTITY	info@cookcountylandbank.org	08/28/2023	2/28/2024
9020 S PARNELL AVE	21	22	71	GOVERNMENT ENTITY	info@cookcountylandbank.org	08/31/2023	2/29/2024
9005 S WALLACE ST	21	22	71	GOVERNMENT ENTITY	info@cookcountylandbank.org	09/11/2023	3/11/2024
4384 W OGDEN AVE	22	10	29	GOVERNMENT ENTITY	info@cookcountylandbank.org	07/07/2021	1/7/2024
2400 S DRAKE AVE	22	10	30	GOVERNMENT ENTITY	info@cookcountylandbank.org	10/06/2021	10/6/2023
3543 W CERMAK RD	22	10	30	GOVERNMENT ENTITY	info@cookcountylandbank.org	05/23/2022	11/23/2023
2247 S SPRINGFIELD AVE	22	10	30	GOVERNMENT ENTITY	info@cookcountylandbank.org	09/20/2023	3/20/2024
5828 S ARCHER AVE	23	08	56	GOVERNMENT ENTITY	info@cookcountylandbank.org	02/22/2022	2/22/2024
1233 S KOMENSKY AVE	24	10	29	GOVERNMENT ENTITY	info@cookcountylandbank.org	07/07/2021	1/7/2024
1238 S SPRINGFIELD AVE	24	10	29	GOVERNMENT ENTITY	info@cookcountylandbank.org	10/06/2021	10/6/2023
1533 S KILDARE AVE	24	10	29	GOVERNMENT ENTITY	info@cookcountylandbank.org	10/06/2021	10/6/2023
2130 S CHRISTIANA AVE	24	10	30	GOVERNMENT ENTITY	info@cookcountylandbank.org	10/06/2021	10/6/2023
1331 S KARLOV AVE	24	10	29	GOVERNMENT ENTITY	info@cookcountylandbank.org	01/04/2022	1/4/2024
1639 S AVERS AVE	24	10	29	GOVERNMENT ENTITY	info@cookcountylandbank.org	01/04/2022	1/4/2024
1219 S AVERS AVE	24	10	29	GOVERNMENT ENTITY	info@cookcountylandbank.org	01/04/2022	1/4/2024
1101 S PULASKI RD	24	11	29	GOVERNMENT ENTITY	info@cookcountylandbank.org	05/02/2022	10/22/2023
4109 W 16TH ST	24	10	29	GOVERNMENT ENTITY	info@cookcountylandbank.org	05/23/2022	11/23/2023
1426 S SPAULDING AVE	24	10	29	GOVERNMENT ENTITY	info@cookcountylandbank.org	05/31/2022	11/30/2023
1819 S KEDZIE AVE	24	10	29	GOVERNMENT ENTITY	info@cookcountylandbank.org	12/28/2022	12/28/2023
1620 S KEDVALE AVE	24	10	29	GOVERNMENT ENTITY	info@cookcountylandbank.org	12/28/2022	12/28/2023
1330 S KOMENSKY AVE	24	10	29	GOVERNMENT ENTITY	info@cookcountylandbank.org	12/28/2022	12/28/2023
1446 S KOSTNER AVE	24	10	29	GOVERNMENT ENTITY	info@cookcountylandbank.org	12/28/2022	12/28/2023
3918 W GRENSHAW ST	24	11	29	GOVERNMENT ENTITY	info@cookcountylandbank.org	12/28/2022	12/28/2023
1529 S TRIPP AVE	24	10	29	GOVERNMENT ENTITY	info@cookcountylandbank.org	12/29/2022	12/29/2023
3819 W ARTHINGTON ST	24	11	26	GOVERNMENT ENTITY	info@cookcountylandbank.org	02/27/2023	2/27/2024
3214 W POLK ST	24	11	27	GOVERNMENT ENTITY	info@cookcountylandbank.org	03/30/2023	2/23/2024
4044 W FIFTH AVE	24	11	26	GOVERNMENT ENTITY	info@cookcountylandbank.org	09/01/2023	3/1/2024
3849 W FLOURNOY ST	24	11	26	GOVERNMENT ENTITY	info@cookcountylandbank.org	09/01/2023	3/1/2024
1446 N ST LOUIS AVE	26	14	23	GOVERNMENT ENTITY	info@cookcountylandbank.org	01/04/2022	10/20/2023
3028 W WASHINGTON BLVD	27	12	27	GOVERNMENT ENTITY	info@cookcountylandbank.org	01/04/2022	1/4/2024
728 N TRUMBULL AVE	27	11	23	GOVERNMENT ENTITY	info@cookcountylandbank.org	03/03/2022	12/21/2023
4747 W MADISON ST	28	11	25	GOVERNMENT ENTITY	info@cookcountylandbank.org	05/06/2021	11/6/2023
4400 W MADISON ST	28	11	26	GOVERNMENT ENTITY	info@cookcountylandbank.org	05/06/2021	11/6/2023
3459 W WALNUT ST	28	11	27	GOVERNMENT ENTITY	info@cookcountylandbank.org	01/04/2022	1/4/2024
4138 W MADISON ST	28	11	26	GOVERNMENT ENTITY	info@cookcountylandbank.org	02/03/2022	2/3/2024
221 N LAPORTE AVE	28	15	25	GOVERNMENT ENTITY	info@cookcountylandbank.org	03/10/2022	1/13/2024
4918 W MADISON ST	28	15	25	GOVERNMENT ENTITY	info@cookcountylandbank.org	05/23/2022	11/23/2023
4515 W WASHINGTON BLVD	28	11	26	GOVERNMENT ENTITY	info@cookcountylandbank.org	10/04/2022	10/4/2023

4142 W GLADYS AVE	28	11	26	GOVERNMENT ENTITY	info@cookcountylandbank.org	09/11/2023	3/11/2024
4247 W WEST END AVE	28	11	26	GOVERNMENT ENTITY	info@cookcountylandbank.org	09/11/2023	3/11/2024
320 N LAMON AVE	28	15	25	GOVERNMENT ENTITY	info@cookcountylandbank.org	09/20/2023	3/20/2024
216 N LEAMINGTON AVE	28	15	25	GOVERNMENT ENTITY	info@cookcountylandbank.org	09/20/2023	3/20/2024
1701 N MELVINA AVE	29	25	25	GOVERNMENT ENTITY	info@cookcountylandbank.org	10/06/2021	10/6/2023
1110 N MENARD AVE	29	15	25	GOVERNMENT ENTITY	info@cookcountylandbank.org	01/04/2022	1/4/2024
5826 W ERIE ST	29	15	25	GOVERNMENT ENTITY	info@cookcountylandbank.org	01/04/2022	1/4/2024
4821 W JACKSON BLVD	29	15	25	GOVERNMENT ENTITY	info@cookcountylandbank.org	01/24/2023	1/24/2024
1436 N WALLER AVE	29	25	25	GOVERNMENT ENTITY	info@cookcountylandbank.org	03/30/2023	9/30/2023
2555 N CICERO AVE	31	25	19	GOVERNMENT ENTITY	info@cookcountylandbank.org	07/05/2022	10/21/2023
2549 N CICERO AVE	31	25	19	GOVERNMENT ENTITY	info@cookcountylandbank.org	07/05/2022	10/21/2023
853 N LARAMIE AVE	37	15	25	GOVERNMENT ENTITY	info@cookcountylandbank.org	08/05/2019	2/5/2024
5414 W WALTON ST	37	15	25	GOVERNMENT ENTITY	info@cookcountylandbank.org	07/07/2021	1/7/2024
5418 W CORTEZ ST	37	15	25	GOVERNMENT ENTITY	info@cookcountylandbank.org	07/07/2021	1/7/2024
848 N LARAMIE AVE	37	15	25	GOVERNMENT ENTITY	info@cookcountylandbank.org	07/07/2021	1/7/2024
629 N LOCKWOOD AVE	37	15	25	GOVERNMENT ENTITY	info@cookcountylandbank.org	07/07/2021	1/7/2024
447 N HARDING AVE	37	11	23	GOVERNMENT ENTITY	info@cookcountylandbank.org	07/07/2021	1/7/2024
5005 W CHICAGO AVE	37	15	25	GOVERNMENT ENTITY	info@cookcountylandbank.org	10/06/2021	10/6/2023
449 N HARDING AVE	37	11	23	GOVERNMENT ENTITY	info@cookcountylandbank.org	02/28/2022	1/30/2024
1022 N LAWLER AVE	37	15	25	GOVERNMENT ENTITY	info@cookcountylandbank.org	03/10/2022	2/3/2024
37 N LOCKWOOD AVE	37	15	25	GOVERNMENT ENTITY	info@cookcountylandbank.org	10/04/2022	10/4/2023
4502 W THOMAS ST	37	11	23	GOVERNMENT ENTITY	info@cookcountylandbank.org	10/04/2022	10/4/2023
130 N LARAMIE AVE	37	15	25	GOVERNMENT ENTITY	info@cookcountylandbank.org	09/20/2023	3/20/2024
6226 W ADDISON ST	38	16	17	GOVERNMENT ENTITY	info@cookcountylandbank.org	03/30/2023	9/30/2023
6224 W ADDISON ST	38	16	17	GOVERNMENT ENTITY	info@cookcountylandbank.org	03/30/2023	9/30/2023



CITY OF CHICAGO



DEPARTMENT OF BUILDINGS

MEMORANDUM

To: The Honorable Jason Ervin
Chairman, Committee on the Budget and Government Operations

From: Matthew Beaudet
Commissioner
Department

CC: Elizabeth Beatty
Mayor's Office of Intergovernmental Affairs

Date: **November 8, 2023**

Re: Request for Information from Annual Appropriation Committee Hearing

ID#: 67-07

The following information is provided in response to questions posed at our department's hearing on October 25, 2023, to discuss the proposed 2024 budget.

Alderman Lopez asked for a list of open electrical violations by ward. Please see the attached.

As always, please let me know if you have any further questions.

Violation Date / Time	Violation Code	Violation Description	Violation Text	Comments	Location	Street Number	Pre-Street Direction	Street Name	Street Suffix	Ward	Code Violations. Status. Status Code
02/01/2023	EL1817	CONTINUITY OF RACEWAYS	raceway, and enclosure. (14E-3-300.10, 14E-3-300.13)	Loose locknuts throughout the first floor	Throughout the first floor	8921	S	THROOP	ST	21	Open
02/01/2023	EL1833	SECURE RACEWAY	Strap and secure raceway and armored cable. (14E-1-110.13(a))	Pipes not supported throughout the first floor	SEQ #: 002□ First floor	8921	S	THROOP	ST	21	Open
07/18/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)		SEQ #: 011□	2234	W	TAYLOR	ST	28	Open
07/18/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)		SEQ #: 010□	2234	W	TAYLOR	ST	28	Open
07/18/2023	EL1833	SECURE RACEWAY	Strap and secure raceway and armored cable. (14E-1-110.13(a))		SEQ #: 003□	2234	W	TAYLOR	ST	28	Open
07/18/2023	EL1834	LISTED FOR USE TEMP & LOCATION	temperature and location.(14E-1-110.2(B), 14E-1-110.11)		SEQ #: 014□	2234	W	TAYLOR	ST	28	Open
07/18/2023	EL1834	LISTED FOR USE TEMP & LOCATION	temperature and location.(14E-1-110.2(B), 14E-1-110.11)		SEQ #: 016□	2234	W	TAYLOR	ST	28	Open
07/19/2023	EL1804	DEFECTIVE FEEDER	Replace defective feeder. (14E-2-215)	HAND REACH NEEDS TO BE RAISED OR BLOCKED OFF	SEQ #: 024□	44	W	112TH	PL	09	Open
07/19/2023	EL1804	DEFECTIVE FEEDER	Replace defective feeder. (14E-2-215)	EXTREMELY DANGEROUS RISER EXPOSED TO TOUCH	SEQ #: 011□	44	W	112TH	PL	09	Open
07/19/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	REPAIR CONDUIT FOR GROUNDING EXTERIOR ROD	SEQ #: 004□	44	W	112TH	PL	09	Open
07/19/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	REPAIR CONDUIT FOR PROPER SIZE GROUND EXTERIOR ROD	SEQ #: 017□	44	W	112TH	PL	09	Open
07/19/2023	EL1827	RESTORE EXIT AND EM	and related equipment to working condition. (14E-7-700.6)	SYSTEM AND RELATED EQUIPMENT TO WORKING CONDITION	SEQ #: 005□	44	W	112TH	PL	09	Open
07/19/2023	EL1827	RESTORE EXIT AND EM	and related equipment to working condition. (14E-7-700.6)	RELATED EQUIPMENT TO WORKING CONDITION	SEQ #: 018□	44	W	112TH	PL	09	Open
07/19/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	OPEN BOXES AND EXPOSED WIRE THROUGHOUT BASEMENT AND UPSTAIRS	SEQ #: 022□	44	W	112TH	PL	09	Open
07/19/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	OPEN BOX EXPOSED WIRE THROUGHOUT BASEMENT AND UPSTAIRS	SEQ #: 009□	44	W	112TH	PL	09	Open
02/06/2023	EL1827	RESTORE EXIT AND EM	Restore exit and emergency lighting system and related equipment to working condition. (14E-7-700.6)	EMERGENCY LIGHTSAND EXIT SIGNS AS THERE ARE BURNT OUT LIGHT BULBS IN EXIT SIGNS	SEQ #: 003□	6509	S	COTTAGE GROVE	AVE	20	Open
02/06/2023	EL1827	RESTORE EXIT AND EM	Restore exit and emergency lighting system and related equipment to working condition. (14E-7-700.6)	EMERGENCY LIGHTSAND EXIT SIGNS AS THERE ARE BURNT OUT LIGHT BULBS IN EXIT SIGNS	SEQ #: 004□	6509	S	COTTAGE GROVE	AVE	20	Open
02/21/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	DANGEROUS AND HAZARDOUS CONDITION	SEQ #: 060□	6404	N	RICHMOND	ST	50	Open
02/21/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	DANGEROUS AND HAZARDOUS CONDITION	SEQ #: 060□	6404	N	RICHMOND	ST	50	Open
02/21/2023	EL1817	CONTINUITY OF RACEWAYS	Provide ground continuity for electrical cable, raceway, and enclosure. (14E-3-300.10, 14E-3-300.13)	DANGEROUS AND HAZARDOUS CONDITION	SEQ #: 011□	6404	N	RICHMOND	ST	50	Open
04/19/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	DANGEROUS AND HAZARDOUS CONDITION	SEQ #: 012□	6404	N	RICHMOND	ST	50	Open
04/19/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	DANGEROUS AND HAZARDOUS CONDITION	SEQ #: 013□	6404	N	RICHMOND	ST	50	Open
04/19/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	DANGEROUS AND HAZARDOUS CONDITION	SEQ #: 054□	6404	N	RICHMOND	ST	50	Open
04/19/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	DANGEROUS AND HAZARDOUS CONDITION	2936,2942,6404 BASEMENT AREAS DANGEROUS AND HAZARDOUS	6404	N	RICHMOND	ST	50	Open

04/19/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)		2938 1ST FLOOR STORE PANEL DANGEROUS AND HAZARDOUS	6404	N	RICHMOND	ST	50	Open
04/19/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)		2936 1ST FLOOR STORE PANEL DANGEROUS AND HAZARDOUS	6404	N	RICHMOND	ST	50	Open
04/19/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)		SEQ #: 032□	6404	N	RICHMOND	ST	50	Open
04/19/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)		DANGEROUS AND HAZARDOUS CONDITION	6404	N	RICHMOND	ST	50	Open
04/19/2023	EL1805	DEFECTIVE DISTRIBUTION	4-408.30, 14E-4-408.36, 14E-4-408.37, 14E-4-408.38, 14E-4-408.39, 14E-4-408.40, 14E-4-408.41))	DANGEROUS AND HAZARDOUS CONDITION	SEQ #: 015□	6404	N	RICHMOND	ST	50	Open
04/19/2023	EL1805	DEFECTIVE DISTRIBUTION	4-408.30, 14E-4-408.36, 14E-4-408.37, 14E-4-408.38, 14E-4-408.39, 14E-4-408.40, 14E-4-408.41))	DANGEROUS AND HAZARDOUS CONDITION	SEQ #: 034□	6404	N	RICHMOND	ST	50	Open
04/19/2023	EL1805	DEFECTIVE DISTRIBUTION	4-408.30, 14E-4-408.36, 14E-4-408.37, 14E-4-408.38, 14E-4-408.39, 14E-4-408.40, 14E-4-408.41))	DANGEROUS AND HAZARDOUS CONDITITION	SEQ #: 034□	6404	N	RICHMOND	ST	50	Open
04/19/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	DANGEROUS AND HAZARDOUS CONDITION	SEQ #: 014□	6404	N	RICHMOND	ST	50	Open
04/19/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	DANGEROUS AND HAZARDOUS CONDITION	SEQ #: 033□	6404	N	RICHMOND	ST	50	Open
04/19/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	DANGEROUS AND HAZARDOUS CONDITYION	SEQ #: 055□	6404	N	RICHMOND	ST	50	Open
04/19/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	DANGEROUS HAZARDOUS CONDITION	SEQ #: 033□	6404	N	RICHMOND	ST	50	Open
04/19/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)		SEQ #: 014□	6404	N	RICHMOND	ST	50	Open
04/19/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)		DANGEROUS AND HAZARDOUS CONDITION	6404	N	RICHMOND	ST	50	Open
04/19/2023	EL1817	CONTINUITY OF RACEWAYS	raceway, and enclosure. (14E-3-300.10, 14E-3-300.13)	DANGEROUS AND HAZARDOUS CONDITION	SEQ #: 039□	6404	N	RICHMOND	ST	50	Open
04/19/2023	EL1827	RESTORE EXIT AND EM	and related equipment to working condition. (14E-7-700.6)	DANGEROUS AND HAZARDOUS CONDITION	SEQ #: 023□	6404	N	RICHMOND	ST	50	Open
04/19/2023	EL1827	RESTORE EXIT AND EM	and related equipment to working condition. (14E-7-700.6)	DANGEROUS AND HAZARDOUS CONDITION	SEQ #: 040□	6404	N	RICHMOND	ST	50	Open
04/19/2023	EL1827	RESTORE EXIT AND EM	and related equipment to working condition. (14E-7-700.6)	DANGEROUS AND HAZARDOUS CONDITION	SEQ #: 056□	6404	N	RICHMOND	ST	50	Open
04/19/2023	EL1827	RESTORE EXIT AND EM	and related equipment to working condition. (14E-7-700.6)		SEQ #: 023□	6404	N	RICHMOND	ST	50	Open
04/19/2023	EL1827	RESTORE EXIT AND EM	Restore exit and emergency lighting system and related equipment to working condition. (14E-7-700.6)		DANGEROUS AND HAZARDOUS CONDITION	6404	N	RICHMOND	ST	50	Open
04/19/2023	EL1827	RESTORE EXIT AND EM	Restore exit and emergency lighting system and related equipment to working condition. (14E-7-700.6)		DANGEROUS AND HAZARDOUS CONDITION	6404	N	RICHMOND	ST	50	Open
04/19/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	DANGEROUS AND HAZARDOUS	SEQ #: 038□	6404	N	RICHMOND	ST	50	Open
04/19/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	DANGEROUS AND HAZARDOUS CONDITION	SEQ #: 038□	6404	N	RICHMOND	ST	50	Open
04/19/2023	EL1833	SECURE RACEWAY	Strap and secure raceway and armored cable. (14E-1-110.13(a))		SEQ #: 019□	6404	N	RICHMOND	ST	50	Open

04/19/2023	EL1833	SECURE RACEWAY	Strap and secure raceway and armored cable. (14E-1-110.13(a))		SEQ #: 047□	6404	N	RICHMOND	ST	50	Open
04/19/2023	EL1839	CORRODED CONDUIT & EQUIP	Replace rusted, deteriorated, or corroded conduit, cabinet, electrical box, or fitting. (14E-3-300.13, 14E-1-110.12(b))		SEQ #: 022□	6404	N	RICHMOND	ST	50	Open
07/11/2023	EL1822	EXPOSED WIRING FIXTURES	Remove exposed wiring at light fixture. (14E-4-410.48)		SEQ #: 008□	4525	S	SPAULDING	AVE	12	Open
07/11/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	D&H EXPOSED WIRING REMOVE IN HALLWAY ALL LOW VOLTAGE DOOR BELL GOING THROUGH STAIRWELL TO 2ND FLR APT TO TRANSFORMER IN APT.	SEQ #: 010□	4525	S	SPAULDING	AVE	12	Open
01/04/2023	EL1817	CONTINUITY OF RACEWAYS	Provide ground continuity for electrical cable, raceway, and enclosure. (14E-3-300.10, 14E-3-300.13)	S/W 1ST AND BASEMENT-NO VISIBLE EQUIPMENT GROUNDS AT BASEMENT REFRIGERATION EQUIPMENT RACEWAYS ENSURE EQUIPMENT GROUND THROUGHOUT DANGEROUS AND HAZARDOUS	SEQ #: 003□	232	E	35TH	ST	04	Open
01/04/2023	EL1817	CONTINUITY OF RACEWAYS	Provide ground continuity for electrical cable, raceway, and enclosure. (14E-3-300.10, 14E-3-300.13)	S/W 1ST AND BASEMENT-NO VISIBLE EQUIPMENT GROUNDS AT BASEMENT REFRIGERATION EQUIPMENT RACEWAYS ENSURE EQUIPMENT GROUND THROUGHOUT DANGEROUS AND HAZARDOUS	SEQ #: 023□	232	E	35TH	ST	04	Open
01/04/2023	EL1827	RESTORE EXIT AND EM	Restore exit and emergency lighting system and related equipment to working condition. (14E-7-700.6)	BROKEN, UNMAINTAINED INSUFFICIENT EXIT SIGNS AND BATTERY LIGHTS DANGEROUS AND HAZARDOUS	SEQ #: 018□	232	E	35TH	ST	04	Open
01/04/2023	EL1827	RESTORE EXIT AND EM	Restore exit and emergency lighting system and related equipment to working condition. (14E-7-700.6)	BROKEN, UNMAINTAINED INSUFFICIENT EXIT SIGNS AND BATTERY LIGHTS DANGEROUS AND HAZARDOUS	SEQ #: 025□	232	E	35TH	ST	04	Open
01/04/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	S/W 1ST AND BASEMENT-OPEN WIRING BASEMENT REFRIGERATION EQUIPMENT DANGEROUS AND HAZARDOUS	SEQ #: 012□	232	E	35TH	ST	04	Open
01/04/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	S/W 1ST AND BASEMENT-OPEN WIRING BASEMENT REFRIGERATION EQUIPMENT DANGEROUS AND HAZARDOUS	SEQ #: 019□	232	E	35TH	ST	04	Open
01/06/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	POINT OF ENTRY ENSURE SERVICE IN APPROVED CONDITION	SEQ #: 005□	5812	S	STATE	ST	20	Open
01/06/2023	EL1805	DEFECTIVE DISTRIBUTION	Replace defective distribution equipment. (14E-4-408.30, 14E-4-408.36, 14E-4-408.37, 14E-4-408.38, 14E-4-408.39, 14E-4-408.40, 14E-4-408.41))	LOOSE PANEL COVERS AT MAIN SERVICE DISCONNECT AREA ENSURE DISTRIBUTION IN APPROVED CONDITION THROUGHOUT DANGEROUS AND HAZARDOUS	SEQ #: 006□	5812	S	STATE	ST	20	Open
01/06/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	NO VISIBLE WATER GROUND ENSURE SERVICE GROUNDED IN APPROVED NO VISIBLE WATER GROUND ENSURE SERVICE GROUNDED IN APPROVED MANNER	SEQ #: 008□	5812	S	STATE	ST	20	Open
01/06/2023	EL1817	CONTINUITY OF RACEWAYS	Provide ground continuity for electrical cable, raceway, and enclosure. (14E-3-300.10, 14E-3-300.13)	CONDUITS NOT CONNECTED TO BOXES OR FITTINGS VARIOUS AREAS REAR AREA ENSURE GROUND CONTINUITY THROUGHOUT DANGEROUS AND HAZARDOUS	SEQ #: 016□	5812	S	STATE	ST	20	Open
01/06/2023	EL1822	EXPOSED WIRING FIXTURES	Remove exposed wiring at light fixture. (14E-4-410.48)	LIGHT FIXTURES AT WASH AREA AND VARIOUS AREAS THROUGHOUT DANGEROUS AND HAZARDOUS	SEQ #: 017□	5812	S	STATE	ST	20	Open
01/06/2023	EL1827	RESTORE EXIT AND EM	Restore exit and emergency lighting system and related equipment to working condition. (14E-7-700.6)	INSUFFICIENT BATTERY LIGHTS AND EXIT SIGNS THROUGHOUT DANGEROUS AND DANGEROUS	SEQ #: 020□	5812	S	STATE	ST	20	Open
01/06/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	OPEN WIRING VARIOUS AREAS THROUGHOUT REMOVE WHERE REQUIRED DANGEROUS AND HAZARDOUS	SEQ #: 011□	5812	S	STATE	ST	20	Open

01/19/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	GARAGE ELECTRICAL SERVICE HAS DAMAGED METER ENCLOSURE DOESN'T APPEAR SEALED DANGEROUS AND HAZARDOUS	SEQ #: 044☐	7432	S	RACINE	AVE	17	Open
01/19/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	CABLES INTERMINGLED WITH OVERHEAD SERVICE CABLES AT EXTERIOR DRIP LOOP UNSUPPORTED CONDUIT LAYING ON OVERHEAD NEUTRAL CONNECTION SERVICE ENTRANCE CONDUCTORS APPEAR TO BE OVER 5' FROM POINT OF ENTRY ENSURE SERVICE IN APPROVED CONDITION DANGEROUS AND HAZARDOUS	SEQ #: 022☐	7432	S	RACINE	AVE	17	Open
01/19/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	ELECTRICAL SERVICE ENSURE SERVICES GROUNDED IN APPROVED MANNER DANGEROUS AND HAZARDOUS	SEQ #: 025☐	7432	S	RACINE	AVE	17	Open
01/19/2023	EL1822	EXPOSED WIRING FIXTURES	Remove exposed wiring at light fixture. (14E-4-410.48)	LIGHT FIXTURE HANGING BY WIRES WATER HEATER ROOM OPEN SPLICE BOX REAR CEILING TRACK LIGHT REMOVE WHERE REQUIRED DANGEROUS AND HAZARDOUS	SEQ #: 034☐	7432	S	RACINE	AVE	17	Open
01/19/2023	EL1827	RESTORE EXIT AND EM	Restore exit and emergency lighting system and related equipment to working condition. (14E-7-700.6)	UNABLE TO VERIFY EXISTING BATTERY LIGHTS AND EXIT SIGNS OPERATING IN APPROVED MANNER DANGEROUS AND HAZARDOUS	SEQ #: 036☐	7432	S	RACINE	AVE	17	Open
01/19/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	ELECTRICAL SERVICE PANEL AND GARAGE EXTERIOR REMOVE WHERE REQUIRED DANGEROUS AND HAZARDOUS	SEQ #: 027☐	7432	S	RACINE	AVE	17	Open
01/19/2023	EL1833	SECURE RACEWAY	Strap and secure raceway and armored cable. (14E-1-110.13(a))	UNSUPPORTED RACEWAYS VARIOUS AREAS EXTERIOR SECURE IN APPROVED MANNER WHERE REQUIRED	SEQ #: 037☐	7432	S	RACINE	AVE	17	Open
01/23/2023	EL1834	LISTED FOR USE TEMP & LOCATION	Electrical equipment shall be listed for use, temperature and location.(14E-1-110.2(B), 14E-1-110.11)	WHICH ARE LISTED FOR USE BY PANEL MANUFACTURER INSTALL PROPER JUNCTION BOXES WHICH ARE LISTED FOR USE IN DAMP/WET LOCATIONS INSIDE WALK-IN COOLER IN THE BASEMENT DANGEROUS AND HAZARDOUS	SEQ #: 001☐	3636	W	111TH	ST	19	Open
01/23/2023	EL1834	LISTED FOR USE TEMP & LOCATION	Electrical equipment shall be listed for use, temperature and location.(14E-1-110.2(B), 14E-1-110.11)	WHICH ARE LISTED FOR USE BY PANEL MANUFACTURER INSTALL PROPER JUNCTION BOXES WHICH ARE LISTED FOR USE IN DAMP/WET LOCATIONS INSIDE WALK-IN COOLER IN THE BASEMENT DANGEROUS AND HAZARDOUS	SEQ #: 032☐	3636	W	111TH	ST	19	Open
01/26/2023	EL1803	DEFECTIVE METER EQUIPMENT	Replace defective meter socket. (14E-2-230.62,14E-2-230.66,14E-3-312.5)	There are 2 missing electrical meters with live wiring exposed. dangerous and Hazardous.	SEQ #: 004☐ OTHER : :OTHER	11925	S	NORMAL	AVE	21	Open
08/21/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	PROPERLY GROUND AND BOND SERVICE.	SEQ #: 032☐	2744	W	18TH	ST	24	Open
08/21/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	PROPERLY GROUND AND BOND SERVICE.	SEQ #: 045☐	2744	W	18TH	ST	24	Open
08/21/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	PROPERLY GROUND AND BOND SERVICE.	SEQ #: 047☐	2744	W	18TH	ST	24	Open
08/21/2023	EL1817	CONTINUITY OF RACEWAYS	raceway, and enclosure. (14E-3-300.10, 14E-3-300.13)	CONNECT PIPES TOGETHER PROPERLY IN BASEMENT.	SEQ #: 014☐	2744	W	18TH	ST	24	Open
08/21/2023	EL1817	CONTINUITY OF RACEWAYS	raceway, and enclosure. (14E-3-300.10, 14E-3-300.13)	CONNECT PIPES TOGETHER PROPERLY IN BASEMENT.	SEQ #: 016☐	2744	W	18TH	ST	24	Open
08/21/2023	EL1817	CONTINUITY OF RACEWAYS	raceway, and enclosure. (14E-3-300.10, 14E-3-300.13)	CONNECT PIPES TOGETHER PROPERLY IN BASEMENT.	SEQ #: 036☐	2744	W	18TH	ST	24	Open
08/21/2023	EL1822	EXPOSED WIRING FIXTURES	Remove exposed wiring at light fixture. (14E-4-410.48)	PROPERLY MOUNT FIXTURES TO COVER EXPOSED WIRING.	SEQ #: 026☐	2744	W	18TH	ST	24	Open
08/21/2023	EL1822	EXPOSED WIRING FIXTURES	Remove exposed wiring at light fixture. (14E-4-410.48)	PROPERLY MOUNT FIXTURES TO COVER EXPOSED WIRING.	SEQ #: 039☐	2744	W	18TH	ST	24	Open

08/21/2023	EL1822	EXPOSED WIRING FIXTURES	Remove exposed wiring at light fixture. (14E-4-410.48)	PROPERLY MOUNT FIXTURES TO COVER EXPOSED WIRING.	SEQ #: 041□	2744	W	18TH	ST	24	Open
08/21/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	INSTALL LIGHT FIXTURE IN LAUNDRY WHERE THERE IS EXPOSED WIRES.	SEQ #: 016□	2744	W	18TH	ST	24	Open
08/21/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	INSTALL LIGHT FIXTURE IN LAUNDRY WHERE THERE IS EXPOSED WIRES.	SEQ #: 030□	2744	W	18TH	ST	24	Open
08/21/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	INSTALL LIGHT FIXTURE IN LAUNDRY WHERE THERE IS EXPOSED WIRES.	SEQ #: 032□	2744	W	18TH	ST	24	Open
08/21/2023	EL1833	SECURE RACEWAY	Strap and secure raceway and armored cable. (14E-1-110.13(a))	SUPPORT ALL RACEWAYS AND BOXES IN BASEMENT.	SEQ #: 030□	2744	W	18TH	ST	24	Open
08/21/2023	EL1833	SECURE RACEWAY	Strap and secure raceway and armored cable. (14E-1-110.13(a))	SUPPORT ALL RACEWAYS AND BOXES IN BASEMENT.	SEQ #: 043□	2744	W	18TH	ST	24	Open
08/21/2023	EL1833	SECURE RACEWAY	Strap and secure raceway and armored cable. (14E-1-110.13(a))	SUPPORT ALL RACEWAYS AND BOXES IN BASEMENT.	SEQ #: 045□	2744	W	18TH	ST	24	Open
08/21/2023	EL1834	LISTED FOR USE TEMP & LOCATION	temperature and location.(14E-1-110.2(B), 14E-1-110.11)	INSTALL GFCI OUTLETS IN PROPER LOCATIONS.	SEQ #: 018□	2744	W	18TH	ST	24	Open
08/21/2023	EL1834	LISTED FOR USE TEMP & LOCATION	temperature and location.(14E-1-110.2(B), 14E-1-110.11)	USE PROPER CONNECTORS AND COUPLINGS FOR EXTERIOR RACEWAY.	SEQ #: 016□	2744	W	18TH	ST	24	Open
08/21/2023	EL1834	LISTED FOR USE TEMP & LOCATION	temperature and location.(14E-1-110.2(B), 14E-1-110.11)	USE PROPER CONNECTORS AND COUPLINGS FOR EXTERIOR RACEWAY.	SEQ #: 018□	2744	W	18TH	ST	24	Open
08/21/2023	EL1834	LISTED FOR USE TEMP & LOCATION	temperature and location.(14E-1-110.2(B), 14E-1-110.11)	USE PROPER CONNECTORS AND COUPLINGS FOR EXTERIOR RACEWAY.	SEQ #: 038□	2744	W	18TH	ST	24	Open
08/28/2023	EL1834	LISTED FOR USE TEMP & LOCATION	temperature and location.(14E-1-110.2(B), 14E-1-110.11)	INSTALL GFCI OUTLETS IN PROPER LOCATIONS.	SEQ #: 048□	2744	W	18TH	ST	24	Open
08/28/2023	EL1834	LISTED FOR USE TEMP & LOCATION	temperature and location.(14E-1-110.2(B), 14E-1-110.11)	INSTALL GFCI OUTLETS IN PROPER LOCATIONS.	SEQ #: 050□	2744	W	18TH	ST	24	Open
01/17/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	OVER LOW VOLTAGE CABLES ABOVE REAR YARD OVERHEAD SERVICE CABLES VISIBLY DETERIORATED AT ATTACHMENT POINT ON BUILDING MAIN DISCONNECT SHOWING DETERIORATION AND DOOR NOT COMPLETELY CLOSED OVERHEAD SERVICE DOES NOT APPEAR SECURELY ATTACHED TO BUILDING ENSURE SERVICE IN APPROVED CONDITION DANGEROUS AND HAZARDOUS	SEQ #: 023□	6200	S	INDIANA	AVE	20	Open
01/17/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	NO VISIBLE WATER GROUND ENSURE SERVICE GROUNDED IN APPROVED MANNER DANGEROUS AND HAZARDOUS	SEQ #: 024□	6200	S	INDIANA	AVE	20	Open
01/17/2023	EL1822	EXPOSED WIRING FIXTURES	Remove exposed wiring at light fixture. (14E-4-410.48)	LIGHT FIXTURES HANGING BY WIRES FRONT ENTRY DAMAGED PENDANT FIXTURE WIRING VARIOUS AREAS REPLACE/REPAIR DANGEROUS AND HAZARDOUS	SEQ #: 029□	6200	S	INDIANA	AVE	20	Open
01/17/2023	EL1822	EXPOSED WIRING FIXTURES	Remove exposed wiring at light fixture. (14E-4-410.48)	LIGHT FIXTURES HANGING BY WIRES FRONT ENTRY DAMAGED PENDANT FIXTURE WIRING VARIOUS AREAS REPLACE/REPAIR DANGEROUS AND HAZARDOUS	SEQ #: 031□	6200	S	INDIANA	AVE	20	Open
01/17/2023	EL1825	SYSTEM III	Install system III emergency lighting. (14E-7-700.6, 14E-7-700.22)	NO BATTERY LIGHTS BUILDING CONTAINS 5 APARTMENTS DANGEROUS AND HAZARDOUS	SEQ #: 031□	6200	S	INDIANA	AVE	20	Open
01/17/2023	EL1825	SYSTEM III	Install system III emergency lighting. (14E-7-700.6, 14E-7-700.22)	NO BATTERY LIGHTS BUILDING CONTAINS 5 APARTMENTS DANGEROUS AND HAZARDOUS	SEQ #: 033□	6200	S	INDIANA	AVE	20	Open
01/17/2023	EL1880	DETERIORATED CONDUCTORS	Replace conductors with damaged or deteriorated insulation.(14E-1-110.7)	OPEN BOX FRONT FOYER CEILING REMOVE THROUGHOUT WHERE REQUIRED DANGEROUS AND HAZARDOUS	SEQ #: 028□	6200	S	INDIANA	AVE	20	Open
01/17/2023	EL1880	DETERIORATED CONDUCTORS	Replace conductors with damaged or deteriorated insulation.(14E-1-110.7)	OPEN BOX FRONT FOYER CEILING REMOVE THROUGHOUT WHERE REQUIRED DANGEROUS AND HAZARDOUS	SEQ #: 030□	6200	S	INDIANA	AVE	20	Open

01/30/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	MAIN SERVICE DISCONNECTS VANDALIZED, OPEN, MISSING BREAKERS DAMAGED MISSING RISER SUPPORTS NO COMMON METER ENSURE SERVICE IN APPROVED CONDITION DANGEROUS AND HAZARDOUS	SEQ #: 020□	1517	S	KEELER	AVE	24	Open
01/30/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	NO VISIBLE WATER GROUND ENSURE SERVICE GROUNDED IN APPROVED MANNER DANGEROUS AND HAZARDOUS	SEQ #: 021□	1517	S	KEELER	AVE	24	Open
01/30/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	OPEN WIRING AT LOWER REAR PORCH AREA BETWEEN PANELS REMOVE WHERE REQUIRED DANGEROUS AND HAZARDOUS	SEQ #: 023□	1517	S	KEELER	AVE	24	Open
01/30/2023	EL1880	DETERIORATED CONDUCTORS	Replace conductors with damaged or deteriorated insulation.(14E-1-110.7)	PULL BOX REAR STAIR AREA REPLACE WHERE REQUIRED	SEQ #: 030□	1517	S	KEELER	AVE	24	Open
01/31/2023	EL1825	SYSTEM III	Install system III emergency lighting. (14E-7-700.6, 14E-7-700.22)	INSTALL REQUIRED EXIT SIGNS AND EM LIGHTING THROUGHOUT THE 1ST FLOOR COMMERCIAL UNIT D&H	SEQ #: 022□	3347	W	IRVING PARK	RD	33	Open
02/01/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	CABLES APPEAR TO BE DETERIORATING AT SERVICE HEAD ENSURE SERVICE IN APPROVED CONDITION	SEQ #: 019□	3710	N	KEDZIE	AVE	33	Open
02/01/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	3710 MAIN SERVICE RISERS MISSING SUPPORTS MAIN SERVICE OVERHEAD SPLICES APPEAR TO BE DETERIORATING MAIN SERVICE ATTACHMENT POINTS DETERIORATING FACE PLATE OF SERVICE HEAD DETERIORATING ENSURE SERVICE IN APPROVED CONDITION	SEQ #: 018□	3710	N	KEDZIE	AVE	33	Open
02/01/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	3710 MAIN SERVICE RISERS MISSING SUPPORTS MAIN SERVICE OVERHEAD SPLICES APPEAR TO BE DETERIORATING MAIN SERVICE ATTACHMENT POINTS DETERIORATING FACE PLATE OF SERVICE HEAD DETERIORATING ENSURE SERVICE IN APPROVED CONDITION	SEQ #: 019□	3710	N	KEDZIE	AVE	33	Open
02/01/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	3720 MISSING METER OPENING COVERS COVER ALL UNUSED OPENINGS IN SERVICE EQUIPMENT ENSURE SERVICE IN APPROVED CONDITION DANGEROUS AND HAZARDOUS	SEQ #: 043□	3710	N	KEDZIE	AVE	33	Open
02/01/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	3720 MISSING METER OPENING COVERS COVER ALL UNUSED OPENINGS IN SERVICE EQUIPMENT ENSURE SERVICE IN APPROVED CONDITION DANGEROUS AND HAZARDOUS	SEQ #: 044□	3710	N	KEDZIE	AVE	33	Open
02/01/2023	EL1805	DEFECTIVE DISTRIBUTION	Replace defective distribution equipment. (14E-4-408.30, 14E-4-408.36, 14E-4-408.37, 14E-4-408.38, 14E-4-408.39, 14E-4-408.40, 14E-4-408.41))	BROKEN VARIOUS AREAS MISSING PANEL FILLERS ENSURE DISTRIBUTION IN APPROVED CONDITION THROUGHOUT DANGEROUS AND HAZARDOUS	SEQ #: 021□	3710	N	KEDZIE	AVE	33	Open
02/01/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	3710 NO VISIBLE WATER GROUNDS ENSURE SERVICES GROUND IN APPROVED MANNER DANGEROUS AND HAZARDOUS	SEQ #: 020□	3710	N	KEDZIE	AVE	33	Open
02/01/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	3720 NO VISIBLE WATER GROUND ENSURE SERVICE GROUNDED IN APPROVED MANNER DANGEROUS AND HAZARDOUS	SEQ #: 044□	3710	N	KEDZIE	AVE	33	Open
02/01/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	3720 NO VISIBLE WATER GROUND ENSURE SERVICE GROUNDED IN APPROVED MANNER DANGEROUS AND HAZARDOUS	SEQ #: 045□	3710	N	KEDZIE	AVE	33	Open
02/01/2023	EL1817	CONTINUITY OF RACEWAYS	Provide ground continuity for electrical cable, raceway, and enclosure. (14E-3-300.10, 14E-3-300.13)	3710 LIQUID TIGHT FLEXIBLE METAL CONDUIT NOT ATTACHED TO BOX FRONT INTERIOR STAIRS ENSURE GROUND CONTINUITY WHERE REQUIRED DANGEROUS AND HAZARDOUS	SEQ #: 033□	3710	N	KEDZIE	AVE	33	Open

02/01/2023	EL1817	CONTINUITY OF RACEWAYS	Provide ground continuity for electrical cable, raceway, and enclosure. (14E-3-300.10, 14E-3-300.13)	3710 LIQUID TIGHT FLEXIBLE METAL CONDUIT NOT ATTACHED TO BOX FRONT INTERIOR STAIRS ENSURE GROUND CONTINUITY WHERE REQUIRED DANGEROUS AND HAZARDOUS	SEQ #: 034□	3710	N	KEDZIE	AVE	33	Open
02/01/2023	EL1827	RESTORE EXIT AND EM	Restore exit and emergency lighting system and related equipment to working condition. (14E-7-700.6)	3710 UNAPPROVED, INSUFFICIENT, UNSUPPORTED, UNMAINTAINED EXIT SIGNS AND BATTERY LIGHTS THROUGHOUT SPACE DANGEROUS AND HAZARDOUS	SEQ #: 023□	3710	N	KEDZIE	AVE	33	Open
02/01/2023	EL1827	RESTORE EXIT AND EM	Restore exit and emergency lighting system and related equipment to working condition. (14E-7-700.6)	INSTALLED IN APPROVED MANNER, UNAPPROVED BATTERY UNITS, NOT MAINTAINED ,DAMAGED, INSUFFICIENT DANGEROUS AND HAZARDOUS	SEQ #: 042□	3710	N	KEDZIE	AVE	33	Open
02/01/2023	EL1827	RESTORE EXIT AND EM	Restore exit and emergency lighting system and related equipment to working condition. (14E-7-700.6)	INSTALLED IN APPROVED MANNER, UNAPPROVED BATTERY UNITS, NOT MAINTAINED ,DAMAGED, INSUFFICIENT DANGEROUS AND HAZARDOUS	SEQ #: 043□	3710	N	KEDZIE	AVE	33	Open
02/01/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	3710 OPEN WIRE ABOVE 2ND FLOOR DROP CEILING REMOVE WHERE REQUIRED THROUGHOUT DANGEROUS AND HAZARDOUS	SEQ #: 024□	3710	N	KEDZIE	AVE	33	Open
02/01/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	3710 OPEN WIRE ABOVE 2ND FLOOR DROP CEILING REMOVE WHERE REQUIRED THROUGHOUT DANGEROUS AND HAZARDOUS	SEQ #: 025□	3710	N	KEDZIE	AVE	33	Open
02/01/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	REMOVE WHERE REQUIRED DANGEROUS AND HAZARDOUS	SEQ #: 038□	3710	N	KEDZIE	AVE	33	Open
02/01/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	REMOVE WHERE REQUIRED DANGEROUS AND HAZARDOUS	SEQ #: 039□	3710	N	KEDZIE	AVE	33	Open
02/01/2023	EL1833	SECURE RACEWAY	Strap and secure raceway and armored cable. (14E-1-110.13(a))	DROP CEILING SECURE WHERE REQUIRED THROUGHOUT	SEQ #: 025□	3710	N	KEDZIE	AVE	33	Open
02/01/2023	EL1833	SECURE RACEWAY	Strap and secure raceway and armored cable. (14E-1-110.13(a))	DROP CEILING SECURE WHERE REQUIRED THROUGHOUT	SEQ #: 026□	3710	N	KEDZIE	AVE	33	Open
02/01/2023	EL1833	SECURE RACEWAY	Strap and secure raceway and armored cable. (14E-1-110.13(a))	3720 UNSUPPORTED FALLING CONDUITS BASEMENT AREAS SECURE WHERE REQUIRED DANGEROUS AND HAZARDOUS	SEQ #: 039□	3710	N	KEDZIE	AVE	33	Open
02/01/2023	EL1833	SECURE RACEWAY	Strap and secure raceway and armored cable. (14E-1-110.13(a))	3720 UNSUPPORTED FALLING CONDUITS BASEMENT AREAS SECURE WHERE REQUIRED DANGEROUS AND HAZARDOUS	SEQ #: 040□	3710	N	KEDZIE	AVE	33	Open
01/19/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	RESTORE POWER TO UNIT 2 WHICH IS OFF DUE TO COMED SHUTOFF	SEQ #: 017□	2238	S	KEELER	AVE	22	Open
01/19/2023	EL1833	SECURE RACEWAY	Strap and secure raceway and armored cable. (14E-1-110.13(a))	SPECIFICALLY ON THE SOUTH EXTERIOR ELEVATION	SEQ #: 024□	2238	S	KEELER	AVE	22	Open
02/07/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	MISSING ITS COVER AND TAMPERED WITH OVERHEAD SERVICE CABLES IN CONTACT WITH OVERHEAD LOW VOLTAGE CABLES AT REAR EXTERIOR ENSURE SERVICE IN APPROVED CONDITION DANGEROUS AND HAZARDOUS	SEQ #: 017□	5069	W	MADISON	ST	28	Open
02/07/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	NO VISIBLE WATER GROUND ENSURE SERVICE GROUNDED IN APPROVED MANNER DANGEROUS AND HAZARDOUS	SEQ #: 018□	5069	W	MADISON	ST	28	Open
02/07/2023	EL1827	RESTORE EXIT AND EM	Restore exit and emergency lighting system and related equipment to working condition. (14E-7-700.6)	EXISTING EMERGENCY LIGHTS AND EXIT SIGNS UNMAINTAINED, UNAPPROVED, INSUFFICIENT, SUPPORTED IN UNAPPROVED MANNER DANGEROUS AND HAZARDOUS	SEQ #: 021□	5069	W	MADISON	ST	28	Open
02/07/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	EQUIPMENT REMOVE WHERE REQUIRED THROUGHOUT PREMISES DANGEROUS AND HAZARDOUS	SEQ #: 023□	5069	W	MADISON	ST	28	Open

02/01/2023	EL1807	BOND AROUND FITTINGS	Install bonding conductor across water meter, union, and similar fittings of cold water pipe used as grounding electrode. (14E-2-250.28)	BOND AROUND WATER METER	SEQ #: 001□	7515	S	CHAPPEL	AVE	08	Open
02/01/2023	EL1857	SMOKE & CARBON DETECTORS	Install required smoke and carbon monoxide detectors. (14E-5-570.10(h)(i))	INSTALL SMOKE AND CARBON MONOXIDE DETECTORS TO CODE	SEQ #: 005□	7515	S	CHAPPEL	AVE	08	Open
02/10/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	3647-49 SERVICE DISCONNECT FOR LOT SIGN DETERIORATED AND COVER IS NOT SECURE DANGEROUS AND HAZARDOUS	SEQ #: 032□	3649	W	DIVISION	ST	36	Open
02/10/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	3647-49 SERVICE DISCONNECT FOR LOT SIGN DETERIORATED AND COVER IS NOT SECURE DANGEROUS AND HAZARDOUS	SEQ #: 033□	3649	W	DIVISION	ST	36	Open
02/10/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	3649 CABLES AT SERVICE HEAD APPEAR DETERIORATED /DAMAGED MAIN DISCONNECTS/PANELS ARE LOCATED ON STAIRS, APPEAR DETERIORATED, HAVE LOOSE COVERS, HAVE NUMEROUS MISSING CIRCUIT BREAKERS, AND BUSS APPEARS DAMAGED ENSURE SERVICE IN APPROVED CONDITION DANGEROUS AND HAZARDOUS	SEQ #: 015□	3649	W	DIVISION	ST	36	Open
02/10/2023	EL1805	DEFECTIVE DISTRIBUTION	Replace defective distribution equipment. (14E-4-408.30, 14E-4-408.36, 14E-4-408.37, 14E-4-408.38, 14E-4-408.39, 14E-4-408.40, 14E-4-408.41))	3649 BASEMENT PANEL IS DETERIORATED AND HAS LOOSE COVER ENSURE DISTRIBUTION THROUGHOUT IN APPROVED CONDITION DANGEROUS AND HAZARDOUS	SEQ #: 017□	3649	W	DIVISION	ST	36	Open
02/10/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	3649 NO VISIBLE WATER GROUND ENSURE SERVICE GROUNDED IN APPROVED MANNER DANGEROUS AND HAZARDOUS	SEQ #: 016□	3649	W	DIVISION	ST	36	Open
02/10/2023	EL1827	RESTORE EXIT AND EM	Restore exit and emergency lighting system and related equipment to working condition. (14E-7-700.6)	3649 REQUIRED EMERGENCY LIGHTING SYSTEM INSUFFICIENT INOPERABLE UNAPPROVED,UNMAINTAINED DANGEROUS AND HAZARDOUS	SEQ #: 025□	3649	W	DIVISION	ST	36	Open
02/10/2023	EL1827	RESTORE EXIT AND EM	Restore exit and emergency lighting system and related equipment to working condition. (14E-7-700.6)	3649 REQUIRED EMERGENCY LIGHTING SYSTEM INSUFFICIENT INOPERABLE UNAPPROVED,UNMAINTAINED DANGEROUS AND HAZARDOUS	SEQ #: 026□	3649	W	DIVISION	ST	36	Open
02/10/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	3647 OPEN WIRING BASEMENT AREA REMOVE WHERE REQUIRED THROUGHOUT PREMISES DANGEROUS AND HAZARDOUS	SEQ #: 019□	3649	W	DIVISION	ST	36	Open
02/10/2023	EL1839	CORRODED CONDUIT & EQUIP	Replace rusted, deteriorated, or corroded conduit, cabinet, electrical box, or fitting. (14E-3-300.13, 14E-1-110.12(b))	3649 CORRODED BOXES, RACEWAY, EQUIPMENT BASEMENT REMOVE/REPLACE WHERE REQUIRED	SEQ #: 020□	3649	W	DIVISION	ST	36	Open
02/15/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	EAST EXTERIOR ARE IN DETERIORATED STATE MIDDLE ELECTRICAL SERVICE HAS DETERIORATED RISER, DETERIORATED SUPPORTS DETERIORATED CABLES VISIBLE AT HEAD DETERIORATED INACCESSIBLE OPEN MOGUL SOUTH ELECTRICAL SERVICE HAS DETERIORATED RISER,DETERIORATED SUPPORTS, DETERIORATED CABLE ENSURE ALL SERVICES IN APPROVED CONDITION DANGEROUS AND HAZARDOUS	SEQ #: 030□	1734	W	GREENLEAF	AVE	49	Open
02/15/2023	EL1822	EXPOSED WIRING FIXTURES	Remove exposed wiring at light fixture. (14E-4-410.48)	COMMON INTERIOR STAIRWELL HAS DAMAGED OPEN AIR SPLICED WIRING REMOVE OPEN WIRING AT LIGHT FIXTURES WHERE REQUIRED THROUGHOUT PREMISES DANGEROUS AND HAZARDOUS	SEQ #: 032□	1734	W	GREENLEAF	AVE	49	Open

02/15/2023	EL1826	SYSTEM II	Install system II emergency lighting. (14E-7-700.6, 14E-7-700.21)	LIGHTING SYSTEM NOT APPROVED NOT SUFFICIENT INSTALL REQUIRED SYSTEM WHERE REQUIRED PREMISES DANGEROUS AND HAZARDOUS	SEQ #: 024□	1734	W	GREENLEAF	AVE	49	Open
02/15/2023	EL1833	SECURE RACEWAY	Strap and secure raceway and armored cable. (14E-1-110.13(a))	MECHANICAL ROOM SECURE WHERE REQUIRED	SEQ #: 027□	1734	W	GREENLEAF	AVE	49	Open
02/15/2023	EL1880	DETERIORATED CONDUCTORS	Replace conductors with damaged or deteriorated insulation.(14E-1-110.7)	WIRING VISIBLE AT OPEN BOX MECHANICAL ROOM CEILING REPLACE WHERE REQUORED THROUGHOUT PREMISES DANGEROUS AND HAZARDOUS	SEQ #: 023□	1734	W	GREENLEAF	AVE	49	Open
02/06/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	SUPPORTS AND MAST IS SHOWING SIGNS OF DETERIORATION ENSURE SERVICE IN APPROVED CONDITION DANGEROUS AND HAZARDOUS	SEQ #: 010□	5943	W	LAWRENCE	AVE	45	Open
02/06/2023	EL1805	DEFECTIVE DISTRIBUTION	4-408.30, 14E-4-408.36, 14E-4-408.37, 14E-4-408.38, 14E-4-408.39, 14E-4-408.40, 14E-4-408.41))	NUMEROUS MISSING PANEL FILLERS AT PANELS ENSURE DISTRIBUTION IN APPROVED CONDITION DANGEROUS AND HAZARDOUS	SEQ #: 012□	5943	W	LAWRENCE	AVE	45	Open
02/06/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	NO VISIBLE WATER GROUND ENSURE SERVICE GROUNDED IN APPROVED MANNER DANGEROUS AND HAZARDOUS	SEQ #: 011□	5943	W	LAWRENCE	AVE	45	Open
02/06/2023	EL1817	CONTINUITY OF RACEWAYS	raceway, and enclosure. (14E-3-300.10, 14E-3-300.13)	LOOSE BOX FITTINGS AT REAR PANEL ENSURE GROUND CONTINUITY WHERE REQUIRED	SEQ #: 018□	5943	W	LAWRENCE	AVE	45	Open
02/06/2023	EL1827	RESTORE EXIT AND EM	and related equipment to working condition. (14E-7-700.6)	UNABLE TO TEST EXISTING BATTERY LIGHTS AND EXIT SIGN OPERABILITY .	SEQ #: 019□	5943	W	LAWRENCE	AVE	45	Open
02/06/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	OPEN WIRE AT FRONT EXTERIOR SIGN AND BOX REMOVE WHERE REQUIRED THROUGHOUT DANGEROUS AND HAZARDOUS	SEQ #: 013□	5943	W	LAWRENCE	AVE	45	Open
02/17/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	6500-10 MAIN ELECTRICAL SERVICE OVERHEAD CONDUCTORS COVERED BY AND IN CONTACT WITH A PLYWOOD ENCLOSURE ENSURE ELECTRICAL SERVICE IN APPROVED CONDITION DANGEROUS AND HAZARDOUS	SEQ #: 030□	6500	S	WESTERN	AVE	16	Open
02/17/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	6500-10 MAIN ELECTRICAL SERVICE OVERHEAD CONDUCTORS COVERED BY AND IN CONTACT WITH A PLYWOOD ENCLOSURE ENSURE ELECTRICAL SERVICE IN APPROVED CONDITION DANGEROUS AND HAZARDOUS	SEQ #: 032□	6500	S	WESTERN	AVE	16	Open
02/17/2023	EL1805	DEFECTIVE DISTRIBUTION	Replace defective distribution equipment. (14E-4-408.30, 14E-4-408.36, 14E-4-408.37, 14E-4-408.38, 14E-4-408.39, 14E-4-408.40, 14E-4-408.41))	CIRCUIT BREAKERS AND INTERIOR MAT SECTIONS ENSURE DISTRIBUTION THROUGHOUT IN APPROVED CONDITION DANGEROUS AND HAZARDOUS	SEQ #: 015□	6500	S	WESTERN	AVE	16	Open
02/17/2023	EL1805	DEFECTIVE DISTRIBUTION	Replace defective distribution equipment. (14E-4-408.30, 14E-4-408.36, 14E-4-408.37, 14E-4-408.38, 14E-4-408.39, 14E-4-408.40, 14E-4-408.41))	CIRCUIT BREAKERS AND INTERIOR MAT SECTIONS ENSURE DISTRIBUTION THROUGHOUT IN APPROVED CONDITION DANGEROUS AND HAZARDOUS	SEQ #: 017□	6500	S	WESTERN	AVE	16	Open
02/17/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	SERVICE ENSURE SERVICE GROUNDED IN APPROVED MANNER DANGEROUS AND HAZARDOUS	SEQ #: 031□	6500	S	WESTERN	AVE	16	Open
02/17/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	SERVICE ENSURE SERVICE GROUNDED IN APPROVED MANNER DANGEROUS AND HAZARDOUS	SEQ #: 033□	6500	S	WESTERN	AVE	16	Open
02/17/2023	EL1827	RESTORE EXIT AND EM	Restore exit and emergency lighting system and related equipment to working condition. (14E-7-700.6)	6502-04 EXISTING EM LIGHT AND EXIT SIGNS UNMAINTAINED, UNABLE TO TEST, INSUFFICIENT DANGEROUS AND HAZARDOUS	SEQ #: 027□	6500	S	WESTERN	AVE	16	Open
02/17/2023	EL1827	RESTORE EXIT AND EM	Restore exit and emergency lighting system and related equipment to working condition. (14E-7-700.6)	6502-04 EXISTING EM LIGHT AND EXIT SIGNS UNMAINTAINED, UNABLE TO TEST, INSUFFICIENT DANGEROUS AND HAZARDOUS	SEQ #: 029□	6500	S	WESTERN	AVE	16	Open

02/17/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	6502-04 OPEN WIRING WITH OPEN AIR SPLICES AT FRONT WINDOW AREA REMOVE WHERE REQUIRED THROUGHOUT WHERE REQUIRED DANGEROUS AND HAZARDOUS	SEQ #: 019□	6500	S	WESTERN	AVE	16	Open
02/17/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	6502-04 OPEN WIRING WITH OPEN AIR SPLICES AT FRONT WINDOW AREA REMOVE WHERE REQUIRED THROUGHOUT WHERE REQUIRED DANGEROUS AND HAZARDOUS	SEQ #: 021□	6500	S	WESTERN	AVE	16	Open
03/02/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	OVERHEAD SERVICE CONDUCTORS WITHIN REACH OF REAR PORCH OVERHEAD SERVICE CONDUCTORS IN NEAR CONTACT WITH REAR WINDOW AWNING ENSURE SERVICE IN APPROVED CONDITION DANGEROUS AND HAZARDOUS	SEQ #: 009□	5642	S	MASON	AVE	13	Open
03/02/2023	EL1817	CONTINUITY OF RACEWAYS	Provide ground continuity for electrical cable, raceway, and enclosure. (14E-3-300.10, 14E-3-300.13)	LIGHT FIXTURE ENSURE GROUND CONTINUITY WHERE REQUIRED DANGEROUS AND HAZARDOUS	SEQ #: 016□	5642	S	MASON	AVE	13	Open
02/23/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	SERVICE DISCONNECTS LOCATED IN BATHROOM SERVICE ENTRANCE CONDUCTORS OVER 5' ENSURE SERVICE IN APPROVED CONDITION DANGEROUS AND HAZARDOUS	SEQ #: 018□	1801	W	87TH	ST	18	Open
02/23/2023	EL1805	DEFECTIVE DISTRIBUTION	Replace defective distribution equipment. (14E-4-408.30, 14E-4-408.36, 14E-4-408.37, 14E-4-408.38, 14E-4-408.39, 14E-4-408.40, 14E-4-408.41)	PANELS MISSING CIRCUIT BREAKERS MULTIPLE MINI CIRCUIT BREAKERS USED IN PANELS ENSURE DISTRIBUTION IN APPROVED CONDITION DANGEROUS AND HAZARDOUS	SEQ #: 019□	1801	W	87TH	ST	18	Open
02/23/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	NO VISIBLE WATER GROUND ENSURE SERVICE GROUNDED IN APPROVED MANNER DANGEROUS AND HAZARDOUS	SEQ #: 020□	1801	W	87TH	ST	18	Open
02/23/2023	EL1827	RESTORE EXIT AND EM	Restore exit and emergency lighting system and related equipment to working condition. (14E-7-700.6)	UNAPPROVED INSUFFICIENT MOUNTED IN UNAPPROVED MANNER UNABLE TO TEST DANGEROUS AND HAZARDOUS	SEQ #: 022□	1801	W	87TH	ST	18	Open
02/23/2023	EL1827	RESTORE EXIT AND EM	Restore exit and emergency lighting system and related equipment to working condition. (14E-7-700.6)	OPEN AIR SPLICED WIRES AT FLEXIBLE METAL CONDUIT REAR CLOSET ENSURE GROUND CONTINUITY WHERE REQUIRED DANGEROUS AND HAZARDOUS	SEQ #: 025□	1801	W	87TH	ST	18	Open
02/23/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	OPEN WIRING VARIOUS AREAS 1ST FLOOR AND BASEMENT REMOVE WHERE REQUIRED DANGEROUS AND HAZARDOUS	SEQ #: 024□	1801	W	87TH	ST	18	Open
02/23/2023	EL1833	SECURE RACEWAY	Strap and secure raceway and armored cable. (14E-1-110.13(a))	UNSUPPORTED RACEWAYS VARIOUS AREAS THROUGHOUT PREMISES SECURE WHERE REQUIRED	SEQ #: 032□	1801	W	87TH	ST	18	Open
02/23/2023	EL1839	CORRODED CONDUIT & EQUIP	Replace rusted, deteriorated, or corroded conduit, cabinet, electrical box, or fitting. (14E-3-300.13, 14E-1-110.12(b))	CORRODED RACEWAYS AND BOXES FRONT EXTERIOR AND BASEMENT REMOVE WHERE REQUIRED THROUGHOUT	SEQ #: 036□	1801	W	87TH	ST	18	Open
02/23/2023	EL1880	DETERIORATED CONDUCTORS	Replace conductors with damaged or deteriorated insulation.(14E-1-110.7)	DAMAGED WIRING AND DETERIORATED WIRING VISIBLE AT BASEMENT REMOVE WHERE REQUIRED THROUGHOUT PREMISES DANGEROUS AND HAZARDOUS	SEQ #: 035□	1801	W	87TH	ST	18	Open
02/24/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	RACEWAY DETERIORATED WEST OVERHEAD SERVICE CABLES DETERIORATED AND UNINSULATED ENSURE SERVICES(S) IN APPROVED CONDITION MULTIPLE SERVICE ON BUILDING DISCONNECTS MUST BE GROUPED ENSURE SERVICES IN APPROVED CONDITION DANGEROUS AND HAZARDOUS	SEQ #: 033□	5300	W	DIVISION	ST	37	Open

02/24/2023	EL1804	DEFECTIVE FEEDER	Replace defective feeder. (14E-2-215)	COUPLED FEEDER RACEWAY AT SOUTH EXTERIOR ENSURE FEEDERS THROUGHOUT IN APPROVED CONDITION DANGEROUS AND HAZARDOUS	SEQ #: 038□	5300	W	DIVISION	ST	37	Open
02/24/2023	EL1805	DEFECTIVE DISTRIBUTION	Replace defective distribution equipment. (14E-4-408.30, 14E-4-408.36, 14E-4-408.37, 14E-4-408.38, 14E-4-408.39, 14E-4-408.40, 14E-4-408.41)	FROM CLUTTER AND STORAGE OPEN DAMAGED A/C DISCONNECT AT REAR EXTERIOR ENSURE DISTRIBUTION THROUGHOUT IN APPROVED CONDITION DANGEROUS AND HAZARDOUS	SEQ #: 019□	5300	W	DIVISION	ST	37	Open
02/24/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	5300-04 NO VISIBLE WATER GROUNDS ENSURE SERVICES GROUNDED IN APPROVED CONDITION DANGEROUS AND HAZARDOUS	SEQ #: 034□	5300	W	DIVISION	ST	37	Open
02/24/2023	EL1827	RESTORE EXIT AND EM	Restore exit and emergency lighting system and related equipment to working condition. (14E-7-700.6)	5300 EMERGENCY LIGHTS AND EXIT SIGNS BROKEN, UNAPPROVED INSUFFICIENT UNMAINTAINED DANGEROUS AND HAZARDOUS	SEQ #: 022□	5300	W	DIVISION	ST	37	Open
02/24/2023	EL1833	SECURE RACEWAY	Strap and secure raceway and armored cable. (14E-1-110.13(a))	5300 UNSUPPORTED RACEWAYS AT CEILING AREA SECURE WHERE REQUIRED	SEQ #: 028□	5300	W	DIVISION	ST	37	Open
02/03/2023	EL1827	RESTORE EXIT AND EM	Restore exit and emergency lighting system and related equipment to working condition. (14E-7-700.6)	RESTORE EXIT AND EMERGENCY LIGHTING SYSTEM AND RELATED EQUIPMENT TO WORKING CONDITION *AMENDMENT*	SEQ #: 008□	2327	N	MILWAUKEE	AVE	01	Open
09/13/2023	EL1827	RESTORE EXIT AND EM	Restore exit and emergency lighting system and related equipment to working condition. (14E-7-700.6)	**AMENDMENT**RESTORE EXI AND EMERGENCY LIGHTING SYSTEM AND RELATED EQUIPMENT TO WORKING CONDIION	SEQ #: 008□	2327	N	MILWAUKEE	AVE	01	Open
02/24/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	INDICATOR LIGHTS ON FIRE PUMP SERVICE EQUIPMENT NOT FULLY ILLUMINATED ENSURE SERVICE IN OPERABLE CONDITION	SEQ #: 016□	5700	N	SHERIDAN	RD	48	Open
02/24/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	EQUIPMENT NOT COMPLETELY ILLUMINATED ENSURE MAIN SERVICES IN APPROVED CONDITION	SEQ #: 015□	5700	N	SHERIDAN	RD	48	Open
02/24/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	NO VISIBLE WATER GROUNDS ENSURE SERVICES GROUNDED IN APPROVED MANNER	SEQ #: 017□	5700	N	SHERIDAN	RD	48	Open
02/24/2023	EL1827	RESTORE EXIT AND EM	and related equipment to working condition. (14E-7-700.6)	EM NOT MAINTAINED DANGEROUS AND HAZARDOUS	SEQ #: 034□	5700	N	SHERIDAN	RD	48	Open
02/24/2023	EL1827	RESTORE EXIT AND EM	Restore exit and emergency lighting system and related equipment to working condition. (14E-7-700.6)	BEING MAINTAINED SOME EXIT SIGNS AND BATTERY LIGHTS NOT WORKING OR PARTIALLY ILLUMINATED NUMEROUS BATTERY LIGHTS AND EXIT SIGNS NOT WORKING WHEN CIRCUIT DEENERGIZED UNAPPROVED EXIT SIGNS LOWER AREA INSTALL APPROVED BATTERY UNITS WHERE REQUIRED DANGEROUS AND HAZARDOUS	SEQ #: 019□	5700	N	SHERIDAN	RD	48	Open
02/24/2023	EL1833	SECURE RACEWAY	Strap and secure raceway and armored cable. (14E-1-110.13(a))	MECHANICAL AREA SECURE WHERE REQUIRED	SEQ #: 023□	5700	N	SHERIDAN	RD	48	Open
02/22/2023	EL1828	UNAPPROVED EM	from emergency lighting system. (14E-7-700.63)	REPLACE PLASTIC EM LIGHT FIXTURE IN FRONT HALLWAY D&H	SEQ #: 013□	3525	W	VAN BUREN	ST	28	Open
03/07/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	UNAPPROVED TAPS AT SERVICE HEADS UNAPPROVED CLEARANCES OF OVERHEAD SERVICE CABLES AND BUILDING DAMAGED SERVICE SPLICES DETERIORATED SERVICE CONNECTION POINTS WOOD SERVICE MASTS APPEAR DETERIORATED SERVICE RACEWAYS PULLED AWAY FROM METER ENCLOSURES ALL AT VARIOUS AREAS ON REAR EXTERIOR OF ADDRESS RANGE ENSURE SERVICES IN APPROVED CONDITION DANGEROUS AND HAZARDOUS	SEQ #: 014□	2552	N	CLARK	ST	43	Open

03/07/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	UNAPPROVED TAPS AT SERVICE HEADS UNAPPROVED CLEARANCES OF OVERHEAD SERVICE CABLES AND BUILDING DAMAGED SERVICE SPLICES DETERIORATED SERVICE CONNECTION POINTS WOOD SERVICE MASTS APPEAR DETERIORATED SERVICE RACEWAYS PULLED AWAY FROM METER ENCLOSURES ALL AT VARIOUS AREAS ON REAR EXTERIOR OF ADDRESS RANGE ENSURE SERVICES IN APPROVED CONDITION DANGEROUS AND HAZARDOUS	SEQ #: 034	2552	N	CLARK	ST	43	Open
03/07/2023	EL1805	DEFECTIVE DISTRIBUTION	Replace defective distribution equipment. (14E-4-408.30, 14E-4-408.36, 14E-4-408.37, 14E-4-408.38, 14E-4-408.39, 14E-4-408.40, 14E-4-408.41))	2552 SUB PANEL HAS BROKEN COVER AND CORRODED CIRCUIT BREAKERS ENSURE DISTRIBUTION THROUGHOUT PREMISES IN APPROVED CONDITION	SEQ #: 011	2552	N	CLARK	ST	43	Open
03/07/2023	EL1805	DEFECTIVE DISTRIBUTION	Replace defective distribution equipment. (14E-4-408.30, 14E-4-408.36, 14E-4-408.37, 14E-4-408.38, 14E-4-408.39, 14E-4-408.40, 14E-4-408.41))	2552 SUB PANEL HAS BROKEN COVER AND CORRODED CIRCUIT BREAKERS ENSURE DISTRIBUTION THROUGHOUT PREMISES IN APPROVED CONDITION	SEQ #: 019	2552	N	CLARK	ST	43	Open
03/05/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	SERVICE CABLES APPEAR TO SHOW DAMAGE AT SERVICE HEAD ENTRY OVERHEAD SERVICE CABLES LAYING ON CORNER OF BUILDING PANELS OPEN, DAMAGED,SEVERELY CORRODED ENSURE SERVICE IN APPROVED CONDITION DANGEROUS AND HAZARDOUS	SEQ #: 018	4261	W	CERMAK	RD	22	Open
03/05/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	SERVICE CABLES APPEAR TO SHOW DAMAGE AT SERVICE HEAD ENTRY OVERHEAD SERVICE CABLES LAYING ON CORNER OF BUILDING PANELS OPEN, DAMAGED,SEVERELY CORRODED ENSURE SERVICE IN APPROVED CONDITION DANGEROUS AND HAZARDOUS	SEQ #: 023	4261	W	CERMAK	RD	22	Open
03/05/2023	EL1805	DEFECTIVE DISTRIBUTION	Replace defective distribution equipment. (14E-4-408.30, 14E-4-408.36, 14E-4-408.37, 14E-4-408.38, 14E-4-408.39, 14E-4-408.40, 14E-4-408.41))	PANELS WITH MINI BREAKERS AT BASEMENT DAMAGED CORRODED DISCONNECTS AT BASEMENT ENSURE DISTRIBUTION THROUGHOUT IN APPROVED CONDITION DANGEROUS AND HAZARDOUS	SEQ #: 022	4261	W	CERMAK	RD	22	Open
03/05/2023	EL1805	DEFECTIVE DISTRIBUTION	Replace defective distribution equipment. (14E-4-408.30, 14E-4-408.36, 14E-4-408.37, 14E-4-408.38, 14E-4-408.39, 14E-4-408.40, 14E-4-408.41))	PANELS WITH MINI BREAKERS AT BASEMENT DAMAGED CORRODED DISCONNECTS AT BASEMENT ENSURE DISTRIBUTION THROUGHOUT IN APPROVED CONDITION DANGEROUS AND HAZARDOUS	SEQ #: 027	4261	W	CERMAK	RD	22	Open
03/05/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	NO VISIBLE WATER GROUND ENSURE SERVICE GROUNDED IN APPROVED MANNER DANGEROUS AND HAZARDOUS	SEQ #: 020	4261	W	CERMAK	RD	22	Open
03/05/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	NO VISIBLE WATER GROUND ENSURE SERVICE GROUNDED IN APPROVED MANNER DANGEROUS AND HAZARDOUS	SEQ #: 025	4261	W	CERMAK	RD	22	Open
03/05/2023	EL1817	CONTINUITY OF RACEWAYS	Provide ground continuity for electrical cable, raceway, and enclosure. (14E-3-300.10, 14E-3-300.13)	EXTERIOR CONDUITS WITH LOOSE FITTINGS THROUGHOUT BASEMENT CONDUITS NOT ATTACHED TO LIGHT FIXTURES FRONT EXTERIOR ENSURE GROUND CONTINUITY WHERE REQUIRED THROUGHOUT PREMISES DANGEROUS AND HAZARDOUS	SEQ #: 027	4261	W	CERMAK	RD	22	Open

03/05/2023	EL1817	CONTINUITY OF RACEWAYS	Provide ground continuity for electrical cable, raceway, and enclosure. (14E-3-300.10, 14E-3-300.13)	EXTERIOR CONDUITS WITH LOOSE FITTINGS THROUGHOUT BASEMENT CONDUITS NOT ATTACHED TO LIGHT FIXTURES FRONT EXTERIOR ENSURE GROUND CONTINUITY WHERE REQUIRED THROUGHOUT PREMISES DANGEROUS AND HAZARDOUS	SEQ #: 032□	4261	W	CERMAK	RD	22	Open
03/05/2023	EL1827	RESTORE EXIT AND EM	and related equipment to working condition. (14E-7-700.6)	MAINTAINED DAMAGED DANGEROUS AND HAZARDOUS	SEQ #: 036□	4261	W	CERMAK	RD	22	Open
03/05/2023	EL1827	RESTORE EXIT AND EM	and related equipment to working condition. (14E-7-700.6)	MAINTAINED DAMAGED DANGEROUS AND HAZARDOUS	SEQ #: 041□	4261	W	CERMAK	RD	22	Open
03/05/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	AREAS AND FRONT EXTERIOR REMOVE WHERE REQUIRED DANGEROUS AND HAZARDOUS	SEQ #: 024□	4261	W	CERMAK	RD	22	Open
03/05/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	AREAS AND FRONT EXTERIOR REMOVE WHERE REQUIRED DANGEROUS AND HAZARDOUS	SEQ #: 029□	4261	W	CERMAK	RD	22	Open
03/05/2023	EL1833	SECURE RACEWAY	Strap and secure raceway and armored cable. (14E-1-110.13(a))	BASEMENTS AREAS SECURE WHERE REQUIRED	SEQ #: 028□	4261	W	CERMAK	RD	22	Open
03/05/2023	EL1833	SECURE RACEWAY	Strap and secure raceway and armored cable. (14E-1-110.13(a))	BASEMENTS AREAS SECURE WHERE REQUIRED	SEQ #: 033□	4261	W	CERMAK	RD	22	Open
03/05/2023	EL1839	CORRODED CONDUIT & EQUIP	Replace rusted, deteriorated, or corroded conduit, cabinet, electrical box, or fitting. (14E-3-300.13, 14E-1-110.12(b))	CORRODED BOXES, CONDUIT, EQUIPMENT THROUGHOUT BASEMENT REPLACE WHERE REQUIRED DANGEROUS AND HAZARDOUS	SEQ #: 026□	4261	W	CERMAK	RD	22	Open
03/05/2023	EL1839	CORRODED CONDUIT & EQUIP	Replace rusted, deteriorated, or corroded conduit, cabinet, electrical box, or fitting. (14E-3-300.13, 14E-1-110.12(b))	CORRODED BOXES, CONDUIT, EQUIPMENT THROUGHOUT BASEMENT REPLACE WHERE REQUIRED DANGEROUS AND HAZARDOUS	SEQ #: 031□	4261	W	CERMAK	RD	22	Open
03/05/2023	EL1880	DETERIORATED CONDUCTORS	Replace conductors with damaged or deteriorated insulation. (14E-1-110.7)	WIRING VISIBLE AT OPEN BOXES, TROUGHS, OPEN EQUIPMENT VARIOUS AREAS AT BASEMENT REPLACE WHERE REQUIRED THROUGHOUT PREMISES DANGEROUS AND HAZARDOUS	SEQ #: 025□	4261	W	CERMAK	RD	22	Open
03/05/2023	EL1880	DETERIORATED CONDUCTORS	Replace conductors with damaged or deteriorated insulation. (14E-1-110.7)	WIRING VISIBLE AT OPEN BOXES, TROUGHS, OPEN EQUIPMENT VARIOUS AREAS AT BASEMENT REPLACE WHERE REQUIRED THROUGHOUT PREMISES DANGEROUS AND HAZARDOUS	SEQ #: 030□	4261	W	CERMAK	RD	22	Open
01/27/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	OF DETERIORATION AND DOOR WILL NOT OPEN SERVICE RISER SUPPORTS UNAPPROVED INSUFFICIENT, CORRODED EXTERIOR OVERHEAD SERVICE SPLICES APPEAR TO HAVE INSUFFICIENT INSULATION SERVICE MODIFIED FROM ORIGINAL CONDITION NEW PANELS ENSURE SERVICE IN APPROVED CONDITION DANGEROUS AND HAZARDOUS	SEQ #: 020□	417	E	60TH	ST	20	Open
01/27/2023	EL1805	DEFECTIVE DISTRIBUTION	Replace defective distribution equipment. (14E-4-408.30, 14E-4-408.36, 14E-4-408.37, 14E-4-408.38, 14E-4-408.39, 14E-4-408.40, 14E-4-408.41)	DISTRIBUTION PANELS AT BASEMENT HAVE TANDEM CIRCUIT BREAKERS (MINI-BREAKERS) ENSURE DISTRIBUTION IN APPROVED CONDITION THROUGHOUT	SEQ #: 022□	417	E	60TH	ST	20	Open
01/27/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	NO VISIBLE WATER GROUND ENSURE SERVICE GROUNDED IN APPROVED MANNER DANGEROUS AND HAZARDOUS	SEQ #: 021□	417	E	60TH	ST	20	Open
01/27/2023	EL1817	CONTINUITY OF RACEWAYS	Provide ground continuity for electrical cable, raceway, and enclosure. (14E-3-300.10, 14E-3-300.13)	CONDUIT NOT ATTACHED TO PANEL TROUGH AT BASEMENT FLEXIBLE CONDUIT FROM MAIN DISCONNECT TO METER ENCLOSURE ENSURE EQUIPMENT GROUND WHERE REQUIRED THROUGHOUT DANGEROUS AND HAZARDOUS	SEQ #: 026□	417	E	60TH	ST	20	Open

01/27/2023	EL1833	SECURE RACEWAY	Strap and secure raceway and armored cable. (14E-1-110.13(a))	FALLING RACEWAY AT BASEMENT UNSUPPORTED CONDUITS SIDE EXTERIOR SECURE WHERE REQUIRED THROUGHOUT DANGEROUS AND HAZARDOUS	SEQ #: 033□	417	E	60TH	ST	20	Open
01/27/2023	EL1839	CORRODED CONDUIT & EQUIP	Replace rusted, deteriorated, or corroded conduit, cabinet, electrical box, or fitting. (14E-3-300.13, 14E-1-110.12(b))	CORRODED CONDUIT BOXES EQUIPMENT AT EXTERIOR AND BASEMENT REPLACE WHERE REQUIRED THROUGHOUT	SEQ #: 025□	417	E	60TH	ST	20	Open
02/01/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	STEALING ELECTRIC FROM POLE (14E-2-230)	SEQ #: 010□	2035	W	70TH	ST	17	Open
02/01/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	STEALING ELECTRIC FROM POLE (14E-2-230)	SEQ #: 020□	2035	W	70TH	ST	17	Open
02/01/2023	EL1803	DEFECTIVE METER EQUIPMENT	Replace defective meter socket. (14E-2-230.62,14E-2-230.66,14E-3-312.5)	DANGEROUS AND HAZARDOUS CONDITION (230.62 (B) (14E-1-110.2.7)	SEQ #: 009□	2035	W	70TH	ST	17	Open
02/01/2023	EL1803	DEFECTIVE METER EQUIPMENT	Replace defective meter socket. (14E-2-230.62,14E-2-230.66,14E-3-312.5)	DANGEROUS AND HAZARDOUS CONDITION (230.62 (B) (14E-1-110.2.7)	SEQ #: 019□	2035	W	70TH	ST	17	Open
07/12/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	INSTALL PROPER SIZE GROUNDING CONDUCTOR	SEQ #: 021□	2035	W	70TH	ST	17	Open
02/08/2023	EL1803	DEFECTIVE METER EQUIPMENT	Replace defective meter socket. (14E-2-230.62,14E-2-230.66,14E-3-312.5)	OPEN ELECTRIC METER THIS POSES A DANGEROUS AND HAZARDOUS CONDITION	SEQ #: 002□	7119	S	EMERALD	AVE	06	Open
02/16/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	HEAD LOW VOLTAGE CABLES ENTANGLED WITH OVERHEAD SERVICE CABLES NEAR HEAD METER COVER NOT COMPLETELY SEALED AT SIDE EXTERIOR ENSURE SERVICE IN APPROVED CONDITION DANGEROUS AND HAZARDOUS	SEQ #: 012□	1321	S	KARLOV	AVE	24	Open
02/16/2023	EL1817	CONTINUITY OF RACEWAYS	Provide ground continuity for electrical cable, raceway, and enclosure. (14E-3-300.10, 14E-3-300.13)	LIQUID TIGHT FLEXIBLE METAL CONDUIT AT 3RD FLOOR PORCH A/C CONDENSER PULLED AWAY FROM DISCONNECT ENSURE GROUND CONTINUITY WHERE THROUGHOUT PREMISES DANGEROUS AND HAZARDOUS	SEQ #: 013□	1321	S	KARLOV	AVE	24	Open
02/16/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	OPEN WIRING AT HANGING RECEPTACLE 3RD FLOOR REAR HALL REMOVE WHERE REQUIRED DANGEROUS AND HAZARDOUS	SEQ #: 015□	1321	S	KARLOV	AVE	24	Open
01/20/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	MAIN DISCONNECTS/PANELS APPEAR SOMEWHAT CORRODED NO COMMON METER ENSURE SERVICE IN APPROVED CONDITION	SEQ #: 026□	3659	W	GRENSHAW	ST	24	Open
01/20/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	INSUFFICIENT WORKING SPACE PANELS DANGEROUS AND HAZARDOUS	SEQ #: 029□	3659	W	GRENSHAW	ST	24	Open
01/20/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	NO VISIBLE WATER GROUND ENSURE SERVICE GROUNDED IN APPROVED MANNER DANGEROUS AND HAZARDOUS	SEQ #: 028□	3659	W	GRENSHAW	ST	24	Open
01/20/2023	EL1822	EXPOSED WIRING FIXTURES	Remove exposed wiring at light fixture. (14E-4-410.48)	OPEN WIRE AT LIGHT FIXTURES VARIOUS AREAS THROUGHOUT FIXTURES HANDING BY WIRES VARIOUS AREAS REPAIR WHERE REQUIRED DANGEROUS AND HAZARDOUS	SEQ #: 033□	3659	W	GRENSHAW	ST	24	Open
02/02/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	CABLES SHOWING DETERIORATION AT SERVICE HEAD,UNABLE TO VIEW CLEARLY MAIN SERVICE DISCONNECT AND METER ENCLOSURES LIVE FRONT ENSURE SERVICE IN APPROVED CONDITION DANGEROUS AND HAZARDOUS	SEQ #: 012□	434	W	WELLINGTON	AVE	44	Open
02/02/2023	EL1822	EXPOSED WIRING FIXTURES	Remove exposed wiring at light fixture. (14E-4-410.48)	LIGHT FIXTURE HANGING BY WIRE AT 1ST FRONT HALL AREA REMOVE WHERE REQUIRED DANGEROUS AND HAZARDOUS	SEQ #: 026□	434	W	WELLINGTON	AVE	44	Open
02/02/2023	EL1827	RESTORE EXIT AND EM	Restore exit and emergency lighting system and related equipment to working condition. (14E-7-700.6)	EMERGENCY LIGHTING SYSTEM UNAPPROVED, UNMAINTAINED INSUFFICIENT. INSUFFICIENT BATTERY LIGHTS VARIOUS DANGEROUS AND HAZARDOUS	SEQ #: 017□	434	W	WELLINGTON	AVE	44	Open

02/02/2023	EL1833	SECURE RACEWAY	Strap and secure raceway and armored cable. (14E-1-110.13(a))	RACEWAY FALLING FROM WALL AT BOILER ROOM SECURE WHERE REQUIRED THROUGHOUT DANGEROUS AND HAZARDOUS	SEQ #: 019□	434	W	WELLINGTON	AVE	44	Open
02/02/2023	EL1839	CORRODED CONDUIT & EQUIP	Replace rusted, deteriorated, or corroded conduit, cabinet, electrical box, or fitting. (14E-3-300.13, 14E-1-110.12(b))	SOME CORRODED RACEWAYS BOXES EQUIPMENT BOILER ROOM REPLACE IF/WHERE REQUIRED	SEQ #: 027□	434	W	WELLINGTON	AVE	44	Open
02/02/2023	EL1865	LIVE FRONT SWITCHBOARD	Replace defective live front service and distribution equipment with dead front. (14E-4-408.20)	DISTRIBUTION EQUIPMENT AT 1ST FLOOR ELECTRICAL ROOM NO QUALIFIED PERSONNEL ON PREMISES ROOM USED FOR RESIDENTIAL BICYCLE STORAGE DANGEROUS AND HAZARDOUS	SEQ #: 013□	434	W	WELLINGTON	AVE	44	Open
03/17/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	EAST TENANT SPACE LOCATED IN LIQUOR STORE DAMAGED METER ENCLOSURE AT REAR EXTERIOR CORRODED MULTI-RACEWAY SERVICE HEAD OVERHEAD SERVICE SPLICES APPEAR DETERIORATING MULTIPLE SERVICES WITH NON GROUPED DISCONNECTS ENSURE SERVICES IN APPROVED CONDITION THROUGHOUT	SEQ #: 031□	7500	S	EXCHANGE	AVE	07	Open
03/17/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	7500 ELECTRICAL SERVICE RISER MISSING SUPPORTS METER ENCLOSURE PAINTED AND POSSIBLY DAMAGED ENSURE SERVICE IN APPROVED CONDITION	SEQ #: 005□	7500	S	EXCHANGE	AVE	07	Open
03/17/2023	EL1804	DEFECTIVE FEEDER	Replace defective feeder. (14E-2-215)	ENSURE FEEDER IN APPROVED CONDITION THROUFGOUT	SEQ #: 008□	7500	S	EXCHANGE	AVE	07	Open
03/17/2023	EL1805	DEFECTIVE DISTRIBUTION	4-408.30, 14E-4-408.36, 14E-4-408.37, 14E-4-408.38, 14E-4-408.39, 14E-4-408.40, 14E-4-408.41)	7500 CIRCUIT BREAKERS COVERED WITH CRUD REAR PANEL ENSURE DISTRIBUTION THROUGHOUT IN APPROVED CONDITION	SEQ #: 007□	7500	S	EXCHANGE	AVE	07	Open
03/17/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	7500 NO VISIBLE WATER GROUND ENSURE SERVICE GROUNDED IN APPROVED MANNER DANGEROUS AND HAZARDOUS	SEQ #: 006□	7500	S	EXCHANGE	AVE	07	Open
03/17/2023	EL1817	CONTINUITY OF RACEWAYS	Provide ground continuity for electrical cable, raceway, and enclosure. (14E-3-300.10, 14E-3-300.13)	LOOSE FITTINGS, UNATTACHED RACEWAYS BROKEN FLEXIBLE CONDUIT VARIOUS AREAS EXTERIOR AND REAR INTERIOR ENSURE GROUND CONTINUITY WHERE REQUIRED THROUGHOUT PREMISES DANGEROUS AND HAZARDOUS	SEQ #: 015□	7500	S	EXCHANGE	AVE	07	Open
03/17/2023	EL1822	EXPOSED WIRING FIXTURES	Remove exposed wiring at light fixture. (14E-4-410.48)	7500 OPEN WIRING AT LIGHT FIXTURES AT COOLER DOORS REMOVE WHERE REQUIRED	SEQ #: 016□	7500	S	EXCHANGE	AVE	07	Open
03/17/2023	EL1827	RESTORE EXIT AND EM	Restore exit and emergency lighting system and related equipment to working condition. (14E-7-700.6)	UNMAINTAINED, NOT MOUNTED IN APPROVED MANNER, UNABLE TO TEXT DANGEROUS AND HAZARDOUS	SEQ #: 018□	7500	S	EXCHANGE	AVE	07	Open
03/17/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	7500 OPEN WIRING REAR STORAGE AREA REMOVE WHERE REQUIRED THROUGHOUT PREMISES DANGEROUS AND HAZARDOUS	SEQ #: 012□	7500	S	EXCHANGE	AVE	07	Open
03/17/2023	EL1833	SECURE RACEWAY	Strap and secure raceway and armored cable. (14E-1-110.13(a))	7500,04-12,21-31 UNSUPPORTED RACEWAYS VARIOUS AREAS EXTERIOR	SEQ #: 034□	7500	S	EXCHANGE	AVE	07	Open
03/17/2023	EL1833	SECURE RACEWAY	Strap and secure raceway and armored cable. (14E-1-110.13(a))	7500 UNSUPPORTED RACEWAYS VARIOUS AREAS SECURE IN APPROVED MANNER WHERE REQUIRED THROUGHOUT PREMISES	SEQ #: 019□	7500	S	EXCHANGE	AVE	07	Open
03/22/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	CABLES DETERIORATED SERVICE RACEWAY HAS HEAD BROKEN/MISSING ENSURE SERVICE IN APPROVED CONDITION DANGEROUS AND HAZARDOUS	SEQ #: 024□	1701	W	79TH	ST	17	Open
03/22/2023	EL1813	PROPER SIZE OCP	Install proper size over-current device for feeder, branch circuit, and equipment. (14E-2-240.2, 14E-2-240.3, 14E-2-240.4)	7901-05 INSTALL GFCI PROTECTION NORTH BASEMENT, KITCHEN,BATH,EXTERIOR	SEQ #: 031□	1701	W	79TH	ST	17	Open

03/22/2023	EL1817	CONTINUITY OF RACEWAYS	Provide ground continuity for electrical cable, raceway, and enclosure. (14E-3-300.10, 14E-3-300.13)	7901-05 OPEN AIR SPLICES BETWEEN FLEXIBLE METAL CONDUIT NORTH BASEMENT ENSURE GROUND CONTINUITY WHERE REQUIRED NO EQUIPMENT GROUND VISIBLE AT REFRIGERATION DISCONNECT BASEMENT DANGEROUS AND HAZARDOUS	SEQ #: 033	1701	W	79TH	ST	17	Open
03/22/2023	EL1817	CONTINUITY OF RACEWAYS	Provide ground continuity for electrical cable, raceway, and enclosure. (14E-3-300.10, 14E-3-300.13)	7901 MISSING EQUIPMENT GROUND REFRIGERATION DISCONNECT BASEMENT DANGEROUS AND HAZARDOUS	SEQ #: 022	1701	W	79TH	ST	17	Open
03/22/2023	EL1827	RESTORE EXIT AND EM	Restore exit and emergency lighting system and related equipment to working condition. (14E-7-700.6)	7901-05 NO EMERGENCY LIGHTING SYSTEM AT NORTH BASEMENT INSTALL WHERE REQUIRED DANGEROUS AND HAZARDOUS	SEQ #: 029	1701	W	79TH	ST	17	Open
03/22/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	7901-05 OPEN WIRE NORTH BASEMENT AND FRONT EXTERIOR REMOVE WHERE REQUIRED DANGEROUS AND HAZARDOUS	SEQ #: 027	1701	W	79TH	ST	17	Open
03/22/2023	EL1833	SECURE RACEWAY	Strap and secure raceway and armored cable. (14E-1-110.13(a))	BASEMENT AND WEST EXTERIOR SECURE WHERE REQUIRED	SEQ #: 034	1701	W	79TH	ST	17	Open
03/22/2023	EL1880	DETERIORATED CONDUCTORS	Replace conductors with damaged or deteriorated insulation.(14E-1-110.7)	VISIBLE AT NORTH BASEMENT REPLACE WHERE REQUIRED	SEQ #: 038	1701	W	79TH	ST	17	Open
03/22/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	ABANDONED SERVICE RACEWAY AT REAR EXTERIOR IS UNSUPPORTED, NO DISTRIBUTION PANEL, UNSURE IF MAIN DISCONNECT IS OPERABLE, EXTERIOR SPLICES APPEAR DAMAGED AND OVERHEAD EXTERIOR CABLES ARE NOT AT APPROVED HEIGHT FROM GROUND DAMAGED EYE PLATE ENSURE SERVICE IN APPROVED CONDITION DANGEROUS AND HAZARDOUS	SEQ #: 017	1653	W	79TH	ST	17	Open
03/22/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	UNAPPROVED CAGE AROUND METER ENCLOSURE OVERHEAD SPLICES APPEAR DAMAGED OVERHEAD EXTERIOR CABLES ARE NOT AT APPROVED HEIGHT MAIN DISCONNECT/PANEL HAS NUMEROUS MISSING KO FILLERS AND MISSING CIRCUIT BREAKERS PANEL COVER IS LOOSE POSSIBLY DAMAGED APPEARS DIFFERENT MANUFACTURER OF CIRCUIT BREAKERS INSTALLED IN PANEL DAMAGED EYE PLATE METER ENCLOSURE BLOCKED BY COVER ENSURE SERVICE IN APPROVED CONDITION DANGEROUS AND	SEQ #: 018	1653	W	79TH	ST	17	Open
03/22/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	NO VISIBLE WATER GROUNDS ENSURE SERVICES GROUNDED IN APPROVED MANNER DANGEROUS AND HAZARDOUS	SEQ #: 019	1653	W	79TH	ST	17	Open
03/22/2023	EL1827	RESTORE EXIT AND EM	Restore exit and emergency lighting system and related equipment to working condition. (14E-7-700.6)	EMERGENCY LIGHTING SYSTEM INSUFFICIENT, UNMAINTAINED AND UNABLE TO TEST DANGEROUS AND HAZARDOUS	SEQ #: 029	1653	W	79TH	ST	17	Open
03/20/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	OVERHEAD SERVICE SPLICES APPEAR DETERIORATED LOW VOLTAGE CABLES IN CONTACT WITH OVERHEAD SERVICE CABLES ENSURE SERVICE IN APPROVED CONDITION DANGEROUS AND HAZARDOUS	SEQ #: 003	1637	W	89TH	ST	18	Open
03/21/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	DETERIORATING AND ARE PARTIALLY UNINSULATED SERVICE MOGUL DETERIORATED AND DAMAGED SERVICE RISER MISSING SUPPORTS ENSURE SERVICE IN APPROVED CONDITION DANGEROUS AND HAZARDOUS	SEQ #: 004	3457	N	RIDGEWAY	AVE	30	Open

03/21/2023	EL1839	CORRODED CONDUIT & EQUIP	Replace rusted, deteriorated, or corroded conduit, cabinet, electrical box, or fitting. (14E-3-300.13, 14E-1-110.12(b))	CORRODED RACEWAYS REAR EXTERIOR REPLACE WHERE REQUIRED	SEQ #: 007□	3457	N	RIDGEWAY	AVE	30	Open
03/28/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	HAS TELEVISION ANTENNA ATTACHED AT TOP ALONG WITH NUMEROUS UNAPPROVED ITEMS WOODEN ELECTRICAL SERVICE MAST HAS DAMAGED SUPPORTS RUSTED SERVICE RISER SUPPORTS DETERIORATED SERVICE CABLES ENSURE SERVICES THROUGHOUT IN APPROVED CONDITION DANGEROUS AND HAZARDOUS	SEQ #: 010□	5157	W	LAKE	ST	28	Open
03/28/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	HAS TELEVISION ANTENNA ATTACHED AT TOP ALONG WITH NUMEROUS UNAPPROVED ITEMS WOODEN ELECTRICAL SERVICE MAST HAS DAMAGED SUPPORTS RUSTED SERVICE RISER SUPPORTS DETERIORATED SERVICE CABLES ENSURE SERVICES THROUGHOUT IN APPROVED CONDITION DANGEROUS AND HAZARDOUS	SEQ #: 020□	5157	W	LAKE	ST	28	Open
03/28/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	HAS TELEVISION ANTENNA ATTACHED AT TOP ALONG WITH NUMEROUS UNAPPROVED ITEMS WOODEN ELECTRICAL SERVICE MAST HAS DAMAGED SUPPORTS RUSTED SERVICE RISER SUPPORTS DETERIORATED SERVICE CABLES ENSURE SERVICES THROUGHOUT IN APPROVED CONDITION DANGEROUS AND HAZARDOUS	SEQ #: 032□	5157	W	LAKE	ST	28	Open
03/28/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	53 SERVICE CABLES APPEAR DETERIORATED, DAMAGED AT DRIP LOOP ENSURE SERVICE IN APPROVED CONDITION	SEQ #: 009□	5157	W	LAKE	ST	28	Open
03/28/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	53 SERVICE CABLES APPEAR DETERIORATED, DAMAGED AT DRIP LOOP ENSURE SERVICE IN APPROVED CONDITION	SEQ #: 019□	5157	W	LAKE	ST	28	Open
03/28/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	53 SERVICE CABLES APPEAR DETERIORATED, DAMAGED AT DRIP LOOP ENSURE SERVICE IN APPROVED CONDITION	SEQ #: 031□	5157	W	LAKE	ST	28	Open
03/28/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	COVER ENSURE SERVICE IN APPROVED CONDITION	SEQ #: 002□	5157	W	LAKE	ST	28	Open
03/28/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	COVER ENSURE SERVICE IN APPROVED CONDITION	SEQ #: 012□	5157	W	LAKE	ST	28	Open
03/28/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	COVER ENSURE SERVICE IN APPROVED CONDITION	SEQ #: 024□	5157	W	LAKE	ST	28	Open
03/28/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	55 NO VISIBLE WATER GROUND ENSURE SERVICE GROUNDED IN APPROVED MANNER DANGEROUS AND HAZARDOUS	SEQ #: 003□	5157	W	LAKE	ST	28	Open
03/28/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	55 NO VISIBLE WATER GROUND ENSURE SERVICE GROUNDED IN APPROVED MANNER DANGEROUS AND HAZARDOUS	SEQ #: 013□	5157	W	LAKE	ST	28	Open
03/28/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	55 NO VISIBLE WATER GROUND ENSURE SERVICE GROUNDED IN APPROVED MANNER DANGEROUS AND HAZARDOUS	SEQ #: 025□	5157	W	LAKE	ST	28	Open
03/28/2023	EL1817	CONTINUITY OF RACEWAYS	Provide ground continuity for electrical cable, raceway, and enclosure. (14E-3-300.10, 14E-3-300.13)	55 CONDUIT AT FRONT INTERIOR CEILING AREA COMING APART AT FITTING ENSURE GROUND CONTINUITY WHERE REQUIRED DANGEROUS AND HAZARDOUS	SEQ #: 006□	5157	W	LAKE	ST	28	Open

03/28/2023	EL1817	CONTINUITY OF RACEWAYS	Provide ground continuity for electrical cable, raceway, and enclosure. (14E-3-300.10, 14E-3-300.13)	55 CONDUIT AT FRONT INTERIOR CEILING AREA COMING APART AT FITTING ENSURE GROUND CONTINUITY WHERE REQUIRED DANGEROUS AND HAZARDOUS	SEQ #: 016□	5157	W	LAKE	ST	28	Open
03/28/2023	EL1817	CONTINUITY OF RACEWAYS	Provide ground continuity for electrical cable, raceway, and enclosure. (14E-3-300.10, 14E-3-300.13)	55 CONDUIT AT FRONT INTERIOR CEILING AREA COMING APART AT FITTING ENSURE GROUND CONTINUITY WHERE REQUIRED DANGEROUS AND HAZARDOUS	SEQ #: 028□	5157	W	LAKE	ST	28	Open
03/28/2023	EL1827	RESTORE EXIT AND EM	and related equipment to working condition. (14E-7-700.6)	55 EMERGENCY LIGHTING SYSTEM NOT WIRED CORRECTLY DANGEROUS AND HAZARDOUS	SEQ #: 005□	5157	W	LAKE	ST	28	Open
03/28/2023	EL1827	RESTORE EXIT AND EM	and related equipment to working condition. (14E-7-700.6)	55 EMERGENCY LIGHTING SYSTEM NOT WIRED CORRECTLY DANGEROUS AND HAZARDOUS	SEQ #: 015□	5157	W	LAKE	ST	28	Open
03/28/2023	EL1827	RESTORE EXIT AND EM	and related equipment to working condition. (14E-7-700.6)	55 EMERGENCY LIGHTING SYSTEM NOT WIRED CORRECTLY DANGEROUS AND HAZARDOUS	SEQ #: 027□	5157	W	LAKE	ST	28	Open
03/21/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	SPLICES AT OVERHEAD UTILITY APPEAR TO BE DETERIORATING MAIN DISCONNECTS/PANELS AT BASEMENT OPEN VANDALIZED AND DAMAGED DETERIORATED METER ENCLOSURES ENSURE SERVICE IN APPROVED CONDITION DANGEROUS AND HAZARDOUS	SEQ #: 001□	1541	S	ST LOUIS	AVE	24	Open
03/21/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	SPLICES AT OVERHEAD UTILITY APPEAR TO BE DETERIORATING MAIN DISCONNECTS/PANELS AT BASEMENT OPEN VANDALIZED AND DAMAGED DETERIORATED METER ENCLOSURES ENSURE SERVICE IN APPROVED CONDITION DANGEROUS AND HAZARDOUS	SEQ #: 020□	1541	S	ST LOUIS	AVE	24	Open
03/21/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	NO VISIBLE WATER GROUND ENSURE SERVICE GROUNDED IN APPROVED MANNER DANGEROUS AND HAZARDOUS	SEQ #: 003□	1541	S	ST LOUIS	AVE	24	Open
03/21/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	NO VISIBLE WATER GROUND ENSURE SERVICE GROUNDED IN APPROVED MANNER DANGEROUS AND HAZARDOUS	SEQ #: 022□	1541	S	ST LOUIS	AVE	24	Open
03/21/2023	EL1817	CONTINUITY OF RACEWAYS	Provide ground continuity for electrical cable, raceway, and enclosure. (14E-3-300.10, 14E-3-300.13)	RACEWAYS NOT ATTACHED TO BOXES, LOOSE FITTINGS BASEMENT ENSURE GROUND CONTINUITY THROUGHOUT PREMISES DANGEROUS AND HAZARDOUS	SEQ #: 018□	1541	S	ST LOUIS	AVE	24	Open
03/21/2023	EL1817	CONTINUITY OF RACEWAYS	Provide ground continuity for electrical cable, raceway, and enclosure. (14E-3-300.10, 14E-3-300.13)	RACEWAYS NOT ATTACHED TO BOXES, LOOSE FITTINGS BASEMENT ENSURE GROUND CONTINUITY THROUGHOUT PREMISES DANGEROUS AND HAZARDOUS	SEQ #: 037□	1541	S	ST LOUIS	AVE	24	Open
03/21/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	OPEN WIRING 1ST FLOOR APARTMENT FURNACE ROOM OPEN WIRING THROUGHOUT BASEMENT REMOVE WHERE REQUIRED DANGEROUS AND HAZARDOUS	SEQ #: 005□	1541	S	ST LOUIS	AVE	24	Open
03/21/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	OPEN WIRING 1ST FLOOR APARTMENT FURNACE ROOM OPEN WIRING THROUGHOUT BASEMENT REMOVE WHERE REQUIRED DANGEROUS AND HAZARDOUS	SEQ #: 024□	1541	S	ST LOUIS	AVE	24	Open
03/21/2023	EL1833	SECURE RACEWAY	Strap and secure raceway and armored cable. (14E-1-110.13(a))	UNSUPPORTED FAILING RACEWAYS THROUGHOUT BASEMENT SECURE WHERE REQUIRED THROUGHOUT PREMISES DANGEROUS AND HAZARDOUS	SEQ #: 016□	1541	S	ST LOUIS	AVE	24	Open
03/21/2023	EL1833	SECURE RACEWAY	Strap and secure raceway and armored cable. (14E-1-110.13(a))	UNSUPPORTED FAILING RACEWAYS THROUGHOUT BASEMENT SECURE WHERE REQUIRED THROUGHOUT PREMISES DANGEROUS AND HAZARDOUS	SEQ #: 035□	1541	S	ST LOUIS	AVE	24	Open

03/21/2023	EL1839	CORRODED CONDUIT & EQUIP	Replace rusted, deteriorated, or corroded conduit, cabinet, electrical box, or fitting. (14E-3-300.13, 14E-1-110.12(b))	CORRODED BOXES, RACEWAYS EQUIPMENT AT REAR EXTERIOR AND THROUGHOUT BASEMENT REPLACE WHERE REQUIRED	SEQ #: 015□	1541	S	ST LOUIS	AVE	24	Open
03/21/2023	EL1839	CORRODED CONDUIT & EQUIP	Replace rusted, deteriorated, or corroded conduit, cabinet, electrical box, or fitting. (14E-3-300.13, 14E-1-110.12(b))	CORRODED BOXES, RACEWAYS EQUIPMENT AT REAR EXTERIOR AND THROUGHOUT BASEMENT REPLACE WHERE REQUIRED	SEQ #: 034□	1541	S	ST LOUIS	AVE	24	Open
03/21/2023	EL1880	DETERIORATED CONDUCTORS	Replace conductors with damaged or deteriorated insulation.(14E-1-110.7)	DETERIORATED CLOTH WIRING AND DAMAGED WIRING VISIBLE AT OPEN BOXES AND JUNCTION BOXES AT 1ST FLOOR AND THROUGHOUT BASEMENT REPLACE WHERE REQUIRED DANGEROUS AND HAZARDOUS	SEQ #: 009□	1541	S	ST LOUIS	AVE	24	Open
03/21/2023	EL1880	DETERIORATED CONDUCTORS	Replace conductors with damaged or deteriorated insulation.(14E-1-110.7)	DETERIORATED CLOTH WIRING AND DAMAGED WIRING VISIBLE AT OPEN BOXES AND JUNCTION BOXES AT 1ST FLOOR AND THROUGHOUT BASEMENT REPLACE WHERE REQUIRED DANGEROUS AND HAZARDOUS	SEQ #: 028□	1541	S	ST LOUIS	AVE	24	Open
03/17/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	47-55 OPEN MOGULS MISSING METERS OPEN METERS INSUFFICIENT RISER SUPPORT DETERIORATED, UNINSULATED SERVICE SPLICES ENSURE SERVICES IN APPROVED CONDITION THROUGHOUT PREMISES DANGEROUS AND HAZARDOUS	SEQ #: 027□	47	W	79TH	ST	17	Open
03/17/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	47 OPEN DAMAGED SERVICE MOGUL AT REAR EXTERIOR MISSING PANEL FILLER AT AMIN PANEL ENSURE SERVICE IN APPROVED CONDITION DANGEROUS AND HAZARDOUS	SEQ #: 011□	47	W	79TH	ST	17	Open
03/17/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	47 NO VISIBLE WATER GROUND ENSURE SERVICE IN APPROVED CONDITION DANGEROUS AND HAZARDOUS +	SEQ #: 012□	47	W	79TH	ST	17	Open
03/17/2023	EL1817	CONTINUITY OF RACEWAYS	Provide ground continuity for electrical cable, raceway, and enclosure. (14E-3-300.10, 14E-3-300.13)	47 CONDUIT PULLED AWAY FROM BOX AT SIDE EXTERIOR LIQUID TIGHT FLEXIBLE METAL CONDUIT FITTING ATTACHED TO GRILL AT INTERIOR PART OF COOLER ENSURE GROUND CONTINUITY WHERE REQUIRED THROUGHOUT PREMISES DANGEROUS AND HAZARDOUS	SEQ #: 019□	47	W	79TH	ST	17	Open
03/17/2023	EL1827	RESTORE EXIT AND EM	and related equipment to working condition. (14E-7-700.6)	47 UNABLE TO PROPERLY TEST EMERGENCY LIGHTING SYSTEM	SEQ #: 023□	47	W	79TH	ST	17	Open
03/30/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	RACEWAY, RACEWAY SUPPORTS DETERIORATING OVERHEAD SPLICES DAMAGED WOODEN SERVICE MAST SUPPORTS APPEAR TO BE DETERIORATING MAIN DISCONNECT APPEARS TO BE ABANDONED ENSURE SERVICE IN APPROVED CONDITION DANGEROUS AND HAZARDOUS	SEQ #: 010□	4427	N	ELSTON	AVE	39	Open
03/30/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	RACEWAY, RACEWAY SUPPORTS DETERIORATING OVERHEAD SPLICES DAMAGED WOODEN SERVICE MAST SUPPORTS APPEAR TO BE DETERIORATING MAIN DISCONNECT APPEARS TO BE ABANDONED ENSURE SERVICE IN APPROVED CONDITION DANGEROUS AND HAZARDOUS	SEQ #: 029□	4427	N	ELSTON	AVE	39	Open
03/30/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	THREE PHASE SERVICE-EXTERIOR SERVICE RACEWAY SUPPORTS DETERIORATING SERVICE CABLES DETERIORATED AT SERVICE HEAD OVERHEAD SERVICE SPLICES DAMAGED OPEN DETERIORATED LIVE FRONT C/T CABINET ENSURE SERVICE IN APPROVED CONDITION DANGEROUS AND HAZARDOUS	SEQ #: 011□	4427	N	ELSTON	AVE	39	Open

03/30/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	THREE PHASE SERVICE-EXTERIOR SERVICE RACEWAY SUPPORTS DETERIORATING SERVICE CABLES DETERIORATED AT SERVICE HEAD OVERHEAD SERVICE SPLICES DAMAGED OPEN DETERIORATED LIVE FRONT C/T CABINET ENSURE SERVICE IN APPROVED CONDITION DANGEROUS AND HAZARDOUS	SEQ #: 030	4427	N	ELSTON	AVE	39	Open
03/30/2023	EL1805	DEFECTIVE DISTRIBUTION	4-408.30, 14E-4-408.36, 14E-4-408.37, 14E-4-408.38, 14E-4-408.39, 14E-4-408.40, 14E-4-408.41)	ENSURE DISTRIBUTION THROUGHOUT IN APPROVED CONDITION DANGEROUS AND HAZARDOUS	SEQ #: 014	4427	N	ELSTON	AVE	39	Open
03/30/2023	EL1805	DEFECTIVE DISTRIBUTION	4-408.30, 14E-4-408.36, 14E-4-408.37, 14E-4-408.38, 14E-4-408.39, 14E-4-408.40, 14E-4-408.41)	ENSURE DISTRIBUTION THROUGHOUT IN APPROVED CONDITION DANGEROUS AND HAZARDOUS	SEQ #: 033	4427	N	ELSTON	AVE	39	Open
03/30/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	NO VISIBLE WATER GROUNDS ENSURE SERVICE IN APPROVED CONDITION DANGEROUS AND HAZARDOUS	SEQ #: 012	4427	N	ELSTON	AVE	39	Open
03/30/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	NO VISIBLE WATER GROUNDS ENSURE SERVICE IN APPROVED CONDITION DANGEROUS AND HAZARDOUS	SEQ #: 031	4427	N	ELSTON	AVE	39	Open
03/30/2023	EL1817	CONTINUITY OF RACEWAYS	Provide ground continuity for electrical cable, raceway, and enclosure. (14E-3-300.10, 14E-3-300.13)	FLEXIBLE METAL CONDUIT NOT CONNECTED TO BOXES OR FIXTURES VARIOUS AREAS EMT WITH LOOSE FITTINGS ENSURE GROUND CONTINUITY WHERE REQUIRED THROUGHOUT PREMISES DANGEROUS AND HAZARDOUS	SEQ #: 016	4427	N	ELSTON	AVE	39	Open
03/30/2023	EL1817	CONTINUITY OF RACEWAYS	Provide ground continuity for electrical cable, raceway, and enclosure. (14E-3-300.10, 14E-3-300.13)	FLEXIBLE METAL CONDUIT NOT CONNECTED TO BOXES OR FIXTURES VARIOUS AREAS EMT WITH LOOSE FITTINGS ENSURE GROUND CONTINUITY WHERE REQUIRED THROUGHOUT PREMISES DANGEROUS AND HAZARDOUS	SEQ #: 035	4427	N	ELSTON	AVE	39	Open
03/30/2023	EL1822	EXPOSED WIRING FIXTURES	Remove exposed wiring at light fixture. (14E-4-410.48)	OPEN WIRING AT LIGHT FIXTURES VARIOUS AREAS REMOVE WHERE REQUIRED DANGEROUS AND HAZARDOUS	SEQ #: 016	4427	N	ELSTON	AVE	39	Open
03/30/2023	EL1822	EXPOSED WIRING FIXTURES	Remove exposed wiring at light fixture. (14E-4-410.48)	OPEN WIRING AT LIGHT FIXTURES VARIOUS AREAS REMOVE WHERE REQUIRED DANGEROUS AND HAZARDOUS	SEQ #: 038	4427	N	ELSTON	AVE	39	Open
03/30/2023	EL1827	RESTORE EXIT AND EM	and related equipment to working condition. (14E-7-700.6)	EMERGENCY LIGHTING SYSTEM NOT OPERABLE UNABLE TO TEST	SEQ #: 019	4427	N	ELSTON	AVE	39	Open
03/30/2023	EL1827	RESTORE EXIT AND EM	and related equipment to working condition. (14E-7-700.6)	EMERGENCY LIGHTING SYSTEM NOT OPERABLE UNABLE TO TEST	SEQ #: 041	4427	N	ELSTON	AVE	39	Open
03/30/2023	EL1833	SECURE RACEWAY	Strap and secure raceway and armored cable. (14E-1-110.13(a))	UNSUPPORTED FALLING RACEWAYS VARIOUS AREAS SECURE WHERE REQUIRED DANGEROUS AND HAZARDOUS	SEQ #: 001	4427	N	ELSTON	AVE	39	Open
03/30/2023	EL1833	SECURE RACEWAY	Strap and secure raceway and armored cable. (14E-1-110.13(a))	UNSUPPORTED FALLING RACEWAYS VARIOUS AREAS SECURE WHERE REQUIRED DANGEROUS AND HAZARDOUS	SEQ #: 020	4427	N	ELSTON	AVE	39	Open
03/30/2023	EL1839	CORRODED CONDUIT & EQUIP	Replace rusted, deteriorated, or corroded conduit, cabinet, electrical box, or fitting. (14E-3-300.13, 14E-1-110.12(b))	CORRODED SIGN STRUCTURES FRONT EXTERIOR REMOVE WHERE REQUIRED	SEQ #: 007	4427	N	ELSTON	AVE	39	Open
03/30/2023	EL1839	CORRODED CONDUIT & EQUIP	Replace rusted, deteriorated, or corroded conduit, cabinet, electrical box, or fitting. (14E-3-300.13, 14E-1-110.12(b))	CORRODED SIGN STRUCTURES FRONT EXTERIOR REMOVE WHERE REQUIRED	SEQ #: 026	4427	N	ELSTON	AVE	39	Open
03/17/2023	EL1817	CONTINUITY OF RACEWAYS	Provide ground continuity for electrical cable, raceway, and enclosure. (14E-3-300.10, 14E-3-300.13)	PULLED AWAY FROM EXTERIOR VACUMN CLEANER WITH NO VISIBLE EQUIPMENT GROUND ENSURE GROUND CONTINUITY WHERE REQUIRED THROUGHOUT PREMISES DANGEROUS AND HAZARDOUS	SEQ #: 007	7900	S	LAFAYETTE	AVE	17	Open
03/17/2023	EL1827	RESTORE EXIT AND EM	and related equipment to working condition. (14E-7-700.6)	SUPPORT EXIT SIGN AT FRONT DOOR IN APPROVED MANNER	SEQ #: 011	7900	S	LAFAYETTE	AVE	17	Open

03/17/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	EXPOSED WIRING AT EXTERIOR VACUUM CLEANER REMOVE WHERE REQUIRED DANGEROUS AND HAZARDOUS	SEQ #: 008□	7900	S	LAFAYETTE	AVE	17	Open
03/17/2023	EL1833	SECURE RACEWAY	Strap and secure raceway and armored cable. (14E-1-110.13(a))	UNSUPPORTED RACEWAYS AT REAR EXTERIOR SECURE WHERE REQUIRED	SEQ #: 012□	7900	S	LAFAYETTE	AVE	17	Open
03/31/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	METER ENCLOSURE SIGNIFICANTLY RUSTED NO VISIBLY MARKED MAIN DISCONNECTS 480 VOLT SERVICE OVER 1200 AMPS DEDICATED ELECTRICAL ROOM FULL OF CLUTTER DEBRIS STORAGE ENSURE SERVICE IN APPROVED CONDITION DANGEROUS AND HAZARDOUS	SEQ #: 026□	11901	S	LOOMIS	ST	21	Open
03/31/2023	EL1805	DEFECTIVE DISTRIBUTION	Replace defective distribution equipment. (14E-4-408.30, 14E-4-408.36, 14E-4-408.37, 14E-4-408.38, 14E-4-408.39, 14E-4-408.40, 14E-4-408.41))	MISSING CIRCUIT BREAKERS ENSURE DISTRIBUTION IN APPROVED CONDITION THROUGHOUT PREMISES DANGEROUS AND HAZARDOUS	SEQ #: 028□	11901	S	LOOMIS	ST	21	Open
03/31/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	NO VISIBLE WATER GROUND ENSURE SERVICE GROUNDED IN APPROVED MANNER DANGEROUS AND HAZARDOUS	SEQ #: 027□	11901	S	LOOMIS	ST	21	Open
03/31/2023	EL1817	CONTINUITY OF RACEWAYS	Provide ground continuity for electrical cable, raceway, and enclosure. (14E-3-300.10, 14E-3-300.13)	MECHANICAL AREA EXTERIOR ENSURE GROUND CONTINUITY WHERE REQUIRED DANGEROUS AND HAZARDOUS	SEQ #: 022□	11901	S	LOOMIS	ST	21	Open
03/31/2023	EL1827	RESTORE EXIT AND EM	Restore exit and emergency lighting system and related equipment to working condition. (14E-7-700.6)	MAINTAINED, VARIOUS UNITS INOPERABLE, UNABLE TO TEST ENSURE REQUIRED EMERGENCY SYSTEM IN OPERABLE CONDITION TYPE OF SYSTEM DEPENDENT ON PLACE OF ASSEMBLY OCCUPANCY DANGEROUS AND HAZARDOUS	SEQ #: 035□	11901	S	LOOMIS	ST	21	Open
03/31/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	OPEN WIRING REAR SOUND ROOM, EXTERIOR, DROP CEILING REMOVE WHERE REQUIRED DANGEROUS AND HAZARDOUS	SEQ #: 033□	11901	S	LOOMIS	ST	21	Open
03/31/2023	EL1839	CORRODED CONDUIT & EQUIP	Replace rusted, deteriorated, or corroded conduit, cabinet, electrical box, or fitting. (14E-3-300.13, 14E-1-110.12(b))	CORRODED DISCONNECTS KITCHEN AREA REPLACE CORRODED EQUIPMENT WHERE REQUIRED	SEQ #: 025□	11901	S	LOOMIS	ST	21	Open
04/06/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	14A-4-404.6 OBTAIN ELECTRICAL PERMIT AND CONTRACTOR DEFECTIVE SERVICE REPLACE DEFECTIVE SERVICE D&H	SEQ #: 030□	3038	W	MONTROSE	AVE	33	Open
04/06/2023	EL1803	DEFECTIVE METER EQUIPMENT	Replace defective meter socket. (14E-2-230.62, 14E-2-230.66, 14E-3-312.5)	DEFECTIVE METER SOCKET HELD BY COM ED LOCK D&H	SEQ #: 032□	3038	W	MONTROSE	AVE	33	Open
04/06/2023	EL1804	DEFECTIVE FEEDER	Replace defective feeder. (14E-2-215)	DEFECTIVE FEEDER REPLACE DEFECTIVE FEEDER D&H	SEQ #: 033□	3038	W	MONTROSE	AVE	33	Open
04/06/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	CONDUCTOR SERVICE NOT GROUNDED NO GRD ROD COULD NOT LOCATED COLD WATER GROUND TO CITY D&H	SEQ #: 034□	3038	W	MONTROSE	AVE	33	Open
04/06/2023	EL1822	EXPOSED WIRING FIXTURES	Remove exposed wiring at light fixture. (14E-4-410.48)	REMOVE EXPOSED WIRING AT FIXTURE	SEQ #: 040□	3038	W	MONTROSE	AVE	33	Open
04/06/2023	EL1827	RESTORE EXIT AND EM	Restore exit and emergency lighting system and related equipment to working condition. (14E-7-700.6)	SYSTEMS TO WORKING CONDITIONS AND ENSURE THAT EXIT SIGNS ARE STEEL NOT (PLASTIC)	SEQ #: 041□	3038	W	MONTROSE	AVE	33	Open
04/06/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	EXPOSED WIRING REMOVE ALL EXPOSED WIRING THROUGH OUT BUILDING D&H	SEQ #: 042□	3038	W	MONTROSE	AVE	33	Open
04/06/2023	EL1880	DETERIORATED CONDUCTORS	Replace conductors with damaged or deteriorated insulation.(14E-1-110.7)	DETERIORATED CONDUCTORS FOR SERVICE	SEQ #: 038□	3038	W	MONTROSE	AVE	33	Open
04/13/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	DEFECTIVE SERVICE ALL PANELS IN BASEMENT LEFT OPEN NO COVERS DEEMED DANGEROUS AND HAZARDOUS	SEQ #: 027□	6134	S	MAY	ST	16	Open
04/13/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	INSTALL PROPER SIZE GROUNDING ELECTRODE	SEQ #: 028□	6134	S	MAY	ST	16	Open

04/13/2023	EL1807	BOND AROUND FITTINGS	Install bonding conductor across water meter, union, and similar fittings of cold water pipe used as grounding electrode. (14E-2-250.28)	INSTALL BONDING CONDUCTOR ACROSS WATER METER UNION AND SIMILAR FITTINGS	SEQ #: 029□	6134	S	MAY	ST	16	Open
04/13/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	EXPOSED WIRING REMOVE EXPOSED WIRING	SEQ #: 034□	6134	S	MAY	ST	16	Open
03/31/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	AT REAR EXTERIOR MISSING SUPPORTS SERVICE RISER NO COMMON METER MISSING CIRCUIT BREAKERS AT MAIN PANELS UNSUPPORTED SERVICE ENTRANCE CABLE ENSURE SERVICE IN APPROVED CONDITION DANGEROUS AND HAZARDOUS	SEQ #: 019□	5529	S	WOLCOTT	AVE	16	Open
03/31/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	NO VISIBLE WATER GROUND ENSURE SERVICE GROUNDED IN APPROVED MANNER DANGEROUS AND HAZARDOUS	SEQ #: 020□	5529	S	WOLCOTT	AVE	16	Open
03/21/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	SERVICE RISER RACEWAY HUB NOT SEATED AT METER ENCLOSURE	SEQ #: 004□	1456	N	CAMPBELL	AVE	01	Open
04/07/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	SERVICE RACEWAY, SUPPORTS AND CABLES DETERIORATED ENSURE SERVICE IN APPROVED CONDITION .	SEQ #: 003□	5301	W	GEORGE	ST	31	Open
04/07/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	TREE BRANCHES,.ENSURE SERVICE IN APPROVED CONDITION DANGEROUS AND HAZARDOUS	SEQ #: 003□	2604	N	SAWYER	AVE	35	Open
04/07/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	EMERGENCY SERVICE-OVERHEAD SERVICE SPLICES APPEAR DAMAGED/DETERIORATED RISER SUPPORTS APPEAR RUSTED ENSURE SERVICE IN APPROVED CONDITION	SEQ #: 007□	5201	W	SCHUBERT	AVE	31	Open
04/07/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	MAIN SERVICE-OVERHEAD SERVICE SPLICES COVERS APPEAR DAMAGED/DETERIORATED RISER SUPPORTS APPEAR RUSTED ENSURE SERVICE IN APPROVED CONDITION	SEQ #: 006□	5201	W	SCHUBERT	AVE	31	Open
04/07/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	EAST INTERIOR STAIRWELL REMOVE OPEN WIRING WHERE REQUIRED DANGEROUS AND HAZARDOUS	SEQ #: 009□	5201	W	SCHUBERT	AVE	31	Open
04/07/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	SERVICE HEAD SERVICE RISER APPEARS DETERIORATED OVERHEAD TEMPORARY SERVICE SPLICES WORN EXTERIOR SERVICE MODIFIED FROM ORIGINAL DETERIORATED EYE PLATE ENSURE SERVICE IN APPROVED CONDITION	SEQ #: 007□	2455	N	LARAMIE	AVE	31	Open
04/07/2023	EL1804	DEFECTIVE FEEDER	Replace defective feeder. (14E-2-215)	UNSUPPORTED FEEDER REAR EXTERIOR ENSURE FEEDERS IN APPROVED CONDITION DANGEROUS AND HAZARDOUS	SEQ #: 009□	2455	N	LARAMIE	AVE	31	Open
04/07/2023	EL1827	RESTORE EXIT AND EM	and related equipment to working condition. (14E-7-700.6)	STAIRS NOT MAINTAINED DANGEROUS AND HAZARDOUS	SEQ #: 014□	2455	N	LARAMIE	AVE	31	Open
04/07/2023	EL1833	SECURE RACEWAY	Strap and secure raceway and armored cable. (14E-1-110.13(a))	UNSUPPORTED HANGING RACEWAYS REAR EXTERIOR SECURE WHERE REQUIRED	SEQ #: 017□	2455	N	LARAMIE	AVE	31	Open
04/13/2023	EL1804	DEFECTIVE FEEDER	Replace defective feeder. (14E-2-215)	OBTAIN PERMIT FOR ELECTRIC WORK PERFORMED	SEQ #: 018□	9160	S	HAMILTON	AVE	19	Open
04/13/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	ELECTRODE NO GROUND ROD AT METER NO GEC AT CWP (COLD WATER PIPE) NO BOND FROM METER TO PANEL	SEQ #: 015□	9160	S	HAMILTON	AVE	19	Open
04/13/2023	EL1828	UNAPPROVED EM	from emergency lighting system. (14E-7-700.63)	EXPOSED WIRING BOXES IN BASEMENT NEED COVERS	SEQ #: 017□	9160	S	HAMILTON	AVE	19	Open
04/18/2023	EL1807	BOND AROUND FITTINGS	Install bonding conductor across water meter, union, and similar fittings of cold water pipe used as grounding electrode. (14E-2-250.28)		SEQ #: 009□	11339	S	WALLACE	ST	21	Open
04/18/2023	EL1817	CONTINUITY OF RACEWAYS	raceway, and enclosure. (14E-3-300.10, 14E-3-300.13)	Basement and panel	SEQ #: 007□	11339	S	WALLACE	ST	21	Open

04/18/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	Basement	SEQ #: 002☐	11339	S	WALLACE	ST	21	Open
04/18/2023	EL1857	SMOKE & CARBON DETECTORS	Install required smoke and carbon monoxide detectors. (14E-5-570.10(h)(i))		SEQ #: 004☐	11339	S	WALLACE	ST	21	Open
04/20/2023	EL1827	RESTORE EXIT AND EM	Restore exit and emergency lighting system and related equipment to working condition. (14E-7-700.6)	UNAPPROVED INOPERABLE EXIT SIGNS UNABLE TO TEST BATTERY LIGHTS DANGEROUS AND HAZARDOUS	SEQ #: 017☐	4527	N	SHERIDAN	RD	46	Open
04/20/2023	EL1827	RESTORE EXIT AND EM	Restore exit and emergency lighting system and related equipment to working condition. (14E-7-700.6)	UNAPPROVED INOPERABLE EXIT SIGNS UNABLE TO TEST BATTERY LIGHTS DANGEROUS AND HAZARDOUS	SEQ #: 018☐	4527	N	SHERIDAN	RD	46	Open
04/20/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	OPEN WIRING AT WINDOW LOW VOLTAGE LIGHTING TRANSFORMERS REMOVE WHERE REQUIRED DANGEROUS AND HAZARDOUS	SEQ #: 013☐	4527	N	SHERIDAN	RD	46	Open
04/20/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	OPEN WIRING AT WINDOW LOW VOLTAGE LIGHTING TRANSFORMERS REMOVE WHERE REQUIRED DANGEROUS AND HAZARDOUS	SEQ #: 015☐	4527	N	SHERIDAN	RD	46	Open
05/03/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)		SEQ #: 001☐	4527	N	SHERIDAN	RD	46	Open
05/03/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)		SEQ #: 003☐	4527	N	SHERIDAN	RD	46	Open
05/03/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)		SEQ #: 025☐	4527	N	SHERIDAN	RD	46	Open
05/03/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)		SEQ #: 027☐	4527	N	SHERIDAN	RD	46	Open
05/03/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)		SEQ #: 002☐	4527	N	SHERIDAN	RD	46	Open
05/03/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)		SEQ #: 026☐	4527	N	SHERIDAN	RD	46	Open
05/03/2023	EL1834	LISTED FOR USE TEMP & LOCATION	temperature and location.(14E-1-110.2(B), 14E-1-110.11)		SEQ #: 005☐	4527	N	SHERIDAN	RD	46	Open
05/03/2023	EL1834	LISTED FOR USE TEMP & LOCATION	temperature and location.(14E-1-110.2(B), 14E-1-110.11)		SEQ #: 029☐	4527	N	SHERIDAN	RD	46	Open
01/13/2023	EL1817	CONTINUITY OF RACEWAYS	Provide ground continuity for electrical cable, raceway, and enclosure. (14E-3-300.10, 14E-3-300.13)	ORDER TO INSURE A PROPER PATH TO GROUND FOR FAULT CURRENTS SPECIFICALLY ON THE WEST EXTERIOR ELEVATION AT THE REAR COACH HOUSE	SEQ #: 008☐	9330	S	LONGWOOD	DR	19	Open
05/23/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	MULTIPLE ELECTRICAL SERVICES: SERVICE CABLES AND RACEWAYS DETERIORATED. MAIN SERVICE DISCONNECT LOCATED IN BASEMENT WELL BEYOND 5' FROM POINT OF ENTRY. SERVICE DISCONNECT AT GARAGE APPEARS DETERIORATING. SERVICE EQUIPMENT AT BASEMENT MISSING COVERS. METER ENCLOSURE AT BASEMENT NOT INSTALLED IN APPROVED MANNER. SERVICE(S) MODIFIED FROM ORIGINAL CONDITION. MISSING MOGUL COVERS AND INACCESSIBLE MOGULS. ENSURE SERVICES IN APPROVED CONDITION. DANGEROUS AND	SEQ #: 008☐	7411	S	STONY ISLAND	AVE	08	Open
04/21/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	ENCLOSURES DETERIORATED SERVICE ENTRANCE CABLE FITTINGS AND CABLE AT LOAD SIDE OF 2 METERS ENCLOSURE 2 METER ENCLOSURE IS DETERIORATING SERVICE DETERIORATING SERVICE DISCONNECTS NOT GROUPED ENSURE SERVICE IN APPROVED CONDITION	SEQ #: 013☐	5605	N	KEYSTONE	AVE	39	Open

04/21/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	ENCLOSURES DETERIORATED SERVICE ENTRANCE CABLE FITTINGS AND CABLE AT LOAD SIDE OF 2 METERS ENCLOSURE 2 METER ENCLOSURE IS DETERIORATING SERVICE DETERIORATING SERVICE DISCONNECTS NOT GROUPED ENSURE SERVICE IN APPROVED CONDITION	SEQ #: 029□	5605	N	KEYSTONE	AVE	39	Open
04/21/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	NO VISIBLE WATER GROUND ENSURE SERVICE GROUNDED IN APPROVED MANNER DANGEROUS AND HAZARDOUS	SEQ #: 002□	5605	N	KEYSTONE	AVE	39	Open
04/21/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	NO VISIBLE WATER GROUND ENSURE SERVICE GROUNDED IN APPROVED MANNER DANGEROUS AND HAZARDOUS	SEQ #: 015□	5605	N	KEYSTONE	AVE	39	Open
04/21/2023	EL1822	EXPOSED WIRING FIXTURES	Remove exposed wiring at light fixture. (14E-4-410.48)	EXPOSED DAMAGED WIRING AT LIGHT FIXTURES VARIOUS REMOVE WHERE REQUIRED DANGEROUS AND HAZARDOUS	SEQ #: 010□	5605	N	KEYSTONE	AVE	39	Open
04/21/2023	EL1822	EXPOSED WIRING FIXTURES	Remove exposed wiring at light fixture. (14E-4-410.48)	EXPOSED DAMAGED WIRING AT LIGHT FIXTURES VARIOUS REMOVE WHERE REQUIRED DANGEROUS AND HAZARDOUS	SEQ #: 023□	5605	N	KEYSTONE	AVE	39	Open
04/21/2023	EL1880	DETERIORATED CONDUCTORS	Replace conductors with damaged or deteriorated insulation.(14E-1-110.7)	SEVERELY DETERIORATED CLOTH WIRING VISIBLE AT OPEN BOXES REPLACE WHERE REQUIRED DANGEROUS AND HAZARDOUS	SEQ #: 007□	5605	N	KEYSTONE	AVE	39	Open
04/21/2023	EL1880	DETERIORATED CONDUCTORS	Replace conductors with damaged or deteriorated insulation.(14E-1-110.7)	SEVERELY DETERIORATED CLOTH WIRING VISIBLE AT OPEN BOXES REPLACE WHERE REQUIRED DANGEROUS AND HAZARDOUS	SEQ #: 020□	5605	N	KEYSTONE	AVE	39	Open
07/19/2023	EL1827	RESTORE EXIT AND EM	and related equipment to working condition. (14E-7-700.6)	SYSTEM AND RELATED EQUIPMENT TO WORKING CONDITION	SEQ #: 034□	6046	S	RACINE	AVE	16	Open
07/19/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	EXPOSED WIRING NEEDS REMOVING THROUGHOUT BASEMENT CEILING	SEQ #: 033□	6046	S	RACINE	AVE	16	Open
05/05/2023	EL1817	CONTINUITY OF RACEWAYS	Provide ground continuity for electrical cable, raceway, and enclosure. (14E-3-300.10, 14E-3-300.13)	box at north exterior. Insure ground continuity where required throughout premises. Dangerous and hazardous.	SEQ #: 004□	4657	S	DREXEL	BLVD	04	Open
05/05/2023	EL1833	SECURE RACEWAY	Strap and secure raceway and armored cable. (14E-1-110.13(a))	Unsupported raceways at exterior areas.	SEQ #: 008□	4657	S	DREXEL	BLVD	04	Open
05/08/2023	EL1827	RESTORE EXIT AND EM	Restore exit and emergency lighting system and related equipment to working condition. (14E-7-700.6)	wire at battery lights. Unmaintained emergency lights and exits. Ensure required emergency lighting system is in approved condition. Dangerous and Hazardous.	SEQ #: 003□	1533	W	WARREN	BLVD	27	Open
05/08/2023	EL1827	RESTORE EXIT AND EM	Restore exit and emergency lighting system and related equipment to working condition. (14E-7-700.6)	Unapproved exit signs in multiple areas. No visible battery lights in the hallway and stairs. Emergency lighting systems not being maintained. Ensure the required emergency system exists and is fully operable. Dangerous and hazardous.	SEQ #: 006□	1519	W	WARREN	BLVD	27	Open
05/08/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	protected from damage at rear exterior and alley area. Overhead service cables possibly showing damage at service heads. Ensure services in approved condition.	SEQ #: 003□	148	N	MAYFIELD	AVE	29	Open
05/08/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	Multiple services on building with damaged service cables visible at rear exterior. Large sequential service disconnect showing signs of deterioration. Ensure all services are in approved condition. Dangerous and Hazardous.	SEQ #: 003□	8200	S	ELLIS	AVE	08	Open
05/08/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	No visible water ground. Ensure all services are grounded in approved manner Dangerous and Hazardous.	SEQ #: 004□	8200	S	ELLIS	AVE	08	Open
05/08/2023	EL1822	EXPOSED WIRING FIXTURES	Remove exposed wiring at light fixture. (14E-4-410.48)	walkway. Remove where required. Dangerous and Hazardous.	SEQ #: 006□	8200	S	ELLIS	AVE	08	Open

05/08/2023	EL1827	RESTORE EXIT AND EM	Restore exit and emergency lighting system and related equipment to working condition. (14E-7-700.6)	Unapproved exit signs. Unmaintained battery lights and exit signs at various locations. Dangerous and hazardous.	SEQ #: 007□	8200	S	ELLIS	AVE	08	Open
05/08/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	A service raceway at the rear utility pole is unsupported and pulling away. Service cable appears to be damaged. Ensure service is in approved condition. Dangerous and Hazardous.	SEQ #: 002□	1251	S	SAWYER	AVE	24	Open
05/15/2023	EL1817	CONTINUITY OF RACEWAYS	raceway, and enclosure. (14E-3-300.10, 14E-3-300.13)	Provide Continuity of broken conduits (14E-3-300.10)	SEQ #: 001□	3325	W	DOUGLAS	BLVD	24	Open
05/15/2023	EL1817	CONTINUITY OF RACEWAYS	raceway, and enclosure. (14E-3-300.10, 14E-3-300.13)	Provide Continuity of broken conduits (14E-3-300.10)	SEQ #: 010□	3325	W	DOUGLAS	BLVD	24	Open
05/15/2023	EL1839	CORRODED CONDUIT & EQUIP	Replace rusted, deteriorated, or corroded conduit, cabinet, electrical box, or fitting. (14E-3-300.13, 14E-1-110.12(b))	Replace rusted, deteriorated, or corroded conduit and electrical boxes (14E-3-300.13)	SEQ #: 002□	3325	W	DOUGLAS	BLVD	24	Open
05/15/2023	EL1839	CORRODED CONDUIT & EQUIP	Replace rusted, deteriorated, or corroded conduit, cabinet, electrical box, or fitting. (14E-3-300.13, 14E-1-110.12(b))	Replace rusted, deteriorated, or corroded conduit and electrical boxes (14E-3-300.13)	SEQ #: 011□	3325	W	DOUGLAS	BLVD	24	Open
05/15/2023	EL1834	LISTED FOR USE TEMP & LOCATION	temperature and location.(14E-1-110.2(B), 14E-1-110.11)	Lights Listed for weather to be installed for all outdoor fixtures 14E-1-110.2 (B)	SEQ #: 007□	5924	W	ROOSEVELT	RD	29	Open
05/19/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	PERMANANTLY SPLICED POSSIBLE DAMAGED. LOOSE PANEL COVERS AND DAMAGED PANELS IN BASEMENT.ENSURE SERVICE IN APPROVED CONDITION. DANGEROUS AND HAZARDOUS	SEQ #: 038□ 5258	8058	S	RACINE	AVE	17	Open
05/19/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	NO VISIBLE WATER GROUND. ENSURE SERVICE GROUNDED IN APPROVED MANNER.DANGEROUS AND HAZARDOUS	SEQ #: 039□ 5258	8058	S	RACINE	AVE	17	Open
05/19/2023	EL1817	CONTINUITY OF RACEWAYS	Provide ground continuity for electrical cable, raceway, and enclosure. (14E-3-300.10, 14E-3-300.13)	52-58 MISSING EQUIPMENT GROUNDS REFRIGIRATION DISCONNECT. LOOSE FITTINGS ON RACEWAY.	SEQ #: 042□	8058	S	RACINE	AVE	17	Open
05/19/2023	EL1827	RESTORE EXIT AND EM	Restore exit and emergency lighting system and related equipment to working condition. (14E-7-700.6)	UNMAINTAINED, BROKEN BATTERY LIGHTS AND EXIT SIGNS. DANGEROUS AND HAZARDOUS	SEQ #: 049□	8058	S	RACINE	AVE	17	Open
05/19/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	REMOVE WHERE REQUIRED. DANGEROUS AND HAZARDOUS.	SEQ #: 048□	8058	S	RACINE	AVE	17	Open
05/19/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	56 OPEN WIRING PROTRUDING FROM RACEWAY REAR STORE. OPEN WIRE REAR ROOM CEILING. REMOVE WHERE REQUIRED. DANGEROUS AND HAZARDOUS.	SEQ #: 053□	8058	S	RACINE	AVE	17	Open
05/19/2023	EL1833	SECURE RACEWAY	Strap and secure raceway and armored cable. (14E-1-110.13(a))	52-58FALLING RACEWAY BASEMENT.	SEQ #: 043□	8058	S	RACINE	AVE	17	Open
05/19/2023	EL1834	LISTED FOR USE TEMP & LOCATION	Electrical equipment shall be listed for use, temperature and location.(14E-1-110.2(B), 14E-1-110.11)	BOXES,FITTINGS,RACEWAYS AT WALK IN COOLERS MUST BE IDENTIFIED FOR USE AND SUITABLE FOR WET LOCATION,	SEQ #: 047□	8058	S	RACINE	AVE	17	Open
05/19/2023	EL1880	DETERIORATED CONDUCTORS	Replace conductors with damaged or deteriorated insulation.(14E-1-110.7)	DAMAGED WIRING VISIBLE AT OPEN PULL BOX. REPLACE WHERE REQUIRED. DANGEROUS AND HAZARDOUS	SEQ #: 041□	8058	S	RACINE	AVE	17	Open
09/29/2023	EL1827	RESTORE EXIT AND EM	Restore exit and emergency lighting system and related equipment to working condition. (14E-7-700.6)	SYSTEM AND RELATED EQUIPMENT TO WORKING CONDITION. EMERGENCY EQUIPMENT S/BE METAL NOT PLASTIC ALSO BASEMENT NEEDS (2) BATTERY EM PACKS	SEQ #: 023□	8058	S	RACINE	AVE	17	Open
09/29/2023	EL1827	RESTORE EXIT AND EM	Restore exit and emergency lighting system and related equipment to working condition. (14E-7-700.6)	SYSTEM AND RELATED EQUIPMENT TO WORKING CONDITION. EMERGENCY EQUIPMENT S/BE METAL NOT PLASTIC ALSO BASEMENT NEEDS (2) BATTERY EM PACKS	SEQ #: 033□	8058	S	RACINE	AVE	17	Open
09/29/2023	EL1833	SECURE RACEWAY	Strap and secure raceway and armored cable. (14E-1-110.13(a))	STRAP AND SECURE RACEWAY CONDUIT AND ARMORED CABLE THROUGH-OUT BASEMENT AND UPSTAIRS	SEQ #: 025□	8058	S	RACINE	AVE	17	Open

09/29/2023	EL1833	SECURE RACEWAY	Strap and secure raceway and armored cable. (14E-1-110.13(a))	STRAP AND SECURE RACEWAY CONDUIT AND ARMORED CABLE THROUGH-OUT BASEMENT AND UPSTAIRS	SEQ #: 035□	8058	S	RACINE	AVE	17	Open
06/06/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	JUMPED OVERHEAD SERVICE SPLICE DAMAGED WITH EXPOSED CONDUCTOR EYE PLATE DETERIORATED TREE LIMBS LAYING ON AND DEFLECTING OVERHEAD SERVICE DROP SERVICE ICE ENERGIZED VIA ILLEGAL CONNECTION TO NEIGHBORING SERVICE DROP SERVICE CONDUCTORS APPEAR DAMAGED AT DRIP LOOP ENSURE SERVICE IN APPROVED CONDITION DANGEROUS AND HAZARDOUS	SEQ #: 013□	8000	S	MANISTEE	AVE	07	Open
06/06/2023	EL1817	CONTINUITY OF RACEWAYS	Provide ground continuity for electrical cable, raceway, and enclosure. (14E-3-300.10, 14E-3-300.13)	CONDUIT VISIBLE AT OPEN WALLS AT 1ST FLOOR APARTMENT ENSURE GROUND CONTINUITY WHERE REQUIRED DANGEROUS AND HAZARDOUS	SEQ #: 021□	8000	S	MANISTEE	AVE	07	Open
06/06/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	EXPOSED LIVE WIRING AT GRADE REAR EXTERIOR YARD REMOVE WHERE REQUIRED DANGEROUS AND HAZARDOUS	SEQ #: 014□	8000	S	MANISTEE	AVE	07	Open
06/06/2023	EL1834	LISTED FOR USE TEMP & LOCATION	Electrical equipment shall be listed for use, temperature and location.(14E-1-110.2(B), 14E-1-110.11)	EXTERIOR LIGHT FIXTURES,BOXES,FITTINGS,RAEWAYS MUST BE SUITABLE FOR WET LOCATION	SEQ #: 015□	8000	S	MANISTEE	AVE	07	Open
05/23/2023	EL1834	LISTED FOR USE TEMP & LOCATION	Electrical equipment shall be listed for use, temperature and location.(14E-1-110.2(B), 14E-1-110.11)	Electical equipment to be listed for use , Fittings outdoors to be compression type and J-boxes to be weather proof	SEQ #: 009□	3256	W	WASHINGTON	BLVD	28	Open
05/23/2023	EL1839	CORRODED CONDUIT & EQUIP	Replace rusted, deteriorated, or corroded conduit, cabinet, electrical box, or fitting. (14E-3-300.13, 14E-1-110.12(b))	Repair or replace corroded conduit at fence intercom system.	SEQ #: 010□	3256	W	WASHINGTON	BLVD	28	Open
05/23/2023	EL1864	SERVICE DROP OUT OF REACH	Relocate service drop conductors out of normal reach.(14E-2-230.24)	Relocate service drop out of reach. Dangerous and hazardous	SEQ #: 011□	3256	W	WASHINGTON	BLVD	28	Open
05/26/2023	EL1817	CONTINUITY OF RACEWAYS	raceway, and enclosure. (14E-3-300.10, 14E-3-300.13)	Provide ground continuity for all conduits on the exterior	SEQ #: 006□	4725	S	MICHIGAN	AVE	03	Open
05/26/2023	EL1833	SECURE RACEWAY	Strap and secure raceway and armored cable. (14E-1-110.13(a))	Strap and secure all raceways on exterior.	SEQ #: 007□	4725	S	MICHIGAN	AVE	03	Open
05/26/2023	EL1834	LISTED FOR USE TEMP & LOCATION	Electrical equipment shall be listed for use, temperature and location.(14E-1-110.2(B), 14E-1-110.11)	electrical equipment to be listed for temperature and location. Flex for gate to be sealed tight metal core and j-box to be metallic. 14E-1-110.3(B)	SEQ #: 009□	4725	S	MICHIGAN	AVE	03	Open
05/26/2023	EL1803	DEFECTIVE METER EQUIPMENT	Replace defective meter socket. (14E-2-230.62,14E-2-230.66,14E-3-312.5)	Defective meter equipment to be replaced. Dangerous and hazardous	SEQ #: 009□	5728	S	HERMITAGE	AVE	15	Open
05/31/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	REAR EXTERIOR LAYING ON METAL ROOF FENCE WOODEN SERVICE MAST AT REAR EXTERIOR SEVERELY DETERIORATED SMALL ELECTRICAL SERVICE ABANDONED AND DE-ENERGIZED ENSURE SERVICE(S) IN APPROVED CONDITION DANGEROUS AND HAZARDOUS	SEQ #: 010□	2001	W	71ST	ST	17	Open
05/31/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	NO VISIBLE WATER GROUND ENSURE SERVICE GROUNDED IN APPROVED MANNER DANGEROUS AND HAZARDOUS	SEQ #: 011□	2001	W	71ST	ST	17	Open
05/31/2023	EL1817	CONTINUITY OF RACEWAYS	Provide ground continuity for electrical cable, raceway, and enclosure. (14E-3-300.10, 14E-3-300.13)	CONNECTED TO DISCONNECT AT REAR AREA FLEXIBLE METAL CONDUIT NOT CONNECTED TO WATER HEATER IN APPROVED MANNER AT REAR AREA ENSURE GROUND CONTINUITY WHERE REQUIRED DANGEROUS AND HAZARDOUS	SEQ #: 015□	2001	W	71ST	ST	17	Open
05/31/2023	EL1827	RESTORE EXIT AND EM	and related equipment to working condition. (14E-7-700.6)	EMERGENCY LIGHTING SYSTEM DANGEROUS AND HAZARDOUS	SEQ #: 022□	2001	W	71ST	ST	17	Open

05/31/2023	EL1833	SECURE RACEWAY	Strap and secure raceway and armored cable. (14E-1-110.13(a))	UNSUPPORTED RACEWAYS AT REAR AREAS SECURE WHERE REQUIRED	SEQ #: 023	2001	W	71ST	ST	17	Open
05/31/2023	EL1834	LISTED FOR USE TEMP & LOCATION	Electrical equipment shall be listed for use, temperature and location.(14E-1-110.2(B), 14E-1-110.11)	LIGHT FIXTURES,BOXES, FITTINGS, RACEWAYS AT WALK IN COOLERS MUST BE SUITABLE FOR LOCATION AND IDENTIFIED FOR USE DANGEROUS AND HAZARDOUS	SEQ #: 020	2001	W	71ST	ST	17	Open
05/31/2023	EL1827	RESTORE EXIT AND EM	and related equipment to working condition. (14E-7-700.6)	EMERGENCY LIGHTING SYSTEM DANGEROUS AND HAZARDOUS	SEQ #: 017	371	E	61ST	ST	20	Open
05/31/2023	EL1834	LISTED FOR USE TEMP & LOCATION	Electrical equipment shall be listed for use, temperature and location.(14E-1-110.2(B), 14E-1-110.11)	LIGHT FIXTURES BOXES FITTINGS RACEWAYS AT EXTERIOR MUST BE SUITABLE FOR WET LOCATION SET SCREW FITTINGS USED AT EAST STORAGE SPACE ENTRY	SEQ #: 022	371	E	61ST	ST	20	Open
05/31/2023	EL1834	LISTED FOR USE TEMP & LOCATION	Electrical equipment shall be listed for use, temperature and location.(14E-1-110.2(B), 14E-1-110.11)	RACEWAY SUPPLYING WATER HEATER AT BASEMENT INSTALLED UNAPPROVED MANNER FLEXIBLE METAL CONDUIT NEEDS TO BE USED FOR CONNECTION AT SPLICE BOX	SEQ #: 020	371	E	61ST	ST	20	Open
05/18/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	AND RACEWAYS DETERIORATING UNMAINTAINED LIVE FRONT MAIN SERVICE AND DISTRIBUTION EQUIPMENT WITH INOPERABLE DOORS ENSURE SERVICES IN APPROVED CONDITION DANGEROUS AND HAZARDOUS	SEQ #: 010	4045	N	ROCKWELL	ST	47	Open
05/18/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	AND RACEWAYS DETERIORATING UNMAINTAINED LIVE FRONT MAIN SERVICE AND DISTRIBUTION EQUIPMENT WITH INOPERABLE DOORS ENSURE SERVICES IN APPROVED CONDITION DANGEROUS AND HAZARDOUS	SEQ #: 020	4045	N	ROCKWELL	ST	47	Open
05/18/2023	EL1805	DEFECTIVE DISTRIBUTION	Replace defective distribution equipment. (14E-4-408.30, 14E-4-408.36, 14E-4-408.37, 14E-4-408.38, 14E-4-408.39, 14E-4-408.40, 14E-4-408.41))	DETERIORATING LIVE FRONT PANELS, PANELS WITH BROKEN DOORS, DETERIORATING DISTRIBUTION EQUIPMENT VISIBLE VARIOUS AREAS ENSURE DISTRIBUTION THROUGHOUT PREMISES IN APPROVED CONDITION DANGEROUS AND HAZARDOUS	SEQ #: 012	4045	N	ROCKWELL	ST	47	Open
05/18/2023	EL1805	DEFECTIVE DISTRIBUTION	Replace defective distribution equipment. (14E-4-408.30, 14E-4-408.36, 14E-4-408.37, 14E-4-408.38, 14E-4-408.39, 14E-4-408.40, 14E-4-408.41))	DETERIORATING LIVE FRONT PANELS, PANELS WITH BROKEN DOORS, DETERIORATING DISTRIBUTION EQUIPMENT VISIBLE VARIOUS AREAS ENSURE DISTRIBUTION THROUGHOUT PREMISES IN APPROVED CONDITION DANGEROUS AND HAZARDOUS	SEQ #: 022	4045	N	ROCKWELL	ST	47	Open
05/18/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	NO VISIBLE WATER GROUNDS(S) ENSURE ALL SERVICE GROUNDED IN APPROVED MANNER DANGEROUS AND HAZARDOUS	SEQ #: 011	4045	N	ROCKWELL	ST	47	Open
05/18/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	NO VISIBLE WATER GROUNDS(S) ENSURE ALL SERVICE GROUNDED IN APPROVED MANNER DANGEROUS AND HAZARDOUS	SEQ #: 021	4045	N	ROCKWELL	ST	47	Open
05/18/2023	EL1817	CONTINUITY OF RACEWAYS	Provide ground continuity for electrical cable, raceway, and enclosure. (14E-3-300.10, 14E-3-300.13)	PULLED AWAY FROM FITTINGS VISIBLE VARIOUS ENSURE GROUND CONTINUITY WHERE REQUIRED DANGEROUS AND HAZARDOUS	SEQ #: 025	4045	N	ROCKWELL	ST	47	Open
05/18/2023	EL1817	CONTINUITY OF RACEWAYS	Provide ground continuity for electrical cable, raceway, and enclosure. (14E-3-300.10, 14E-3-300.13)	PULLED AWAY FROM FITTINGS VISIBLE VARIOUS ENSURE GROUND CONTINUITY WHERE REQUIRED DANGEROUS AND HAZARDOUS	SEQ #: 032	4045	N	ROCKWELL	ST	47	Open
05/18/2023	EL1822	EXPOSED WIRING FIXTURES	Remove exposed wiring at light fixture. (14E-4-410.48)	OPEN WIRING AT LIGHT FIXTURES VARIOUS AREAS REMOVE WHERE REQUIRED DANGEROUS AND HAZARDOUS	SEQ #: 026	4045	N	ROCKWELL	ST	47	Open

05/18/2023	EL1822	EXPOSED WIRING FIXTURES	Remove exposed wiring at light fixture. (14E-4-410.48)	OPEN WIRING AT LIGHT FIXTURES VARIOUS AREAS REMOVE WHERE REQUIRED DANGEROUS AND HAZARDOUS	SEQ #: 033☐	4045	N	ROCKWELL	ST	47	Open
05/18/2023	EL1826	SYSTEM II	Install system II emergency lighting. (14E-7-700.6, 14E-7-700.21)	PREMISES DOES NOT HAVE REQUIRED FULLY OPERABLE TYPE II EMERGENCY LIGHTING SYSTEM DANGEROUS AND HAZARDOUS	SEQ #: 016☐	4045	N	ROCKWELL	ST	47	Open
05/18/2023	EL1826	SYSTEM II	Install system II emergency lighting. (14E-7-700.6, 14E-7-700.21)	PREMISES DOES NOT HAVE REQUIRED FULLY OPERABLE TYPE II EMERGENCY LIGHTING SYSTEM DANGEROUS AND HAZARDOUS	SEQ #: 026☐	4045	N	ROCKWELL	ST	47	Open
05/18/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	OPEN WIRING VARIOUS AREAS THROUGHOUT PREMISES REMOVE WHERE REQUIRED DANGEROUS AND HAZARDOUS	SEQ #: 017☐	4045	N	ROCKWELL	ST	47	Open
05/18/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	OPEN WIRING VARIOUS AREAS THROUGHOUT PREMISES REMOVE WHERE REQUIRED DANGEROUS AND HAZARDOUS	SEQ #: 027☐	4045	N	ROCKWELL	ST	47	Open
05/18/2023	EL1833	SECURE RACEWAY	Strap and secure raceway and armored cable. (14E-1-110.13(a))	UNSUPPORTED CONDUITS SECURE WHERE REQUIRED	SEQ #: 035☐	4045	N	ROCKWELL	ST	47	Open
05/18/2023	EL1833	SECURE RACEWAY	Strap and secure raceway and armored cable. (14E-1-110.13(a))	UNSUPPORTED CONDUITS SECURE WHERE REQUIRED	SEQ #: 039☐	4045	N	ROCKWELL	ST	47	Open
05/18/2023	EL1880	DETERIORATED CONDUCTORS	Replace conductors with damaged or deteriorated insulation.(14E-1-110.7)	REPLACE DETERIORATED DAMAGED WIRING VISIBLE AT VARIOUS AREAS WHERE REQUIRED THROUGHOUT PREMISES	SEQ #: 033☐	4045	N	ROCKWELL	ST	47	Open
05/18/2023	EL1880	DETERIORATED CONDUCTORS	Replace conductors with damaged or deteriorated insulation.(14E-1-110.7)	REPLACE DETERIORATED DAMAGED WIRING VISIBLE AT VARIOUS AREAS WHERE REQUIRED THROUGHOUT PREMISES	SEQ #: 037☐	4045	N	ROCKWELL	ST	47	Open
06/16/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	D&H BURNED OUT BY FIRE CONDUCTORS ARE COMPROMISED	SEQ #: 006☐	11030	S	HALSTED	ST	21	Open
06/16/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	D&H BURNED OUT BY FIRE CONDUCTORS ARE COMPROMISED	SEQ #: 019☐	11030	S	HALSTED	ST	21	Open
06/16/2023	EL1803	DEFECTIVE METER EQUIPMENT	Replace defective meter socket. (14E-2-230.62,14E-2-230.66,14E-3-312.5)	CONDUCTORS ARE COMPROMISED NEED REPLACING	SEQ #: 007☐	11030	S	HALSTED	ST	21	Open
06/16/2023	EL1803	DEFECTIVE METER EQUIPMENT	Replace defective meter socket. (14E-2-230.62,14E-2-230.66,14E-3-312.5)	CONDUCTORS ARE COMPROMISED NEED REPLACING	SEQ #: 020☐	11030	S	HALSTED	ST	21	Open
06/16/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	D&H BURNED OUT BY FIRE CONDUCTORS ARE COMPROMISED	SEQ #: 008☐	11030	S	HALSTED	ST	21	Open
06/16/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	D&H BURNED OUT BY FIRE CONDUCTORS ARE COMPROMISED	SEQ #: 021☐	11030	S	HALSTED	ST	21	Open
06/16/2023	EL1815	DEFECTIVE BREAKER	Replace defective circuit breaker. (14E-2-240.80, 14E-2-240.81, 14E-2-240.82, 14E-2-240.83, 14E-2-240.84, 14E-2-240.85)	D&H REPLACE CIRCUIT BREAKERS DUE TO FIRE DAMAGE	SEQ #: 009☐	11030	S	HALSTED	ST	21	Open
06/16/2023	EL1815	DEFECTIVE BREAKER	Replace defective circuit breaker. (14E-2-240.80, 14E-2-240.81, 14E-2-240.82, 14E-2-240.83, 14E-2-240.84, 14E-2-240.85)	D&H REPLACE CIRCUIT BREAKERS DUE TO FIRE DAMAGE	SEQ #: 022☐	11030	S	HALSTED	ST	21	Open
06/16/2023	EL1822	EXPOSED WIRING FIXTURES	Remove exposed wiring at light fixture. (14E-4-410.48)	REMOVE EXPOSED WIRING AT LIGHT FIXTURE IN GARAGE AREA	SEQ #: 011☐	11030	S	HALSTED	ST	21	Open
06/16/2023	EL1822	EXPOSED WIRING FIXTURES	Remove exposed wiring at light fixture. (14E-4-410.48)	REMOVE EXPOSED WIRING AT LIGHT FIXTURE IN GARAGE AREA	SEQ #: 024☐	11030	S	HALSTED	ST	21	Open
06/16/2023	EL1827	RESTORE EXIT AND EM	and related equipment to working condition. (14E-7-700.6)	LIGHTING SYSTEM EXIT SIGN MUST BE METAL NOT PLASTIC	SEQ #: 012☐	11030	S	HALSTED	ST	21	Open
06/16/2023	EL1827	RESTORE EXIT AND EM	and related equipment to working condition. (14E-7-700.6)	LIGHTING SYSTEM EXIT SIGN MUST BE METAL NOT PLASTIC	SEQ #: 025☐	11030	S	HALSTED	ST	21	Open
06/16/2023	EL1822	EXPOSED WIRING FIXTURES	Remove exposed wiring at light fixture. (14E-4-410.48)	EXPOSED WIRING FIXTURES; REMOVE EXPOSED WIRING AT FIXTURES	SEQ #: 011☐	11010	S	HALSTED	ST	21	Open
06/16/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	EXPOSED WIRING NEEDS REMOVING	SEQ #: 013☐	11010	S	HALSTED	ST	21	Open
06/24/2023	EL1822	EXPOSED WIRING FIXTURES	Remove exposed wiring at light fixture. (14E-4-410.48)	3RD FLOOR SHOWER AND HALLWAY - OPEN WIRING OR MISSING KNOCKOUTS .	SEQ #: 005☐ INTERIOR:003 :	2008	S	BLUE ISLAND	AVE	25	Open

06/16/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	MULTIPLE SERVICE ON BUILDING DISCONNECTS NOT GROUPED	SEQ #: 024☐	7907	S	EBERHART	AVE	06	Open
06/16/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	CABLES INSUFFICIENTLY SUPPORTED, WITHIN REACH OF PORCH AND LAYING ON PORCH EXCESSIVE VEGETATION GROWING ON SERVICE DROP ENSURE SERVICE IN APPROVED CONDITION DANGEROUS AND HAZARDOUS	SEQ #: 020☐	7907	S	EBERHART	AVE	06	Open
06/16/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	SOUTH ELECTRICAL SERVICE MAIN DISCONNECT AT FAR SOUTH BASEMENT IS OPEN, DETERIORATED, DAMAGED, HAS A MISSING JUMPED FUSE AND LIVE FRONT EXTERIOR MOGUL IS MISSING COVER AND SEALED WITH WOOD OVERHEAD CABLES POSSIBLY DAMAGED AT HEAD AND HAVE DETERIORATED SPLICES WITH EXPOSED CONDUCTOR METERING EQUIPMENT AND PANELS AT BASEMENT ARE OPEN, VANDALIZED AND DAMAGED SERVICE HAS BEEN PARTIALLY MODIFIED FROM ORIGINAL CONDITION ENSURE SERVICE IN APPROVED	SEQ #: 019☐	7907	S	EBERHART	AVE	06	Open
06/16/2023	EL1805	DEFECTIVE DISTRIBUTION	Replace defective distribution equipment. (14E-4-408.30, 14E-4-408.36, 14E-4-408.37, 14E-4-408.38, 14E-4-408.39, 14E-4-408.40, 14E-4-408.41)	SEVERELY DAMAGED CORRODED PANEL AND EQUIPMENT AT NORTH BASEMENT AREAS ENSURE DISTRIBUTION EQUIPMENT IN APPROVED CONDITION THROUGHOUT PREMISES DANGEROUS AND HAZARDOUS	SEQ #: 025☐	7907	S	EBERHART	AVE	06	Open
06/16/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	NO VISIBLE WATER GROUNDS ENSURE SERVICES GROUNDED IN APPROVED MANNER DANGEROUS AND HAZARDOUS	SEQ #: 022☐	7907	S	EBERHART	AVE	06	Open
06/16/2023	EL1817	CONTINUITY OF RACEWAYS	Provide ground continuity for electrical cable, raceway, and enclosure. (14E-3-300.10, 14E-3-300.13)	RACEWAY PULLED FROM BOXES AND FITTINGS VARIOUS AREAS EXTERIOR AND BASEMENT ENSURE GROUND CONTINUITY WHERE REQUIRED THROUGHOUT PREMISES DANGEROUS AND HAZARDOUS	SEQ #: 033☐	7907	S	EBERHART	AVE	06	Open
06/16/2023	EL1822	EXPOSED WIRING FIXTURES	Remove exposed wiring at light fixture. (14E-4-410.48)	2ND FLOOR APARTMENT AND FRONT EXTERIOR REPAIR WHERE REQUIRED THROUGHOUT PREMISES DANGEROUS AND HAZARDOUS	SEQ #: 040☐	7907	S	EBERHART	AVE	06	Open
06/16/2023	EL1827	RESTORE EXIT AND EM	Restore exit and emergency lighting system and related equipment to working condition. (14E-7-700.6)	EMERGENCY LIGHTING AT SOUTH INTERIOR AREAS UNMAINTAINED AND INSUFFICIENT BASEMENT ENSURE OPERABLE SYSTEM WHERE REQUIRED THROUGHOUT PREMISES DANGEROUS AND HAZARDOUS	SEQ #: 036☐	7907	S	EBERHART	AVE	06	Open
06/16/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	BASEMENT AREAS REMOVE WHERE REQUIRED THROUGHOUT PREMISES DANGEROUS AND HAZARDOUS	SEQ #: 027☐	7907	S	EBERHART	AVE	06	Open
06/16/2023	EL1833	SECURE RACEWAY	Strap and secure raceway and armored cable. (14E-1-110.13(a))	UNSUPPORTED HANGING RACEWAYS AT BASEMENT AND EXTERIOR SECURE WHERE REQUIRED DANGEROUS AND HAZARDOUS	SEQ #: 034☐	7907	S	EBERHART	AVE	06	Open
06/16/2023	EL1834	LISTED FOR USE TEMP & LOCATION	temperature and location. (14E-1-110.2(B), 14E-1-110.11)	FITTINGS RACEWAYS MUST BE SUITABLE FOR WET LOCATION	SEQ #: 031☐	7907	S	EBERHART	AVE	06	Open
06/16/2023	EL1839	CORRODED CONDUIT & EQUIP	Replace rusted, deteriorated, or corroded conduit, cabinet, electrical box, or fitting. (14E-3-300.13, 14E-1-110.12(b))	CORRODED CONDUIT BOXES RACEWAYS AND EQUIPMENT VARIOUS AREAS THROUGHOUT BASEMENT AND EXTERIOR REPLACE WHERE REQUIRED THROUGHOUT PREMISES DANGEROUS AND HAZARDOUS	SEQ #: 029☐	7907	S	EBERHART	AVE	06	Open
06/16/2023	EL1864	SERVICE DROP OUT OF REACH	Relocate service drop conductors out of normal reach. (14E-2-230.24)	ABANDONED LIVE SERVICE DROP AT CENTER OF REAR EXTERIOR WITHIN REACH OF PORCH DANGEROUS AND HAZARDOUS	SEQ #: 021☐	7907	S	EBERHART	AVE	06	Open

06/16/2023	EL1880	DETERIORATED CONDUCTORS	Replace conductors with damaged or deteriorated insulation.(14E-1-110.7)	DETERIORATED CLOTH WIRING DAMAGED WIRING VISIBLE AT OPEN BOXES AND EQUIPMENT THROUGHOUT BASEMENT REPLACE WHERE REQUIRED THROUGHOUT PREMISES DANGEROUS AND HAZARDOUS	SEQ #: 030☐	7907	S	EBERHART	AVE	06	Open
05/23/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	deteriorated/damaged at service head. Ensure service in approved condition. Dangerous and Hazardous	SEQ #: 005☐	5254	W	WOLFRAM	ST	31	Open
05/23/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	Overhead service cables appear deteriorated / damaged at service head. Ensure service in approved condition. Dangerous and Hazardous	SEQ #: 004☐	5254	W	WOLFRAM	ST	31	Open
06/27/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	1ST FLOOR - OPEN SWITCH AND OUTLET BOXES.	SEQ #: 008☐ INTERIOR:001 :	4833	W	GLADYS	AVE	29	Open
05/23/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	Front Building Service - Unapproved riser supports. Deteriorated eye plate. Deteriorated cables at service head. Deteriorated overhead splice covers. Ensure service is in approved condition for both front and rear buildings. Dangerous and hazardous.	SEQ #: 006☐	1943	N	LA CROSSE	AVE	36	Open
05/23/2023	EL1822	EXPOSED WIRING FIXTURES	Remove exposed wiring at light fixture. (14E-4-410.48)	Provide access to inspect condition of electrical service equipment at front and rear buildings . Dangerous and hazardous.	SEQ #: 009☐	1943	N	LA CROSSE	AVE	36	Open
05/23/2023	EL1834	LISTED FOR USE TEMP & LOCATION	temperature and location.(14E-1-110.2(B), 14E-1-110.11)	Exterior light fixtures, boxes, fittings, raceways must be suitable for wet conditions.	SEQ #: 008☐	1943	N	LA CROSSE	AVE	36	Open
05/23/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	Overhead service splices are deteriorated and there appears to be bare conductor Ensure service is in approved condition. Very Dangerous and Hazardous.	SEQ #: 005☐	3054	N	MAJOR	AVE	30	Open
06/28/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	REPLACE DEFECTIVE SERVICE	SEQ #: 012☐	11806	S	PARNELL	AVE	21	Open
06/28/2023	EL1803	DEFECTIVE METER EQUIPMENT	Replace defective meter socket. (14E-2-230.62,14E-2-230.66,14E-3-312.5)	D&H REPLACE DEFECTIVE METER SOCKET	SEQ #: 013☐	11806	S	PARNELL	AVE	21	Open
06/28/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	INSTALL PROPER SIZE GOUNDING CONDUCTOR	SEQ #: 014☐	11806	S	PARNELL	AVE	21	Open
06/28/2023	EL1822	EXPOSED WIRING FIXTURES	Remove exposed wiring at light fixture. (14E-4-410.48)	D&H REMOVE EXSPOSED WIRING AT LIGHT FIXTURE 1st FLR EXHAUST FAN.	SEQ #: 017☐	11806	S	PARNELL	AVE	21	Open
06/28/2023	EL1822	EXPOSED WIRING FIXTURES	Remove exposed wiring at light fixture. (14E-4-410.48)	D&H REMOVE EXSPOSED WIRING AT LIGHT FIXTURE GOING TO 2nd FLR	SEQ #: 018☐	11806	S	PARNELL	AVE	21	Open
06/29/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	REPLACE DEFECTIVE SERVICE D&H	SEQ #: 001☐	11806	S	PARNELL	AVE	21	Open
06/29/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	REPLACE DEFECTIVE SERVICE D&H	SEQ #: 012☐	11806	S	PARNELL	AVE	21	Open
06/29/2023	EL1803	DEFECTIVE METER EQUIPMENT	Replace defective meter socket. (14E-2-230.62,14E-2-230.66,14E-3-312.5)	REPLAC DEFECTIVE METER SOCKET D&H	SEQ #: 002☐	11806	S	PARNELL	AVE	21	Open
06/29/2023	EL1803	DEFECTIVE METER EQUIPMENT	Replace defective meter socket. (14E-2-230.62,14E-2-230.66,14E-3-312.5)	REPLAC DEFECTIVE METER SOCKET D&H	SEQ #: 013☐	11806	S	PARNELL	AVE	21	Open
06/29/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	INSTALL PROPER SIZE GROUNDING CONDUCTOR D&H	SEQ #: 003☐	11806	S	PARNELL	AVE	21	Open
06/29/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	INSTALL PROPER SIZE GROUNDING CONDUCTOR D&H	SEQ #: 014☐	11806	S	PARNELL	AVE	21	Open
06/29/2023	EL1822	EXPOSED WIRING FIXTURES	Remove exposed wiring at light fixture. (14E-4-410.48)	REMOVE EXSPOSED WIRING AT FLIGHT FIXTURE 1ST FLR KITCHEN EXHASUT FAN	SEQ #: 005☐	11806	S	PARNELL	AVE	21	Open
06/29/2023	EL1822	EXPOSED WIRING FIXTURES	Remove exposed wiring at light fixture. (14E-4-410.48)	REMOVE EXSPOSED WIRING AT FLIGHT FIXTURE 1ST FLR KITCHEN EXHASUT FAN	SEQ #: 016☐	11806	S	PARNELL	AVE	21	Open
06/29/2023	EL1822	EXPOSED WIRING FIXTURES	Remove exposed wiring at light fixture. (14E-4-410.48)	REMOVE EXSPOSED WIRING AT LIGHT FIXTURE GOING TO 2ND FLR	SEQ #: 006☐	11806	S	PARNELL	AVE	21	Open
06/29/2023	EL1822	EXPOSED WIRING FIXTURES	Remove exposed wiring at light fixture. (14E-4-410.48)	REMOVE EXSPOSED WIRING AT LIGHT FIXTURE GOING TO 2ND FLR	SEQ #: 017☐	11806	S	PARNELL	AVE	21	Open

06/28/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	SERVICE RISER IS REACHABLE	SEQ #: 001☐	3529	W	FLOURNOY	ST	24	Open
06/28/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	SERVICE RISER IS REACHABLE	SEQ #: 006☐	3529	W	FLOURNOY	ST	24	Open
06/28/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	EXSPOSED WIRING IN BASEMENT EXTERIOR	SEQ #: 004☐	3529	W	FLOURNOY	ST	24	Open
06/28/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	EXSPOSED WIRING IN BASEMENT EXTERIOR	SEQ #: 009☐	3529	W	FLOURNOY	ST	24	Open
06/23/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	Meter enclosure has damaged cover. Low voltage cales in contact with overhead service cables at rear exterior. Ensure service in approved condition. Dangerous and Hazardous	SEQ #: 005☐	7919	S	PHILLIPS	AVE	07	Open
06/30/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	NO GEC NOTICEABLE FOR WATER MAIN	SEQ #: 019☐	10604	S	WALDEN	PKWY	19	Open
06/30/2023	EL1827	RESTORE EXIT AND EM	and related equipment to working condition. (14E-7-700.6)		SEQ #: 020☐	10604	S	WALDEN	PKWY	19	Open
05/10/2023	EL1805	DEFECTIVE DISTRIBUTION	4-408.30, 14E-4-408.36, 14E-4-408.37, 14E-4-408.38, 14E-4-408.39, 14E-4-408.40, 14E-4-408.41)	proper use of disconnect on rtu	SEQ #: 008☐	1929	W	87TH	ST	19	Open
05/10/2023	EL1828	UNAPPROVED EM	from emergency lighting system. (14E-7-700.63)	replace plastic exit signs	SEQ #: 010☐	1929	W	87TH	ST	19	Open
05/10/2023	EL1834	LISTED FOR USE TEMP & LOCATION	temperature and location.(14E-1-110.2(B), 14E-1-110.11)	replace the liquidtight whips and connectors on rtu	SEQ #: 012☐	1929	W	87TH	ST	19	Open
07/11/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	SERVICE HEAD MISSING. OVERHEAD SPLICES DAMAGED. UNAPPROVED ATTACHMENTS TO SERVICE MAST. MECHANICAL LINES TIED TO AND BEING SUPPORTED BY OVERHEAD SERVICE CABLES. MAIN PANEL INACCESSIBLE AND POSSIBLY DAMAGED BY CLUTTER AND STORAGE. ENSURE SERVICE IN APPROVED CONDITION. DANGEROUS AND HAZARDOUS	SEQ #: 011☐	4325	S	HALSTED	ST	11	Open
07/11/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	NO VISIBLE WATER GROUND. DAMAGED SUPPLEMENTAL GROUND. ENSURE SERVICE GROUNDED IN APPROVED MANNER. DANGEROUS AND HAZRDOUS	SEQ #: 013☐	4325	S	HALSTED	ST	11	Open
07/11/2023	EL1817	CONTINUITY OF RACEWAYS	Provide ground continuity for electrical cable, raceway, and enclosure. (14E-3-300.10, 14E-3-300.13)	RACEWAYS NOT ATTACHED TO BOXES OR EQUIPMENT VARIOUS AREAS THROUGHOUT. ENSURE GROUND CONTINUITY THROUGHOUT. DANGEROUS AND HAZARDOUS	SEQ #: 016☐	4325	S	HALSTED	ST	11	Open
07/11/2023	EL1822	EXPOSED WIRING FIXTURES	Remove exposed wiring at light fixture. (14E-4-410.48)	AREAS THROUGHOUT. DANGEROUS AND HAZARDOUS	SEQ #: 019☐	4325	S	HALSTED	ST	11	Open
07/11/2023	EL1827	RESTORE EXIT AND EM	and related equipment to working condition. (14E-7-700.6)	LIGHTING SYSTEM. DANGEROUS AND HAZARDOUS	SEQ #: 022☐	4325	S	HALSTED	ST	11	Open
07/11/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	OPEN WIRING VISIBLE THROUGHOUT PREMISES. DANGEROUS AND HAZARDOUS	SEQ #: 015☐	4325	S	HALSTED	ST	11	Open
07/11/2023	EL1833	SECURE RACEWAY	Strap and secure raceway and armored cable. (14E-1-110.13(a))	AND EXTERIOR. DANGEROUS AND HAZARDOUS	SEQ #: 024☐	4325	S	HALSTED	ST	11	Open
07/11/2023	EL1834	LISTED FOR USE TEMP & LOCATION	Electrical equipment shall be listed for use, temperature and location.(14E-1-110.2(B), 14E-1-110.11)	DAMAGED MODIFIED UNSUPPORTED DIXCONNECTS AND EQUIPMENT VARIOUS AREAS. DANGEROUS AND HAZARDOUS	SEQ #: 023☐	4325	S	HALSTED	ST	11	Open
07/11/2023	EL1834	LISTED FOR USE TEMP & LOCATION	Electrical equipment shall be listed for use, temperature and location.(14E-1-110.2(B), 14E-1-110.11)	MISSING EQUIPMENT COVERS VARIOUS AREAS. INSTALL WHERE REQUIRED. DANGEROUS AND HAZARDOUS	SEQ #: 028☐	4325	S	HALSTED	ST	11	Open
07/11/2023	EL1834	LISTED FOR USE TEMP & LOCATION	Electrical equipment shall be listed for use, temperature and location.(14E-1-110.2(B), 14E-1-110.11)	DEVICES USED AT EXTERIOR. EXTERIOR LIGHT FIXTURES, BOXES, FITTINGS, RACEWAYS MUST BE SUITABLE FOR WET LOCATION. DANGEROUS AND HAZARDOUS	SEQ #: 021☐	4325	S	HALSTED	ST	11	Open

07/13/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	SERVICE HEAD MISSING. OVERHEAD SPLICES DAMAGED. UNAPPROVED ATTACHMENTS TO SERVICE MAST. MECHANICAL LINES TIED TO AND BEING SUPPORTED BY OVERHEAD SERVICE CABLES. MAIN PANEL INACCESSIBLE AND POSSIBLY DAMAGED BY CLUTTER AND STORAGE. ENSURE SERVICE IN APPROVED CONDITION. DANGEROUS AND HAZARDOUS	SEQ #: 011□	4325	S	HALSTED	ST	11	Open
07/13/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	SERVICE HEAD MISSING. OVERHEAD SPLICES DAMAGED. UNAPPROVED ATTACHMENTS TO SERVICE MAST. MECHANICAL LINES TIED TO AND BEING SUPPORTED BY OVERHEAD SERVICE CABLES. MAIN PANEL INACCESSIBLE AND POSSIBLY DAMAGED BY CLUTTER AND STORAGE. ENSURE SERVICE IN APPROVED CONDITION. DANGEROUS AND HAZARDOUS	SEQ #: 021□	4325	S	HALSTED	ST	11	Open
07/13/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	NO VISIBLE WATER GROUND. DAMAGED SUPPLEMENTAL GROUND. ENSURE SERVICE GROUNDED IN APPROVED MANNER. DANGEROUS AND HAZRDOUS	SEQ #: 012□	4325	S	HALSTED	ST	11	Open
07/13/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	NO VISIBLE WATER GROUND. DAMAGED SUPPLEMENTAL GROUND. ENSURE SERVICE GROUNDED IN APPROVED MANNER. DANGEROUS AND HAZRDOUS	SEQ #: 023□	4325	S	HALSTED	ST	11	Open
07/13/2023	EL1817	CONTINUITY OF RACEWAYS	Provide ground continuity for electrical cable, raceway, and enclosure. (14E-3-300.10, 14E-3-300.13)	RACEWAYS NOT ATTACHED TO BOXES OR EQUIPMENT VARIOUS AREAS THROUGHOUT. ENSURE GROUND CONTINUITY THROUGHOUT. DANGEROUS AND HAZARDOUS	SEQ #: 016□	4325	S	HALSTED	ST	11	Open
07/13/2023	EL1817	CONTINUITY OF RACEWAYS	Provide ground continuity for electrical cable, raceway, and enclosure. (14E-3-300.10, 14E-3-300.13)	RACEWAYS NOT ATTACHED TO BOXES OR EQUIPMENT VARIOUS AREAS THROUGHOUT. ENSURE GROUND CONTINUITY THROUGHOUT. DANGEROUS AND HAZARDOUS	SEQ #: 026□	4325	S	HALSTED	ST	11	Open
07/13/2023	EL1822	EXPOSED WIRING FIXTURES	Remove exposed wiring at light fixture. (14E-4-410.48)	AREAS THROUGHOUT. DANGEROUS AND HAZARDOUS	SEQ #: 019□	4325	S	HALSTED	ST	11	Open
07/13/2023	EL1822	EXPOSED WIRING FIXTURES	Remove exposed wiring at light fixture. (14E-4-410.48)	AREAS THROUGHOUT. DANGEROUS AND HAZARDOUS	SEQ #: 029□	4325	S	HALSTED	ST	11	Open
07/13/2023	EL1827	RESTORE EXIT AND EM	and related equipment to working condition. (14E-7-700.6)	LIGHTING SYSTEM. DANGEROUS AND HAZARDOUS	SEQ #: 022□	4325	S	HALSTED	ST	11	Open
07/13/2023	EL1827	RESTORE EXIT AND EM	and related equipment to working condition. (14E-7-700.6)	LIGHTING SYSTEM. DANGEROUS AND HAZARDOUS	SEQ #: 032□	4325	S	HALSTED	ST	11	Open
07/13/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	OPEN WIRING VISIBLE THROUGHOUT PREMISES. DANGEROUS AND HAZARDOUS	SEQ #: 015□	4325	S	HALSTED	ST	11	Open
07/13/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	OPEN WIRING VISIBLE THROUGHOUT PREMISES. DANGEROUS AND HAZARDOUS	SEQ #: 025□	4325	S	HALSTED	ST	11	Open
07/13/2023	EL1833	SECURE RACEWAY	Strap and secure raceway and armored cable. (14E-1-110.13(a))	AND EXTERIOR. DANGEROUS AND HAZARDOUS	SEQ #: 024□	4325	S	HALSTED	ST	11	Open
07/13/2023	EL1833	SECURE RACEWAY	Strap and secure raceway and armored cable. (14E-1-110.13(a))	AND EXTERIOR. DANGEROUS AND HAZARDOUS	SEQ #: 034□	4325	S	HALSTED	ST	11	Open
07/13/2023	EL1834	LISTED FOR USE TEMP & LOCATION	Electrical equipment shall be listed for use, temperature and location.(14E-1-110.2(B), 14E-1-110.11)	DAMAGED MODIFIED UNSUPPORTED DIXCONNECTS AND EQUIPMENT VARIOUS AREAS. DANGEROUS AND HAZARDOUS	SEQ #: 023□	4325	S	HALSTED	ST	11	Open
07/13/2023	EL1834	LISTED FOR USE TEMP & LOCATION	Electrical equipment shall be listed for use, temperature and location.(14E-1-110.2(B), 14E-1-110.11)	DAMAGED MODIFIED UNSUPPORTED DIXCONNECTS AND EQUIPMENT VARIOUS AREAS. DANGEROUS AND HAZARDOUS	SEQ #: 033□	4325	S	HALSTED	ST	11	Open
07/13/2023	EL1834	LISTED FOR USE TEMP & LOCATION	Electrical equipment shall be listed for use, temperature and location.(14E-1-110.2(B), 14E-1-110.11)	MISSING EQUIPMENT COVERS VARIOUS AREAS. INSTALL WHERE REQUIRED. DANGEROUS AND HAZARDOUS	SEQ #: 028□	4325	S	HALSTED	ST	11	Open

07/13/2023	EL1834	LISTED FOR USE TEMP & LOCATION	Electrical equipment shall be listed for use, temperature and location.(14E-1-110.2(B), 14E-1-110.11)	MISSING EQUIPMENT COVERS VARIOUS AREAS. INSTALL WHERE REQUIRED. DANGEROUS AND HAZARDOUS	SEQ #: 038	4325	S	HALSTED	ST	11	Open
07/13/2023	EL1834	LISTED FOR USE TEMP & LOCATION	Electrical equipment shall be listed for use, temperature and location.(14E-1-110.2(B), 14E-1-110.11)	DEVICES USED AT EXTERIOR. EXTERIOR LIGHT FIXTURES, BOXES, FITTINGS, RACEWAYS MUST BE SUITABLE FOR WET LOCATION. DANGEROUS AND HAZARDOUS	SEQ #: 021	4325	S	HALSTED	ST	11	Open
07/13/2023	EL1834	LISTED FOR USE TEMP & LOCATION	Electrical equipment shall be listed for use, temperature and location.(14E-1-110.2(B), 14E-1-110.11)	DEVICES USED AT EXTERIOR. EXTERIOR LIGHT FIXTURES, BOXES, FITTINGS, RACEWAYS MUST BE SUITABLE FOR WET LOCATION. DANGEROUS AND HAZARDOUS	SEQ #: 031	4325	S	HALSTED	ST	11	Open
07/12/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	336-48 DAMAGED VANDALIZED ELECTRICAL SERVICES THROUGHOUT ENTIRE EXTERIOR	SEQ #: 058	5201	W	LAKE	ST	37	Open
07/12/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	336-48 DAMAGED VANDALIZED ELECTRICAL SERVICES THROUGHOUT ENTIRE EXTERIOR	SEQ #: 066	5201	W	LAKE	ST	37	Open
07/12/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	348 DAMAGED VANDALIZED ELECTRICAL SERVICES DANAGEROUS AND HAZARDOUS	SEQ #: 046	5201	W	LAKE	ST	37	Open
07/12/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	348 DAMAGED VANDALIZED ELECTRICAL SERVICES DANAGEROUS AND HAZARDOUS	SEQ #: 065	5201	W	LAKE	ST	37	Open
07/12/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	36-38 DAMAGED VANDALIZED SERICE EQUIPMENT REAR EXTERIOR AND BASEMENT.	SEQ #: 046	5201	W	LAKE	ST	37	Open
07/12/2023	EL1805	DEFECTIVE DISTRIBUTION	Replace defective distribution equipment. (14E-4-408.30, 14E-4-408.36, 14E-4-408.37, 14E-4-408.38, 14E-4-408.39, 14E-4-408.40, 14E-4-408.41)	348 ELECTRICAL PANEL LOCATED AT REAR EXTERION. PANEL LOCATED ON BASEMENT STAIRS. ENSURE DISTRIBUTION IN APPROVED CONDITION. DANGEROUS AND HAZARDOUS	SEQ #: 048	5201	W	LAKE	ST	37	Open
07/12/2023	EL1805	DEFECTIVE DISTRIBUTION	Replace defective distribution equipment. (14E-4-408.30, 14E-4-408.36, 14E-4-408.37, 14E-4-408.38, 14E-4-408.39, 14E-4-408.40, 14E-4-408.41)	348 ELECTRICAL PANEL LOCATED AT REAR EXTERION. PANEL LOCATED ON BASEMENT STAIRS. ENSURE DISTRIBUTION IN APPROVED CONDITION. DANGEROUS AND HAZARDOUS	SEQ #: 066	5201	W	LAKE	ST	37	Open
07/12/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	336-38 NO VISIBLE WATER GROUND. ENSURE SERVICE GROUNDED IN APPROVED MANNER. DANGEROUS AND HAZARDOUS	SEQ #: 033	5201	W	LAKE	ST	37	Open
07/12/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	336-38 NO VISIBLE WATER GROUND. ENSURE SERVICE GROUNDED IN APPROVED MANNER. DANGEROUS AND HAZARDOUS	SEQ #: 041	5201	W	LAKE	ST	37	Open
07/12/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	348 NO VISIBLE WATER GROUND. ENSURE SERVICE GROUNDED IN APPROVED MANNER. DANGEROUS AND HAZARDOUS	SEQ #: 049	5201	W	LAKE	ST	37	Open
07/12/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	348 NO VISIBLE WATER GROUND. ENSURE SERVICE GROUNDED IN APPROVED MANNER. DANGEROUS AND HAZARDOUS	SEQ #: 068	5201	W	LAKE	ST	37	Open
07/12/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	36-38 NO VISIBLE WATER GROUND. ENSURE SERVICE GROUNDED IN APPROVED MANNER. DANGEROUS AND HAZARDOUS	SEQ #: 033	5201	W	LAKE	ST	37	Open
07/12/2023	EL1817	CONTINUITY OF RACEWAYS	Provide ground continuity for electrical cable, raceway, and enclosure. (14E-3-300.10, 14E-3-300.13)	348 RACEWAYS PULLED AWAY FROM FITTINGS. LOOSE FITTINGS. VARIOUS AREAS. ENSURE GROUND CONTINUITY WHERE REQUIRED THROUGHOUT PREMISES. DANGEROUS AND HAZARDOUS	SEQ #: 054	5201	W	LAKE	ST	37	Open
07/12/2023	EL1817	CONTINUITY OF RACEWAYS	Provide ground continuity for electrical cable, raceway, and enclosure. (14E-3-300.10, 14E-3-300.13)	348 RACEWAYS PULLED AWAY FROM FITTINGS. LOOSE FITTINGS. VARIOUS AREAS. ENSURE GROUND CONTINUITY WHERE REQUIRED THROUGHOUT PREMISES. DANGEROUS AND HAZARDOUS	SEQ #: 062	5201	W	LAKE	ST	37	Open
07/12/2023	EL1822	EXPOSED WIRING FIXTURES	Remove exposed wiring at light fixture. (14E-4-410.48)	348 OPEN WIRING VARIOUS AREAS THROUGHOUT. REMOVE WHERE REQUIRED. DANGEROUS AND HAZARDOUS	SEQ #: 053	5201	W	LAKE	ST	37	Open

07/12/2023	EL1822	EXPOSED WIRING FIXTURES	Remove exposed wiring at light fixture. (14E-4-410.48)	348 OPEN WIRING VARIOUS AREAS THROUGHOUT. REMOVE WHERE REQUIRED. DANGEROUS AND HAZARDOUS	SEQ #: 072□	5201	W	LAKE	ST	37	Open
07/12/2023	EL1827	RESTORE EXIT AND EM	and related equipment to working condition. (14E-7-700.6)	336-38 UNMAINTAINED EMERGENCY LIGHTING SYSTEM. DANGEROUS AND HAZARDOUS	SEQ #: 042□	5201	W	LAKE	ST	37	Open
07/12/2023	EL1827	RESTORE EXIT AND EM	and related equipment to working condition. (14E-7-700.6)	336-38 UNMAINTAINED EMERGENCY LIGHTING SYSTEM. DANGEROUS AND HAZARDOUS	SEQ #: 050□	5201	W	LAKE	ST	37	Open
07/12/2023	EL1827	RESTORE EXIT AND EM	Restore exit and emergency lighting system and related equipment to working condition. (14E-7-700.6)	348 UNAPPROVED, DAMAGED, INOPERABLE, INSUFFICIENT EMERGENCY LIGHTING SYSTEM. DANGEROUS AND HAZARDOUS	SEQ #: 028□	5201	W	LAKE	ST	37	Open
07/12/2023	EL1827	RESTORE EXIT AND EM	Restore exit and emergency lighting system and related equipment to working condition. (14E-7-700.6)	348 UNAPPROVED, DAMAGED, INOPERABLE, INSUFFICIENT EMERGENCY LIGHTING SYSTEM. DANGEROUS AND HAZARDOUS	SEQ #: 054□	5201	W	LAKE	ST	37	Open
07/12/2023	EL1827	RESTORE EXIT AND EM	and related equipment to working condition. (14E-7-700.6)	36-38 UNMAINTAINED EMERGENCY LIGHTING SYSTEM. DANGEROUS AND HAZARDOUS	SEQ #: 042□	5201	W	LAKE	ST	37	Open
07/12/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	WHERE REQUIRED. DANGEROUS AND HAZARDOUS	SEQ #: 050□	5201	W	LAKE	ST	37	Open
07/12/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	WHERE REQUIRED. DANGEROUS AND HAZARDOUS	SEQ #: 069□	5201	W	LAKE	ST	37	Open
07/12/2023	EL1833	SECURE RACEWAY	Strap and secure raceway and armored cable. (14E-1-110.13(a))	336-38 UNSUPPORTED RACEWAYS N/W STORE. SECURE WHERE REQUIRED.	SEQ #: 040□	5201	W	LAKE	ST	37	Open
07/12/2023	EL1833	SECURE RACEWAY	Strap and secure raceway and armored cable. (14E-1-110.13(a))	336-38 UNSUPPORTED RACEWAYS N/W STORE. SECURE WHERE REQUIRED.	SEQ #: 048□	5201	W	LAKE	ST	37	Open
07/12/2023	EL1833	SECURE RACEWAY	Strap and secure raceway and armored cable. (14E-1-110.13(a))	336-48 UNSUPPORTED FALLING RACEWAYS THROUGHOUT EXTERIOR. SECURE WHERE REQUIRED. DANGEROUS AND HAZARDOUS	SEQ #: 060□	5201	W	LAKE	ST	37	Open
07/12/2023	EL1833	SECURE RACEWAY	Strap and secure raceway and armored cable. (14E-1-110.13(a))	336-48 UNSUPPORTED FALLING RACEWAYS THROUGHOUT EXTERIOR. SECURE WHERE REQUIRED. DANGEROUS AND HAZARDOUS	SEQ #: 068□	5201	W	LAKE	ST	37	Open
07/12/2023	EL1833	SECURE RACEWAY	Strap and secure raceway and armored cable. (14E-1-110.13(a))	36-38 UNSUPPORTED RACEWAYS N/W STORE. SECURE WHERE REQUIRED.	SEQ #: 040□	5201	W	LAKE	ST	37	Open
07/12/2023	EL1834	LISTED FOR USE TEMP & LOCATION	temperature and location.(14E-1-110.2(B), 14E-1-110.11)	FITTINGS, RACEWAYS MUST BE SUITABLE FOR WET LOCATIONS.	SEQ #: 041□	5201	W	LAKE	ST	37	Open
07/12/2023	EL1834	LISTED FOR USE TEMP & LOCATION	temperature and location.(14E-1-110.2(B), 14E-1-110.11)	FITTINGS, RACEWAYS MUST BE SUITABLE FOR WET LOCATIONS.	SEQ #: 049□	5201	W	LAKE	ST	37	Open
07/12/2023	EL1834	LISTED FOR USE TEMP & LOCATION	Electrical equipment shall be listed for use, temperature and location.(14E-1-110.2(B), 14E-1-110.11)	336-38 EXTERIOR LIGHT FIXTURES MUST BE SUITABLE FOR USE AND INSTLALED IN APPROVED MANNER.	SEQ #: 035□	5201	W	LAKE	ST	37	Open
07/12/2023	EL1834	LISTED FOR USE TEMP & LOCATION	Electrical equipment shall be listed for use, temperature and location.(14E-1-110.2(B), 14E-1-110.11)	336-38 EXTERIOR LIGHT FIXTURES MUST BE SUITABLE FOR USE AND INSTLALED IN APPROVED MANNER.	SEQ #: 043□	5201	W	LAKE	ST	37	Open
07/12/2023	EL1834	LISTED FOR USE TEMP & LOCATION	temperature and location.(14E-1-110.2(B), 14E-1-110.11)	FITTINGS, RACEWAYS MUST BE SUITABLE FOR WET LOCATIONS.	SEQ #: 059□	5201	W	LAKE	ST	37	Open
07/12/2023	EL1834	LISTED FOR USE TEMP & LOCATION	temperature and location.(14E-1-110.2(B), 14E-1-110.11)	FITTINGS, RACEWAYS MUST BE SUITABLE FOR WET LOCATIONS.	SEQ #: 067□	5201	W	LAKE	ST	37	Open
07/12/2023	EL1834	LISTED FOR USE TEMP & LOCATION	temperature and location.(14E-1-110.2(B), 14E-1-110.11)	RACEWAYS MUST BE SUITABLE FOR WET LOCATOINS.	SEQ #: 052□	5201	W	LAKE	ST	37	Open
07/12/2023	EL1834	LISTED FOR USE TEMP & LOCATION	temperature and location.(14E-1-110.2(B), 14E-1-110.11)	RACEWAYS MUST BE SUITABLE FOR WET LOCATOINS.	SEQ #: 071□	5201	W	LAKE	ST	37	Open
07/12/2023	EL1834	LISTED FOR USE TEMP & LOCATION	temperature and location.(14E-1-110.2(B), 14E-1-110.11)	FITTINGS, RACEWAYS MUST BE SUITABLE FOR WET LOCATIONS.	SEQ #: 041□	5201	W	LAKE	ST	37	Open
07/12/2023	EL1834	LISTED FOR USE TEMP & LOCATION	temperature and location.(14E-1-110.2(B), 14E-1-110.11)	SUITABLE FOR USE AND INSTLALED IN APPROVED MANNER.	SEQ #: 035□	5201	W	LAKE	ST	37	Open
07/12/2023	EL1839	CORRODED CONDUIT & EQUIP	Replace rusted, deteriorated, or corroded conduit, cabinet, electrical box, or fitting. (14E-3-300.13, 14E-1-110.12(b))	348 CORRODED CONDUIT, BOXES, EQUIPMENT VARIOUS AREAS. REMOVE WHERE REQUIRED.	SEQ #: 032□	5201	W	LAKE	ST	37	Open

07/12/2023	EL1839	CORRODED CONDUIT & EQUIP	Replace rusted, deteriorated, or corroded conduit, cabinet, electrical box, or fitting. (14E-3-300.13, 14E-1-110.12(b))	348 CORRODED CONDUIT, BOXES, EQUIPMENT VARIOUS AREAS. REMOVE WHERE REQUIRED.	SEQ #: 058□	5201	W	LAKE	ST	37	Open
06/21/2023	EL1822	EXPOSED WIRING FIXTURES	Remove exposed wiring at light fixture. (14E-4-410.48)		SEQ #: 006□	125	W	75TH	ST	06	Open
06/16/2023	EL1822	EXPOSED WIRING FIXTURES	Remove exposed wiring at light fixture. (14E-4-410.48)		SEQ #: 005□	6230	S	ASHLAND	AVE	16	Open
06/16/2023	EL1822	EXPOSED WIRING FIXTURES	Remove exposed wiring at light fixture. (14E-4-410.48)		SEQ #: 012□	6230	S	ASHLAND	AVE	16	Open
06/16/2023	EL1827	RESTORE EXIT AND EM	and related equipment to working condition. (14E-7-700.6)		SEQ #: 007□	6230	S	ASHLAND	AVE	16	Open
06/16/2023	EL1827	RESTORE EXIT AND EM	and related equipment to working condition. (14E-7-700.6)		SEQ #: 014□	6230	S	ASHLAND	AVE	16	Open
07/19/2023	EL1827	RESTORE EXIT AND EM	and related equipment to working condition. (14E-7-700.6)		SEQ #: 011□	13355	S	INDIANA	AVE	09	Open
07/07/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)		SEQ #: 015□	7357	S	RACINE	AVE	17	Open
07/07/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)		SEQ #: 018□	7357	S	RACINE	AVE	17	Open
07/07/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)		SEQ #: 016□	7357	S	RACINE	AVE	17	Open
07/07/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)		SEQ #: 019□	7357	S	RACINE	AVE	17	Open
07/07/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)		SEQ #: 017□	7357	S	RACINE	AVE	17	Open
07/07/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)		SEQ #: 020□	7357	S	RACINE	AVE	17	Open
07/07/2023	EL1833	SECURE RACEWAY	Strap and secure raceway and armored cable. (14E-1-110.13(a))		SEQ #: 007□	7357	S	RACINE	AVE	17	Open
07/07/2023	EL1833	SECURE RACEWAY	Strap and secure raceway and armored cable. (14E-1-110.13(a))		SEQ #: 010□	7357	S	RACINE	AVE	17	Open
07/15/2023	EL1839	CORRODED CONDUIT & EQUIP	Replace rusted, deteriorated, or corroded conduit, cabinet, electrical box, or fitting. (14E-3-300.13, 14E-1-110.12(b))	REPLACE ALL CORRODED CONDUIT , BX , CABINET AND ELECTRICAL BOXES THROUGHOUT BASEMENT.	SEQ #: 006□	2234	W	TAYLOR	ST	28	Open
07/15/2023	EL1839	CORRODED CONDUIT & EQUIP	Replace rusted, deteriorated, or corroded conduit, cabinet, electrical box, or fitting. (14E-3-300.13, 14E-1-110.12(b))	REPLACE ALL CORRODED CONDUIT , BX , CABINET AND ELECTRICAL BOXES THROUGHOUT BASEMENT.	SEQ #: 029□	2234	W	TAYLOR	ST	28	Open
07/18/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	NO GROUND TO MAIN WATER	SEQ #: 022□	2234	W	TAYLOR	ST	28	Open
07/18/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	NO GROUND TO MAIN WATER	SEQ #: 025□	2234	W	TAYLOR	ST	28	Open
07/18/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	THROUGHOUT BASEMENT	SEQ #: 0	2234	W	TAYLOR	ST	28	Open
07/18/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	THROUGHOUT BASEMENT	SEQ #: 024□ EQ #: 0	2234	W	TAYLOR	ST	28	Open
07/18/2023	EL1833	SECURE RACEWAY	Strap and secure raceway and armored cable. (14E-1-110.13(a))	SUPPORT PIPE ABOVE FRONT AWNING	SEQ #: 014□	2234	W	TAYLOR	ST	28	Open
07/18/2023	EL1833	SECURE RACEWAY	Strap and secure raceway and armored cable. (14E-1-110.13(a))	SUPPORT PIPE ABOVE FRONT AWNING	SEQ #: 015□	2234	W	TAYLOR	ST	28	Open
07/18/2023	EL1833	SECURE RACEWAY	Strap and secure raceway and armored cable. (14E-1-110.13(a))	SUPPORT PIPE ABOVE FRONT AWNING	SEQ #: 017□	2234	W	TAYLOR	ST	28	Open
07/18/2023	EL1833	SECURE RACEWAY	Strap and secure raceway and armored cable. (14E-1-110.13(a))	SUPPORT PIPE ABOVE FRONT AWNING	SEQ #: 018□	2234	W	TAYLOR	ST	28	Open
07/18/2023	EL1834	LISTED FOR USE TEMP & LOCATION	temperature and location.(14E-1-110.2(B), 14E-1-110.11)	LED ON FRONT AWNING NOT RATED FOR EXTERIOR USE	SEQ #: 004□	2234	W	TAYLOR	ST	28	Open
07/18/2023	EL1834	LISTED FOR USE TEMP & LOCATION	temperature and location.(14E-1-110.2(B), 14E-1-110.11)	LED ON FRONT AWNING NOT RATED FOR EXTERIOR USE	SEQ #: 027□	2234	W	TAYLOR	ST	28	Open
07/19/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)		SEQ #: 002□	5133	N	OAK PARK	AVE	41	Open

07/19/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)		SEQ #: 005☐	5133	N	OAK PARK	AVE	41	Open
07/07/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	REMOVE AND/OR COVER EXPOSED WIRING THROUGHOUT.	SEQ #: 021☐	6405	S	CARPENTER	ST	16	Open
07/07/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	REMOVE AND/OR COVER EXPOSED WIRING THROUGHOUT.	SEQ #: 036☐	6405	S	CARPENTER	ST	16	Open
07/07/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)		SEQ #: 016☐	6405	S	CARPENTER	ST	16	Open
07/07/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)		SEQ #: 031☐	6405	S	CARPENTER	ST	16	Open
07/07/2023	EL1833	SECURE RACEWAY	Strap and secure raceway and armored cable. (14E-1-110.13(a))		SEQ #: 023☐	6405	S	CARPENTER	ST	16	Open
07/07/2023	EL1833	SECURE RACEWAY	Strap and secure raceway and armored cable. (14E-1-110.13(a))		SEQ #: 030☐	6405	S	CARPENTER	ST	16	Open
07/07/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	THROUGHOUT	SEQ #: 018☐	7059	S	ASHLAND	AVE	17	Open
07/07/2023	EL1833	SECURE RACEWAY	Strap and secure raceway and armored cable. (14E-1-110.13(a))	THROUGHOUT	SEQ #: 017☐	7059	S	ASHLAND	AVE	17	Open
07/25/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	1ST FLOOR - EXPOSED WIRING , MAINLY AT THE PANEL BOX WITH MISSING COVERS	SEQ #: 009☐ INTERIOR:001 :	3615	W	OGDEN	AVE	24	Open
08/01/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	Main service panel is open and damaged. Ensure service in approved condition. Dangerous and Hazardous	SEQ #: 010☐	3615	W	OGDEN	AVE	24	Open
08/01/2023	EL1805	DEFECTIVE DISTRIBUTION	4-408.30, 14E-4-408.36, 14E-4-408.37, 14E-4-408.38, 14E-4-408.39, 14E-4-408.40, 14E-4-408.41)	Distribution panels open and damaged. Ensure distribution throughout in approved condition. Dangerous and Hazardous	SEQ #: 013☐	3615	W	OGDEN	AVE	24	Open
08/01/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	No visible water ground. Dangerous and Hazrdous	SEQ #: 011☐	3615	W	OGDEN	AVE	24	Open
08/01/2023	EL1817	CONTINUITY OF RACEWAYS	Provide ground continuity for electrical cable, raceway, and enclosure. (14E-3-300.10, 14E-3-300.13)	Raceways pulled apart at fittings. Raceways pulled away from boxes. Ensure ground continuity throughout. Dangerous and Hazardous	SEQ #: 022☐	3615	W	OGDEN	AVE	24	Open
08/01/2023	EL1827	RESTORE EXIT AND EM	and related equipment to working condition. (14E-7-700.6)	Emergency lighting system damaged, inoperable, insufficient. Dangerous and Hazardoua	SEQ #: 019☐	3615	W	OGDEN	AVE	24	Open
08/01/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	Open wiring various areas. Remove where required. Dangerous and Hazardous	SEQ #: 016☐	3615	W	OGDEN	AVE	24	Open
08/01/2023	EL1833	SECURE RACEWAY	Strap and secure raceway and armored cable. (14E-1-110.13(a))	Unsupported falling conduits various areas. Dangerous and Hazardous	SEQ #: 020☐	3615	W	OGDEN	AVE	24	Open
08/01/2023	EL1834	LISTED FOR USE TEMP & LOCATION	temperature and location.(14E-1-110.2(B), 14E-1-110.11)	Missing equipment covers various. Install where require. Dangerous and Hazardous	SEQ #: 029☐	3615	W	OGDEN	AVE	24	Open
08/01/2023	EL1839	CORRODED CONDUIT & EQUIP	Replace rusted, deteriorated, or corroded conduit, cabinet, electrical box, or fitting. (14E-3-300.13, 14E-1-110.12(b))	Corroded conduit, boxes, equipment throughout. Replace where required.	SEQ #: 030☐	3615	W	OGDEN	AVE	24	Open
08/01/2023	EL1880	DETERIORATED CONDUCTORS	Replace conductors with damaged or deteriorated insulation.(14E-1-110.7)	Damaged deteriorated wiring visible at open panels and boxes. Replace where required. Dangerous and Hazardous	SEQ #: 014☐	3615	W	OGDEN	AVE	24	Open
07/23/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	SUITE 403 - EXPOSED WIRING AT JUNCTION BOXES THRU-OUT.DANGEROUS AND HAZARDOUS (SEC 14X-7-703.2, 14X-7-703.5)	SEQ #: 001☐ INTERIOR:004 :	400	W	76TH	ST	06	Open
07/22/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	NORTH WALL - EXPOSED WIRING AT PANELS AND OUTLETS. MISSING PANELS. THEY ARE EXPOSED TO THE ELEMENTS, MISSING ROOF . (SEC 14X-7-703.2, 14X-7-703.5)	SEQ #: 003☐ EXTERIOR:N :	4040	W	OGDEN	AVE	22	Open
07/27/2023	EL1827	RESTORE EXIT AND EM	and related equipment to working condition. (14E-7-700.6)		SEQ #: 005☐	6852	S	ASHLAND	AVE	17	Open
07/27/2023	EL1827	RESTORE EXIT AND EM	and related equipment to working condition. (14E-7-700.6)		SEQ #: 033☐	6852	S	ASHLAND	AVE	17	Open
07/27/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	BASEMENT	SEQ #: 006☐	6852	S	ASHLAND	AVE	17	Open

07/27/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	BASEMENT	SEQ #: 034□	6852	S	ASHLAND	AVE	17	Open
07/27/2023	EL1833	SECURE RACEWAY	Strap and secure raceway and armored cable. (14E-1-110.13(a))		SEQ #: 010□	6852	S	ASHLAND	AVE	17	Open
07/27/2023	EL1833	SECURE RACEWAY	Strap and secure raceway and armored cable. (14E-1-110.13(a))		SEQ #: 038□	6852	S	ASHLAND	AVE	17	Open
08/02/2023	EL1827	RESTORE EXIT AND EM	and related equipment to working condition. (14E-7-700.6)		SEQ #: 002□	7122	S	VINCENNES	AVE	06	Open
08/02/2023	EL1827	RESTORE EXIT AND EM	and related equipment to working condition. (14E-7-700.6)		SEQ #: 018□	7122	S	VINCENNES	AVE	06	Open
08/02/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	THROUGHOUT BUILDING	SEQ #: 003□	7122	S	VINCENNES	AVE	06	Open
08/02/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	THROUGHOUT BUILDING	SEQ #: 019□	7122	S	VINCENNES	AVE	06	Open
08/02/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)		SEQ #: 001□	7122	S	VINCENNES	AVE	06	Open
08/02/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)		SEQ #: 017□	7122	S	VINCENNES	AVE	06	Open
07/26/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	46-58 Low voltage cable laying on overhead service wires at rear exterior. Dangerous and Hazardous	SEQ #: 001□	3952	W	MONROE	ST	28	Open
07/26/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	46-58 Low voltage cable laying on overhead service wires at rear exterior. Dangerous and Hazardous	SEQ #: 017□	3952	W	MONROE	ST	28	Open
07/26/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	46-58 No visible water ground. Ensure service for premises grounded in approved manner. Dangerous and Hazrdous	SEQ #: 002□	3952	W	MONROE	ST	28	Open
07/26/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	46-58 No visible water ground. Ensure service for premises grounded in approved manner. Dangerous and Hazrdous	SEQ #: 018□	3952	W	MONROE	ST	28	Open
07/26/2023	EL1817	CONTINUITY OF RACEWAYS	Provide ground continuity for electrical cable, raceway, and enclosure. (14E-3-300.10, 14E-3-300.13)	connected to boxes various. Ensure ground continuity where required. Dangerous and Hazardous	SEQ #: 012□	3952	W	MONROE	ST	28	Open
07/26/2023	EL1817	CONTINUITY OF RACEWAYS	Provide ground continuity for electrical cable, raceway, and enclosure. (14E-3-300.10, 14E-3-300.13)	connected to boxes various. Ensure ground continuity where required. Dangerous and Hazardous	SEQ #: 028□	3952	W	MONROE	ST	28	Open
07/26/2023	EL1827	RESTORE EXIT AND EM	and related equipment to working condition. (14E-7-700.6)	emergency lighting system. Dangerous and Hazardous	SEQ #: 009□	3952	W	MONROE	ST	28	Open
07/26/2023	EL1827	RESTORE EXIT AND EM	and related equipment to working condition. (14E-7-700.6)	emergency lighting system. Dangerous and Hazardous	SEQ #: 025□	3952	W	MONROE	ST	28	Open
07/26/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	Remove where required throughout. Dangerous and Hazardous	SEQ #: 011□	3952	W	MONROE	ST	28	Open
07/26/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	Remove where required throughout. Dangerous and Hazardous	SEQ #: 027□	3952	W	MONROE	ST	28	Open
07/26/2023	EL1834	LISTED FOR USE TEMP & LOCATION	temperature and location.(14E-1-110.2(B), 14E-1-110.11)	52 - Exterior light fixtures, boxes, fittings, raceways must be suitable for wet locations.	SEQ #: 014□	3952	W	MONROE	ST	28	Open
07/26/2023	EL1834	LISTED FOR USE TEMP & LOCATION	temperature and location.(14E-1-110.2(B), 14E-1-110.11)	52 - Exterior light fixtures, boxes, fittings, raceways must be suitable for wet locations.	SEQ #: 030□	3952	W	MONROE	ST	28	Open
07/26/2023	EL1834	LISTED FOR USE TEMP & LOCATION	Electrical equipment shall be listed for use, temperature and location.(14E-1-110.2(B), 14E-1-110.11)	52 - Light fixtures, boxes, fittings, raceways, devices at walk in coolers must be identified and listed for us. Dangerous and Hazardous	SEQ #: 013□	3952	W	MONROE	ST	28	Open
07/26/2023	EL1834	LISTED FOR USE TEMP & LOCATION	Electrical equipment shall be listed for use, temperature and location.(14E-1-110.2(B), 14E-1-110.11)	52 - Light fixtures, boxes, fittings, raceways, devices at walk in coolers must be identified and listed for us. Dangerous and Hazardous	SEQ #: 029□	3952	W	MONROE	ST	28	Open
07/26/2023	EL1834	LISTED FOR USE TEMP & LOCATION	Electrical equipment shall be listed for use, temperature and location.(14E-1-110.2(B), 14E-1-110.11)	52 - Lighting retrofit units visible at ceiling and fixtures throughout must be listed for use and installed in approved manner.	SEQ #: 019□	3952	W	MONROE	ST	28	Open
07/26/2023	EL1834	LISTED FOR USE TEMP & LOCATION	Electrical equipment shall be listed for use, temperature and location.(14E-1-110.2(B), 14E-1-110.11)	52 - Lighting retrofit units visible at ceiling and fixtures throughout must be listed for use and installed in approved manner.	SEQ #: 035□	3952	W	MONROE	ST	28	Open

07/26/2023	EL1834	LISTED FOR USE TEMP & LOCATION	temperature and location.(14E-1-110.2(B), 14E-1-110.11)	Install where required. Dangerous and Hazardous	SEQ #: 018□	3952	W	MONROE	ST	28	Open
07/26/2023	EL1834	LISTED FOR USE TEMP & LOCATION	temperature and location.(14E-1-110.2(B), 14E-1-110.11)	Install where required. Dangerous and Hazardous	SEQ #: 034□	3952	W	MONROE	ST	28	Open
07/26/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	panel/disconnect has unapproved cover screws. No common meter. Service disconnects appear over 5' from point of entry. 2nd floor disconnect and meter enclosures partially buried in wall. Unsupported feeder raceway to 2nd floor. Temporary overhead service splices appear to be deteriorating. Ensure service in approved condition. Dangerous and Hazardous	SEQ #: 001□	3608	W	CHICAGO	AVE	27	Open
07/26/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	panel/disconnect has unapproved cover screws. No common meter. Service disconnects appear over 5' from point of entry. 2nd floor disconnect and meter enclosures partially buried in wall. Unsupported feeder raceway to 2nd floor. Temporary overhead service splices appear to be deteriorating. Ensure service in approved condition. Dangerous and Hazardous	SEQ #: 029□	3608	W	CHICAGO	AVE	27	Open
07/26/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	No visible water ground. Ensure service grounded in approved manner. Dangerous and Hazardous	SEQ #: 002□	3608	W	CHICAGO	AVE	27	Open
07/26/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	No visible water ground. Ensure service grounded in approved manner. Dangerous and Hazardous	SEQ #: 030□	3608	W	CHICAGO	AVE	27	Open
07/26/2023	EL1817	CONTINUITY OF RACEWAYS	Provide ground continuity for electrical cable, raceway, and enclosure. (14E-3-300.10, 14E-3-300.13)	Flexible metal conduit damaged and not seated at furnace connection. Ensure ground continuity where required. Dangerous and Hazardous	SEQ #: 011□	3608	W	CHICAGO	AVE	27	Open
07/26/2023	EL1817	CONTINUITY OF RACEWAYS	Provide ground continuity for electrical cable, raceway, and enclosure. (14E-3-300.10, 14E-3-300.13)	Flexible metal conduit damaged and not seated at furnace connection. Ensure ground continuity where required. Dangerous and Hazardous	SEQ #: 039□	3608	W	CHICAGO	AVE	27	Open
07/26/2023	EL1827	RESTORE EXIT AND EM	and related equipment to working condition. (14E-7-700.6)	unapproved, unmaintained, insufficient. Dangerous and Hazardous	SEQ #: 007□	3608	W	CHICAGO	AVE	27	Open
07/26/2023	EL1827	RESTORE EXIT AND EM	and related equipment to working condition. (14E-7-700.6)	unapproved, unmaintained, insufficient. Dangerous and Hazardous	SEQ #: 035□	3608	W	CHICAGO	AVE	27	Open
07/26/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	Remove where required. Dangerous and Hazardous	SEQ #: 004□	3608	W	CHICAGO	AVE	27	Open
07/26/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	Remove where required. Dangerous and Hazardous	SEQ #: 032□	3608	W	CHICAGO	AVE	27	Open
07/26/2023	EL1833	SECURE RACEWAY	Strap and secure raceway and armored cable. (14E-1-110.13(a))	Unsupported falling raceways at 1st floor, exterior and basement. Secure where required. Dangerous and Hazardous	SEQ #: 019□	3608	W	CHICAGO	AVE	27	Open
07/26/2023	EL1833	SECURE RACEWAY	Strap and secure raceway and armored cable. (14E-1-110.13(a))	Unsupported falling raceways at 1st floor, exterior and basement. Secure where required. Dangerous and Hazardous	SEQ #: 047□	3608	W	CHICAGO	AVE	27	Open
07/26/2023	EL1834	LISTED FOR USE TEMP & LOCATION	temperature and location.(14E-1-110.2(B), 14E-1-110.11)	Exterior light fixtures, boxes, fittings, raceways must be suitable for wet locations.	SEQ #: 012□	3608	W	CHICAGO	AVE	27	Open
07/26/2023	EL1834	LISTED FOR USE TEMP & LOCATION	temperature and location.(14E-1-110.2(B), 14E-1-110.11)	Exterior light fixtures, boxes, fittings, raceways must be suitable for wet locations.	SEQ #: 040□	3608	W	CHICAGO	AVE	27	Open
07/26/2023	EL1834	LISTED FOR USE TEMP & LOCATION	temperature and location.(14E-1-110.2(B), 14E-1-110.11)	Hard pipe connection to water heater makes splice box inaccessible. Repair where required.	SEQ #: 020□	3608	W	CHICAGO	AVE	27	Open
07/26/2023	EL1834	LISTED FOR USE TEMP & LOCATION	temperature and location.(14E-1-110.2(B), 14E-1-110.11)	Hard pipe connection to water heater makes splice box inaccessible. Repair where required.	SEQ #: 048□	3608	W	CHICAGO	AVE	27	Open
07/26/2023	EL1834	LISTED FOR USE TEMP & LOCATION	temperature and location.(14E-1-110.2(B), 14E-1-110.11)	Low voltage light fixtures throughout must be listed for use and installed in approved manner.	SEQ #: 013□	3608	W	CHICAGO	AVE	27	Open
07/26/2023	EL1834	LISTED FOR USE TEMP & LOCATION	temperature and location.(14E-1-110.2(B), 14E-1-110.11)	Low voltage light fixtures throughout must be listed for use and installed in approved manner.	SEQ #: 041□	3608	W	CHICAGO	AVE	27	Open

07/26/2023	EL1834	LISTED FOR USE TEMP & LOCATION	Electrical equipment shall be listed for use, temperature and location.(14E-1-110.2(B), 14E-1-110.11)	Missing equipment covers at exterior hvac equipment. Install where required throughout premises. Dangerous and Hazardous	SEQ #: 018☐	3608	W	CHICAGO	AVE	27	Open
07/26/2023	EL1834	LISTED FOR USE TEMP & LOCATION	Electrical equipment shall be listed for use, temperature and location.(14E-1-110.2(B), 14E-1-110.11)	Missing equipment covers at exterior hvac equipment. Install where required throughout premises. Dangerous and Hazardous	SEQ #: 046☐	3608	W	CHICAGO	AVE	27	Open
07/26/2023	EL1839	CORRODED CONDUIT & EQUIP	Replace rusted, deteriorated, or corroded conduit, cabinet, electrical box, or fitting. (14E-3-300.13, 14E-1-110.12(b))	Severely corroded conduit, boxes, and equipment at basement and exterior. Replace where required throughout premises. Dangerous and Hazardous	SEQ #: 016☐	3608	W	CHICAGO	AVE	27	Open
07/26/2023	EL1839	CORRODED CONDUIT & EQUIP	Replace rusted, deteriorated, or corroded conduit, cabinet, electrical box, or fitting. (14E-3-300.13, 14E-1-110.12(b))	Severely corroded conduit, boxes, and equipment at basement and exterior. Replace where required throughout premises. Dangerous and Hazardous	SEQ #: 044☐	3608	W	CHICAGO	AVE	27	Open
07/26/2023	EL1880	DETERIORATED CONDUCTORS	Replace conductors with damaged or deteriorated insulation.(14E-1-110.7)	Damaged corroded wiring visible at open boxes at exterior and basement. Replace where required. Dangerous and Hazardous	SEQ #: 017☐	3608	W	CHICAGO	AVE	27	Open
07/26/2023	EL1880	DETERIORATED CONDUCTORS	Replace conductors with damaged or deteriorated insulation.(14E-1-110.7)	Damaged corroded wiring visible at open boxes at exterior and basement. Replace where required. Dangerous and Hazardous	SEQ #: 045☐	3608	W	CHICAGO	AVE	27	Open
07/19/2023	EL1825	SYSTEM III	Install system III emergency lighting. (14E-7-700.6, 14E-7-700.22)	THROUGHOUT	SEQ #: 015☐	103	W	112TH	ST	09	Open
07/19/2023	EL1825	SYSTEM III	Install system III emergency lighting. (14E-7-700.6, 14E-7-700.22)	THROUGHOUT	SEQ #: 028☐	103	W	112TH	ST	09	Open
07/19/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	THROUGHOUT	SEQ #: 012☐	103	W	112TH	ST	09	Open
07/19/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	THROUGHOUT	SEQ #: 025☐	103	W	112TH	ST	09	Open
07/19/2023	EL1833	SECURE RACEWAY	Strap and secure raceway and armored cable. (14E-1-110.13(a))	THROUGHOUT	SEQ #: 017☐	103	W	112TH	ST	09	Open
07/19/2023	EL1833	SECURE RACEWAY	Strap and secure raceway and armored cable. (14E-1-110.13(a))	THROUGHOUT	SEQ #: 030☐	103	W	112TH	ST	09	Open
07/19/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	THROUGHOUT	SEQ #: 019☐	139	W	112TH	ST	09	Open
07/19/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	SERVICE HEAD IS MISSING/BROKEN	SEQ #: 013☐	28	W	113TH	PL	09	Open
07/19/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	THROUGHOUT	SEQ #: 017☐	28	W	113TH	PL	09	Open
07/26/2023	EL1827	RESTORE EXIT AND EM	and related equipment to working condition. (14E-7-700.6)	THROUGHOUT	SEQ #: 023☐	4102	W	MADISON	ST	28	Open
07/26/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	THROUGHOUT	SEQ #: 019☐	4102	W	MADISON	ST	28	Open
07/26/2023	EL1833	SECURE RACEWAY	Strap and secure raceway and armored cable. (14E-1-110.13(a))	THROUGHOUT	SEQ #: 021☐	4102	W	MADISON	ST	28	Open
07/26/2023	EL1834	LISTED FOR USE TEMP & LOCATION	temperature and location.(14E-1-110.2(B), 14E-1-110.11)	FIXTURES UNDER AWNING	SEQ #: 016☐	4102	W	MADISON	ST	28	Open
07/26/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	PIPES NOT CONNECTED PROPERLY AND NEED SUPPORT. IN BACK OF BULDING	SEQ #: 018☐	5467	W	CHICAGO	AVE	37	Open
07/26/2023	EL1817	CONTINUITY OF RACEWAYS	raceway, and enclosure. (14E-3-300.10, 14E-3-300.13)	THROUGH	SEQ #: 016☐	5467	W	CHICAGO	AVE	37	Open
07/26/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	THROUGHOUT	SEQ #: 021☐	5467	W	CHICAGO	AVE	37	Open
07/26/2023	EL1833	SECURE RACEWAY	Strap and secure raceway and armored cable. (14E-1-110.13(a))	THROUGHOUT	SEQ #: 017☐	5467	W	CHICAGO	AVE	37	Open
07/26/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	ALL LB'S ARE IN THE GROUND. PANEL COVERS MISSING.	SEQ #: 022☐	617	N	CICERO	AVE	28	Open
07/26/2023	EL1803	DEFECTIVE METER EQUIPMENT	Replace defective meter socket. (14E-2-230.62,14E-2-230.66,14E-3-312.5)	IN BACK OF BUILDING.	SEQ #: 027☐	617	N	CICERO	AVE	28	Open
07/26/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	NO GEC TO WATER MAIN TO ALL PANELS.	SEQ #: 023☐	617	N	CICERO	AVE	28	Open

07/26/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	THROUGHOUT	SEQ #: 025□	617	N	CICERO	AVE	28	Open
07/26/2023	EL1833	SECURE RACEWAY	Strap and secure raceway and armored cable. (14E-1-110.13(a))	THROUGHOUT	SEQ #: 026□	617	N	CICERO	AVE	28	Open
07/28/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	Service eye plate appears to be deteriorating.	SEQ #: 001□	5311	S	NAGLE	AVE	23	Open
07/28/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	Service eye plate appears to be deteriorating.	SEQ #: 002□	5311	S	NAGLE	AVE	23	Open
07/28/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	entrance cables. Deteriorated service raceways. Deteriorated overhead service splices. Ensure services in approved condition. Dangerous and Hazardous	SEQ #: 001□	6124	S	DR MARTIN L KING JR	DR	20	Open
07/28/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	entrance cables. Deteriorated service raceways. Deteriorated overhead service splices. Ensure services in approved condition. Dangerous and Hazardous	SEQ #: 008□	6124	S	DR MARTIN L KING JR	DR	20	Open
07/28/2023	EL1833	SECURE RACEWAY	Strap and secure raceway and armored cable. (14E-1-110.13(a))	areas. Secure where required. Dangerous and Hazardous	SEQ #: 005□	6124	S	DR MARTIN L KING JR	DR	20	Open
07/28/2023	EL1833	SECURE RACEWAY	Strap and secure raceway and armored cable. (14E-1-110.13(a))	areas. Secure where required. Dangerous and Hazardous	SEQ #: 012□	6124	S	DR MARTIN L KING JR	DR	20	Open
07/28/2023	EL1834	LISTED FOR USE TEMP & LOCATION	temperature and location.(14E-1-110.2(B), 14E-1-110.11)	Exterior light fixtures, boxes, fittings must be suitable for wet locations.	SEQ #: 006□	6124	S	DR MARTIN L KING JR	DR	20	Open
07/28/2023	EL1834	LISTED FOR USE TEMP & LOCATION	temperature and location.(14E-1-110.2(B), 14E-1-110.11)	Exterior light fixtures, boxes, fittings must be suitable for wet locations.	SEQ #: 013□	6124	S	DR MARTIN L KING JR	DR	20	Open
07/31/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	damaged and pulled loose from building. Main panel damaged, tampered with, missing excessive amount of circuit breakers. Ensure service in approved condition.	SEQ #: 020□	3051	N	KEDZIE	AVE	35	Open
07/31/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	57 Wooden service mast appears to be splitting and requiring additional support. Meter enclosure appears to be moving away from building. Ensure service in approved condition.	SEQ #: 036□	3051	N	KEDZIE	AVE	35	Open
07/31/2023	EL1805	DEFECTIVE DISTRIBUTION	4-408.30, 14E-4-408.36, 14E-4-408.37, 14E-4-408.38, 14E-4-408.39, 14E-4-408.40, 14E-4-408.41)	51 Open damaged panels. Ensure distribution in approved condition throughout. Dangerous and Hazardous	SEQ #: 022□	3051	N	KEDZIE	AVE	35	Open
07/31/2023	EL1805	DEFECTIVE DISTRIBUTION	Replace defective distribution equipment. (14E-4-408.30, 14E-4-408.36, 14E-4-408.37, 14E-4-408.38, 14E-4-408.39, 14E-4-408.40, 14E-4-408.41)	57 Panels are damaged, missing circuit breaker and have been tampered with. Ensure distribution throughout in approved condition. Dangerous and Hazardous	SEQ #: 038□	3051	N	KEDZIE	AVE	35	Open
07/31/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	grounded in approved manner. Dangreous and Hazardous	SEQ #: 021□	3051	N	KEDZIE	AVE	35	Open
07/31/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	57 No visible water ground. Dangerous and Hazardous	SEQ #: 037□	3051	N	KEDZIE	AVE	35	Open
07/31/2023	EL1827	RESTORE EXIT AND EM	Restore exit and emergency lighting system and related equipment to working condition. (14E-7-700.6)	51 Damaged, inoperable, unapproved emergency lighting system throughout premises. Dangerous and Hazardous	SEQ #: 028□	3051	N	KEDZIE	AVE	35	Open
07/31/2023	EL1827	RESTORE EXIT AND EM	and related equipment to working condition. (14E-7-700.6)	inoperable, insufficient, unmaintained. Dangerous and Hazardous	SEQ #: 040□	3051	N	KEDZIE	AVE	35	Open
07/31/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	51 Open wire various areas throughout premises. Dangerous and Hazardous	SEQ #: 024□	3051	N	KEDZIE	AVE	35	Open
07/31/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	57 Open wiring at damaged sealtight exterior vacuum/air pump. Remove where required. Dangeorous and Hazardous	SEQ #: 042□	3051	N	KEDZIE	AVE	35	Open
07/31/2023	EL1833	SECURE RACEWAY	Strap and secure raceway and armored cable. (14E-1-110.13(a))	51 Unsupported falling raceways throughout. Dangerous and Hazardous	SEQ #: 025□	3051	N	KEDZIE	AVE	35	Open
07/31/2023	EL1834	LISTED FOR USE TEMP & LOCATION	temperature and location.(14E-1-110.2(B), 14E-1-110.11)	51 Missing equipment covers various areas. Dangerous and Hazardous	SEQ #: 029□	3051	N	KEDZIE	AVE	35	Open

07/31/2023	EL1834	LISTED FOR USE TEMP & LOCATION	Electrical equipment shall be listed for use, temperature and location.(14E-1-110.2(B), 14E-1-110.11)	57 Electricla system subject to damage due to collapsing roof and related damage at adjacenet part of building. Dangerous and Hazardous	SEQ #: 051☐	3051	N	KEDZIE	AVE	35	Open
07/31/2023	EL1834	LISTED FOR USE TEMP & LOCATION	temperature and location.(14E-1-110.2(B), 14E-1-110.11)	57 Exterior light fixtures, boxes, fittings must be suitable for wet locations.	SEQ #: 043☐	3051	N	KEDZIE	AVE	35	Open
07/31/2023	EL1834	LISTED FOR USE TEMP & LOCATION	temperature and location.(14E-1-110.2(B), 14E-1-110.11)	must be identified for usa and suitable for wet locations.	SEQ #: 044☐	3051	N	KEDZIE	AVE	35	Open
07/31/2023	EL1880	DETERIORATED CONDUCTORS	Replace conductors with damaged or deteriorated insulation.(14E-1-110.7)	51 Damaged wiring visible at open panels and boxes throughout. Dangerous and Hazardous	SEQ #: 032☐	3051	N	KEDZIE	AVE	35	Open
08/01/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	Main electrical service equipment appears unmaintained with signs of disrepair. Ensure serivce in approved condition.	SEQ #: 001☐	2432	W	63RD	ST	16	Open
08/01/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	Main electrical service equipment appears unmaintained with signs of disrepair. Ensure serivce in approved condition.	SEQ #: 016☐	2432	W	63RD	ST	16	Open
08/01/2023	EL1805	DEFECTIVE DISTRIBUTION	Replace defective distribution equipment. (14E-4-408.30, 14E-4-408.36, 14E-4-408.37, 14E-4-408.38, 14E-4-408.39, 14E-4-408.40, 14E-4-408.41)	Distribution equipment throughout deteriorated, loose covers, covered with cruf. Ensure distribution equipment in approved condition throughout. Dangerous and Hazardous	SEQ #: 003☐	2432	W	63RD	ST	16	Open
08/01/2023	EL1805	DEFECTIVE DISTRIBUTION	Replace defective distribution equipment. (14E-4-408.30, 14E-4-408.36, 14E-4-408.37, 14E-4-408.38, 14E-4-408.39, 14E-4-408.40, 14E-4-408.41)	Distribution equipment throughout deteriorated, loose covers, covered with cruf. Ensure distribution equipment in approved condition throughout. Dangerous and Hazardous	SEQ #: 018☐	2432	W	63RD	ST	16	Open
08/01/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	No visible water ground. Ensure service grounded in approved manner. Dangerous and Hazardous	SEQ #: 002☐	2432	W	63RD	ST	16	Open
08/01/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	No visible water ground. Ensure service grounded in approved manner. Dangerous and Hazardous	SEQ #: 017☐	2432	W	63RD	ST	16	Open
08/01/2023	EL1827	RESTORE EXIT AND EM	Restore exit and emergency lighting system and related equipment to working condition. (14E-7-700.6)	Inoperable, unmaintained, insufficient emergency lighting system at premises. Dangerous and Hazardous	SEQ #: 005☐	2432	W	63RD	ST	16	Open
08/01/2023	EL1827	RESTORE EXIT AND EM	Restore exit and emergency lighting system and related equipment to working condition. (14E-7-700.6)	Inoperable, unmaintained, insufficient emergency lighting system at premises. Dangerous and Hazardous	SEQ #: 020☐	2432	W	63RD	ST	16	Open
08/01/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	Open wiring rear area at mechanical equipment and cooler light fixtures. Remove where required. Dangerous and Hazardous	SEQ #: 007☐	2432	W	63RD	ST	16	Open
08/01/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	Open wiring rear area at mechanical equipment and cooler light fixtures. Remove where required. Dangerous and Hazardous	SEQ #: 022☐	2432	W	63RD	ST	16	Open
08/01/2023	EL1833	SECURE RACEWAY	Strap and secure raceway and armored cable. (14E-1-110.13(a))	Unsuupported raceways various.	SEQ #: 038☐	2432	W	63RD	ST	16	Open
08/01/2023	EL1834	LISTED FOR USE TEMP & LOCATION	Electrical equipment shall be listed for use, temperature and location.(14E-1-110.2(B), 14E-1-110.11)	Front sign structure not securely chained to building. Lower chains not secure. Ensure sign in approved condition. Repair where required throughout.	SEQ #: 019☐	2432	W	63RD	ST	16	Open
08/01/2023	EL1834	LISTED FOR USE TEMP & LOCATION	Electrical equipment shall be listed for use, temperature and location.(14E-1-110.2(B), 14E-1-110.11)	Front sign structure not securely chained to building. Lower chains not secure. Ensure sign in approved condition. Repair where required throughout.	SEQ #: 034☐	2432	W	63RD	ST	16	Open
08/01/2023	EL1834	LISTED FOR USE TEMP & LOCATION	Electrical equipment shall be listed for use, temperature and location.(14E-1-110.2(B), 14E-1-110.11)	Light fixtures, boxes, fittings, raceways at coolers must be identified for use and suitable for wet locations. Dangerous and Hazardous	SEQ #: 013☐	2432	W	63RD	ST	16	Open
08/01/2023	EL1834	LISTED FOR USE TEMP & LOCATION	Electrical equipment shall be listed for use, temperature and location.(14E-1-110.2(B), 14E-1-110.11)	Light fixtures, boxes, fittings, raceways at coolers must be identified for use and suitable for wet locations. Dangerous and Hazardous	SEQ #: 028☐	2432	W	63RD	ST	16	Open
08/01/2023	EL1834	LISTED FOR USE TEMP & LOCATION	Electrical equipment shall be listed for use, temperature and location.(14E-1-110.2(B), 14E-1-110.11)	Neon signage at front window area not installed in approved manner. Repair where requiried. Dangerous and Hazardous.	SEQ #: 011☐	2432	W	63RD	ST	16	Open

08/01/2023	EL1834	LISTED FOR USE TEMP & LOCATION	Electrical equipment shall be listed for use, temperature and location.(14E-1-110.2(B), 14E-1-110.11)	Neon signage at front window area not installed in approved manner. Repair where required. Dangerous and Hazardous.	SEQ #: 026□	2432	W	63RD	ST	16	Open
08/01/2023	EL1839	CORRODED CONDUIT & EQUIP	Replace rusted, deteriorated, or corroded conduit, cabinet, electrical box, or fitting. (14E-3-300.13, 14E-1-110.12(b))	Corroded equipment various areas. Replace where required.	SEQ #: 018□	2432	W	63RD	ST	16	Open
08/01/2023	EL1839	CORRODED CONDUIT & EQUIP	Replace rusted, deteriorated, or corroded conduit, cabinet, electrical box, or fitting. (14E-3-300.13, 14E-1-110.12(b))	Corroded equipment various areas. Replace where required.	SEQ #: 033□	2432	W	63RD	ST	16	Open
08/03/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	Overhead service cables appear damaged at drip loop splice. Service cables within reach of 2nd floor rear window. Dangerous and Hazardous	SEQ #: 009□	8529	S	CARPENTER	ST	17	Open
08/07/2023	EL1834	LISTED FOR USE TEMP & LOCATION	temperature and location.(14E-1-110.2(B), 14E-1-110.11)	Exterior light fixtures, boxes, fittings, raceways must be suitable for wet location.	SEQ #: 016□	8529	S	CARPENTER	ST	17	Open
07/24/2023	EL1827	RESTORE EXIT AND EM	and related equipment to working condition. (14E-7-700.6)	INTERIOR HALLWAY	SEQ #: 012□	4200	W	WASHINGTON	BLVD	28	Open
08/08/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	head. Overhead service drop pulled loose from building. Exterior service raceway deteriorated and missing supports. Electrical panels open, deteriorated and damaged. Meter enclosures deteriorated, damaged, unapproved covers.. Missing meter. Ensure service in approved condition. Dangerous and Hazardous	SEQ #: 011□	6441	S	ABERDEEN	ST	16	Open
08/08/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	No visible water ground. Ensure service in approved condition. Dangerous and Hazardous	SEQ #: 013□	6441	S	ABERDEEN	ST	16	Open
08/08/2023	EL1817	CONTINUITY OF RACEWAYS	Provide ground continuity for electrical cable, raceway, and enclosure. (14E-3-300.10, 14E-3-300.13)	Raceway not connected to furnace at basement. Ensure ground continuity where required throughout. Dangerous and Hazardous	SEQ #: 020□	6441	S	ABERDEEN	ST	16	Open
08/08/2023	EL1833	SECURE RACEWAY	Strap and secure raceway and armored cable. (14E-1-110.13(a))	Unsupported conduits basement. Ensure raceways supported where required throughout premises.	SEQ #: 014□	6441	S	ABERDEEN	ST	16	Open
08/08/2023	EL1834	LISTED FOR USE TEMP & LOCATION	Electrical equipment shall be listed for use, temperature and location.(14E-1-110.2(B), 14E-1-110.11)	be suitable for wet locations. Interior rated light switch used at rear porch. Dangerous and Hazardous	SEQ #: 017□	6441	S	ABERDEEN	ST	16	Open
08/08/2023	EL1880	DETERIORATED CONDUCTORS	Replace conductors with damaged or deteriorated insulation.(14E-1-110.7)	Wiring hanging out of panels appears possibly damaged. Replace where required throughout premises.	SEQ #: 016□	6441	S	ABERDEEN	ST	16	Open
08/03/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	Exterior door to main electrical disconnect equipment missing. Main service equipment has been subject to weather for unknown period of time. Ensure equipment in approved condition via inspection and report. Dangerous and Hazardous	SEQ #: 001□	6610	S	KENWOOD	AVE	20	Open
08/03/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	Exterior door to main electrical disconnect equipment missing. Main service equipment has been subject to weather for unknown period of time. Ensure equipment in approved condition via inspection and report. Dangerous and Hazardous	SEQ #: 027□	6610	S	KENWOOD	AVE	20	Open
08/03/2023	EL1817	CONTINUITY OF RACEWAYS	Provide ground continuity for electrical cable, raceway, and enclosure. (14E-3-300.10, 14E-3-300.13)	Conduits pulle apart at fittings at exteior. Repair and ensure ground continuity where required throughout premises. Dangerous and Hazardous	SEQ #: 007□	6610	S	KENWOOD	AVE	20	Open
08/03/2023	EL1817	CONTINUITY OF RACEWAYS	Provide ground continuity for electrical cable, raceway, and enclosure. (14E-3-300.10, 14E-3-300.13)	Conduits pulle apart at fittings at exteior. Repair and ensure ground continuity where required throughout premises. Dangerous and Hazardous	SEQ #: 033□	6610	S	KENWOOD	AVE	20	Open
08/03/2023	EL1827	RESTORE EXIT AND EM	Restore exit and emergency lighting system and related equipment to working condition. (14E-7-700.6)	Unapproved emergency lighting system at rear exterior stair / porch areas. Dangerous and Hazardous	SEQ #: 004□	6610	S	KENWOOD	AVE	20	Open
08/03/2023	EL1827	RESTORE EXIT AND EM	Restore exit and emergency lighting system and related equipment to working condition. (14E-7-700.6)	Unapproved emergency lighting system at rear exterior stair / porch areas. Dangerous and Hazardous	SEQ #: 030□	6610	S	KENWOOD	AVE	20	Open

08/03/2023	EL1828	UNAPPROVED EM	from emergency lighting system. (14E-7-700.63)	THROUGHOUT	SEQ #: 040□	6610	S	KENWOOD	AVE	20	Open
08/03/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	Exposed underground cable at missing front court yard lamp post locations. Open wire at N/E 1st floor apartment. Remove where required. Dangerous and Hazardous	SEQ #: 006□	6610	S	KENWOOD	AVE	20	Open
08/03/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	Exposed underground cable at missing front court yard lamp post locations. Open wire at N/E 1st floor apartment. Remove where required. Dangerous and Hazardous	SEQ #: 032□	6610	S	KENWOOD	AVE	20	Open
08/03/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	THROUGHOUT	SEQ #: 036□	6610	S	KENWOOD	AVE	20	Open
08/11/2023	EL1827	RESTORE EXIT AND EM	and related equipment to working condition. (14E-7-700.6)		SEQ #: 019□	4351	S	COTTAGE GROVE	AVE	04	Open
08/11/2023	EL1827	RESTORE EXIT AND EM	and related equipment to working condition. (14E-7-700.6)		SEQ #: 020□	4351	S	COTTAGE GROVE	AVE	04	Open
08/11/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)		SEQ #: 020□	4351	S	COTTAGE GROVE	AVE	04	Open
08/11/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)		SEQ #: 021□	4351	S	COTTAGE GROVE	AVE	04	Open
08/11/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	DETERIORATED WIRES ON LOAD SIDE OF SERVICE, NO PUBLIC METER.	SEQ #: 013□	4137	W	CORNELIA	AVE	30	Open
08/11/2023	EL1803	DEFECTIVE METER EQUIPMENT	Replace defective meter socket. (14E-2-230.62,14E-2-230.66,14E-3-312.5)	REPLACE DEFECTIVE METER SOCKET.	SEQ #: 014□	4137	W	CORNELIA	AVE	30	Open
08/11/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)		SEQ #: 016□	4137	W	CORNELIA	AVE	30	Open
08/11/2023	EL1817	CONTINUITY OF RACEWAYS	raceway, and enclosure. (14E-3-300.10, 14E-3-300.13)		SEQ #: 019□	4137	W	CORNELIA	AVE	30	Open
08/11/2023	EL1825	SYSTEM III	Install system III emergency lighting. (14E-7-700.6, 14E-7-700.22)		SEQ #: 030□	4137	W	CORNELIA	AVE	30	Open
08/11/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	THROUGHOUT	SEQ #: 020□	4137	W	CORNELIA	AVE	30	Open
08/11/2023	EL1833	SECURE RACEWAY	Strap and secure raceway and armored cable. (14E-1-110.13(a))	THROUGHOUT	SEQ #: 022□	4137	W	CORNELIA	AVE	30	Open
08/11/2023	EL1864	SERVICE DROP OUT OF REACH	Relocate service drop conductors out of normal reach.(14E-2-230.24)		SEQ #: 026□	4137	W	CORNELIA	AVE	30	Open
08/14/2023	EL1825	SYSTEM III	Install system III emergency lighting. (14E-7-700.6, 14E-7-700.22)	THROUGHOUT WHERE NEEDED STAIRWAY FRONT AND BACK INTERIOR.	SEQ #: 023□	5308	S	PAULINA	ST	16	Open
08/14/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	THROUGHOUT	SEQ #: 025□	5308	S	PAULINA	ST	16	Open
08/14/2023	EL1834	LISTED FOR USE TEMP & LOCATION	temperature and location.(14E-1-110.2(B), 14E-1-110.11)	CONNECTORS OUTSIDE ARE SET SCREW.	SEQ #: 022□	5308	S	PAULINA	ST	16	Open
08/24/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	Service entrance cable unsupported, falling off rear exterior, possibly damaged. Debris and clutter laying on top of meter enclosure. Meter enclosure possibly damaged. Ensure service in approved condition. Dangerous and Hazardous	SEQ #: 016□	2436	S	ALBANY	AVE	25	Open
08/24/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	Service entrance cable unsupported, falling off rear exterior, possibly damaged. Debris and clutter laying on top of meter enclosure. Meter enclosure possibly damaged. Ensure service in approved condition. Dangerous and Hazardous	SEQ #: 027□	2436	S	ALBANY	AVE	25	Open
08/24/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	No visible water ground. Ensure service grounded in approved manner. Dangerous and Hazardous	SEQ #: 017□	2436	S	ALBANY	AVE	25	Open
08/24/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	No visible water ground. Ensure service grounded in approved manner. Dangerous and Hazardous	SEQ #: 028□	2436	S	ALBANY	AVE	25	Open

08/24/2023	EL1826	SYSTEM II	Install system II emergency lighting. (14E-7-700.6, 14E-7-700.21)	Required emergency lighting system not installed. Occupancy used for transient residential. Dangerous and Hazardous	SEQ #: 005□	2436	S	ALBANY	AVE	25	Open
08/24/2023	EL1826	SYSTEM II	Install system II emergency lighting. (14E-7-700.6, 14E-7-700.21)	Required emergency lighting system not installed. Occupancy used for transient residential. Dangerous and Hazardous	SEQ #: 024□	2436	S	ALBANY	AVE	25	Open
08/24/2023	EL1834	LISTED FOR USE TEMP & LOCATION	Electrical equipment shall be listed for use, temperature and location.(14E-1-110.2(B), 14E-1-110.11)	Exterior light fixtures, boxes, fittings, raceways must be suitable for wet locations. Interior light switch used at rear exterior. Dangerous and Hazardous	SEQ #: 009□	2436	S	ALBANY	AVE	25	Open
08/24/2023	EL1834	LISTED FOR USE TEMP & LOCATION	Electrical equipment shall be listed for use, temperature and location.(14E-1-110.2(B), 14E-1-110.11)	Exterior light fixtures, boxes, fittings, raceways must be suitable for wet locations. Interior light switch used at rear exterior. Dangerous and Hazardous	SEQ #: 028□	2436	S	ALBANY	AVE	25	Open
08/25/2023	EL1817	CONTINUITY OF RACEWAYS	raceway, and enclosure. (14E-3-300.10, 14E-3-300.13)	CONTINUITY OF RACEWAYS PROVIDE GROUND CONTINUITY FOR CABLE, RACEWAYS (BSMT)	SEQ #: 005□	1575	N	MILWAUKEE	AVE	01	Open
08/25/2023	EL1822	EXPOSED WIRING FIXTURES	Remove exposed wiring at light fixture. (14E-4-410.48)	EXPOSED LIVE WIRES AT LIGHT FIXTURES THROUGH-OUT BUILDING	SEQ #: 008□	1575	N	MILWAUKEE	AVE	01	Open
08/25/2023	EL1827	RESTORE EXIT AND EM	and related equipment to working condition. (14E-7-700.6)	SYSTEM AND RELATED EQUIPMENT TO WORKING CONDITION	SEQ #: 009□	1575	N	MILWAUKEE	AVE	01	Open
08/25/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	REMOVE ALL EXPOSE WIRE THROUGH-OUT BUILDING	SEQ #: 010□	1575	N	MILWAUKEE	AVE	01	Open
08/25/2023	EL1883	REPAIR BATTERY LIGHT	Repair emergency battery light unit. (14E-7-700.66)	BOXES THROUGH-OUT NEE KO FILLERS	SEQ #: 015□	1575	N	MILWAUKEE	AVE	01	Open
08/28/2023	EL1817	CONTINUITY OF RACEWAYS	Provide ground continuity for electrical cable, raceway, and enclosure. (14E-3-300.10, 14E-3-300.13)	CONTINUITY OF RACEWAYS; PROVIDE GROUND CONTINUITY FOR ELECTRICAL CABLE, RACEWAYS; BSMT	SEQ #: 005□	1575	N	MILWAUKEE	AVE	01	Open
08/28/2023	EL1822	EXPOSED WIRING FIXTURES	Remove exposed wiring at light fixture. (14E-4-410.48)	EXPOSED WIRE AT LIGHT FIXTURES THROUGH-OUT BUILDING	SEQ #: 008□	1575	N	MILWAUKEE	AVE	01	Open
08/28/2023	EL1827	RESTORE EXIT AND EM	Restore exit and emergency lighting system and related equipment to working condition. (14E-7-700.6)	RESTOR EMERGENCY LIGHTING SYSTEM AND RELATED EQUIPMENT TO WORKING CONDITION. BSMT NEEDS ADDITIONAL EM LIGHTING BATTERY PACKS;	SEQ #: 009□	1575	N	MILWAUKEE	AVE	01	Open
08/28/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	REMOVE ALL EXPOSED WIRING THOUGH-OUT BUILDING	SEQ #: 010□	1575	N	MILWAUKEE	AVE	01	Open
08/28/2023	EL1883	REPAIR BATTERY LIGHT	Repair emergency battery light unit. (14E-7-700.66)	BOXES THROUGH-OUT BUILDING NEED K/O FILLERS	SEQ #: 015□	1575	N	MILWAUKEE	AVE	01	Open
08/25/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	Service equipment showing deterioration. Debris, clutter stored on service equipment. Water piping installed directly over and almost in contact with service equipment tap box. Ensure service in approved condition.	SEQ #: 001□	12141	S	INDIANA	AVE	09	Open
08/25/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	Service equipment showing deterioration. Debris, clutter stored on service equipment. Water piping installed directly over and almost in contact with service equipment tap box. Ensure service in approved condition.	SEQ #: 004□	12141	S	INDIANA	AVE	09	Open
08/25/2023	EL1805	DEFECTIVE DISTRIBUTION	Replace defective distribution equipment. (14E-4-408.30, 14E-4-408.36, 14E-4-408.37, 14E-4-408.38, 14E-4-408.39, 14E-4-408.40, 14E-4-408.41))	Distribution panel at basement adjacent to service equipment is missing cover and appears tampered with. Loose disconnect covers at meter room. Ensure distribution throughout in approved condition. Dangerous and Hazardous	SEQ #: 003□	12141	S	INDIANA	AVE	09	Open
08/25/2023	EL1805	DEFECTIVE DISTRIBUTION	Replace defective distribution equipment. (14E-4-408.30, 14E-4-408.36, 14E-4-408.37, 14E-4-408.38, 14E-4-408.39, 14E-4-408.40, 14E-4-408.41))	Distribution panel at basement adjacent to service equipment is missing cover and appears tampered with. Loose disconnect covers at meter room. Ensure distribution throughout in approved condition. Dangerous and Hazardous	SEQ #: 006□	12141	S	INDIANA	AVE	09	Open
08/25/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	No visible water ground. Ensure service grounded in approved manner. Dangeorus and Hazardous	SEQ #: 002□	12141	S	INDIANA	AVE	09	Open

08/25/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	No visible water ground. Ensure service grounded in approved manner. Dangeorus and Hazardous	SEQ #: 005□	12141	S	INDIANA	AVE	09	Open
08/25/2023	EL1827	RESTORE EXIT AND EM	Restore exit and emergency lighting system and related equipment to working condition. (14E-7-700.6)	Emergency lighting system not being maintained, damaged, inoperable, insufficient various areas throughout premises. Restore to approved condition. Dangerus and Hazardous	SEQ #: 006□	12141	S	INDIANA	AVE	09	Open
08/25/2023	EL1827	RESTORE EXIT AND EM	Restore exit and emergency lighting system and related equipment to working condition. (14E-7-700.6)	Emergency lighting system not being maintained, damaged, inoperable, insufficient various areas throughout premises. Restore to approved condition. Dangerus and Hazardous	SEQ #: 009□	12141	S	INDIANA	AVE	09	Open
08/25/2023	EL1833	SECURE RACEWAY	Strap and secure raceway and armored cable. (14E-1-110.13(a))	Unsupported raceways boiler room. Secure where required throughout.	SEQ #: 007□	12141	S	INDIANA	AVE	09	Open
08/25/2023	EL1833	SECURE RACEWAY	Strap and secure raceway and armored cable. (14E-1-110.13(a))	Unsupported raceways boiler room. Secure where required throughout.	SEQ #: 010□	12141	S	INDIANA	AVE	09	Open
08/25/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	equipment. Damaged feeder breaker to east fire damaged unit at service meter bank. Ensure serivce in approved condition. Dangerous and Hazardous	SEQ #: 001□	251	E	121ST	PL	09	Open
08/25/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	equipment. Damaged feeder breaker to east fire damaged unit at service meter bank. Ensure serivce in approved condition. Dangerous and Hazardous	SEQ #: 004□	251	E	121ST	PL	09	Open
08/25/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	No visible water ground. Ensure service grounded inapproved manner. Dangerous and Hazardous	SEQ #: 005□	251	E	121ST	PL	09	Open
08/25/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	No visible water ground. Ensure service grounded inapproved manner. Dangerous and Hazardous	SEQ #: 008□	251	E	121ST	PL	09	Open
08/25/2023	EL1817	CONTINUITY OF RACEWAYS	Provide ground continuity for electrical cable, raceway, and enclosure. (14E-3-300.10, 14E-3-300.13)	Wire mold pulle apart at 1st floor ceiling. Ensure ground continuity where required throughout premises. Dangerous and Hazardous	SEQ #: 006□	251	E	121ST	PL	09	Open
08/25/2023	EL1817	CONTINUITY OF RACEWAYS	Provide ground continuity for electrical cable, raceway, and enclosure. (14E-3-300.10, 14E-3-300.13)	Wire mold pulle apart at 1st floor ceiling. Ensure ground continuity where required throughout premises. Dangerous and Hazardous	SEQ #: 009□	251	E	121ST	PL	09	Open
08/25/2023	EL1822	EXPOSED WIRING FIXTURES	Remove exposed wiring at light fixture. (14E-4-410.48)	Light fixtures hanging by wires basement ceiling. Remove where required throughout premises. Dangerous and Hazardous	SEQ #: 007□	251	E	121ST	PL	09	Open
08/25/2023	EL1822	EXPOSED WIRING FIXTURES	Remove exposed wiring at light fixture. (14E-4-410.48)	Light fixtures hanging by wires basement ceiling. Remove where required throughout premises. Dangerous and Hazardous	SEQ #: 010□	251	E	121ST	PL	09	Open
08/25/2023	EL1827	RESTORE EXIT AND EM	Restore exit and emergency lighting system and related equipment to working condition. (14E-7-700.6)	Emergency lights and exit signs not being maintained, broken, unapproved, insufficient. Dangerous and Hazardous	SEQ #: 003□	251	E	121ST	PL	09	Open
08/25/2023	EL1827	RESTORE EXIT AND EM	Restore exit and emergency lighting system and related equipment to working condition. (14E-7-700.6)	Emergency lights and exit signs not being maintained, broken, unapproved, insufficient. Dangerous and Hazardous	SEQ #: 006□	251	E	121ST	PL	09	Open
08/25/2023	EL1833	SECURE RACEWAY	Strap and secure raceway and armored cable. (14E-1-110.13(a))	hall ceiling. Secure where required throughout premises.	SEQ #: 004□	251	E	121ST	PL	09	Open
08/25/2023	EL1833	SECURE RACEWAY	Strap and secure raceway and armored cable. (14E-1-110.13(a))	hall ceiling. Secure where required throughout premises.	SEQ #: 007□	251	E	121ST	PL	09	Open
08/25/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	Some deterioration service equipment. Water piping directly over service equipment. Debris and clutter on top of service equipment. Ensure service in approved condition.	SEQ #: 007□	221	E	121ST	PL	09	Open
08/25/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	in approved manner. Dangerousa and Hazardous	SEQ #: 008□	221	E	121ST	PL	09	Open
08/25/2023	EL1817	CONTINUITY OF RACEWAYS	Provide ground continuity for electrical cable, raceway, and enclosure. (14E-3-300.10, 14E-3-300.13)	Wire mold pulled apart at various areas. Ensure ground continuity where required throughout premises. Dangerous and Hazardous	SEQ #: 010□	221	E	121ST	PL	09	Open

08/25/2023	EL1822	EXPOSED WIRING FIXTURES	Remove exposed wiring at light fixture. (14E-4-410.48)	Open wiring at light fixtures management office ceiling. Remove where required throughout premises. Dangerous and Hazardous	SEQ #: 009□	221	E	121ST	PL	09	Open
08/25/2023	EL1827	RESTORE EXIT AND EM	Restore exit and emergency lighting system and related equipment to working condition. (14E-7-700.6)	Battery lights and exit signs not being maintained, inoperable, unapproved, insufficient. Dangerous and Hazardous	SEQ #: 012□	221	E	121ST	PL	09	Open
08/25/2023	EL1833	SECURE RACEWAY	Strap and secure raceway and armored cable. (14E-1-110.13(a))	Unsupported raceways at boiler room. Secure where required throughout premises.	SEQ #: 016□	221	E	121ST	PL	09	Open
08/28/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	Cobwebs and crud inside main disconnect door. Meter cover appears not completely seated. Ensure service in approved condition.	SEQ #: 002□	8724	S	BURLEY	AVE	10	Open
08/28/2023	EL1827	RESTORE EXIT AND EM	and related equipment to working condition. (14E-7-700.6)	Unapproved, unmaintained, inoperable battery lights and exit signs. Dangerous and Hazardous	SEQ #: 003□	8724	S	BURLEY	AVE	10	Open
08/28/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	Open wire at small transformer connection at box in electrical closet and mechanical room. Remove where required throughout premises. Dangerous and Hazardous	SEQ #: 004□	8724	S	BURLEY	AVE	10	Open
08/28/2023	EL1839	CORRODED CONDUIT & EQUIP	Replace rusted, deteriorated, or corroded conduit, cabinet, electrical box, or fitting. (14E-3-300.13, 14E-1-110.12(b))	Corroded conduit at exterior. Replace where required throughout premises.	SEQ #: 005□	8724	S	BURLEY	AVE	10	Open
08/30/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	POSSBLY DAMAGED FROM DEBRIS AND CLUTTER IN CLOSE PROXIMITY. ENSURE SERVICE IN APPROVED CONDITION. DANGEROUS AND HAZARDOUS	SEQ #: 020□	10610	S	VINCENNES	AVE	19	Open
08/30/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	MAST, RACEWAY, CABLES, PANEL. PANEL COVERD BY WOOD. ENSURE SERVICE IN APPROVED CONDITION. DANGEROUS AND HAZARDOUS	SEQ #: 019□	10610	S	VINCENNES	AVE	19	Open
08/30/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	NO VISIBLE WATER GROUNDS. ENSURE SERVICES GROUNDED IN APPROVED MANNER. DANGEROUS AND HAZARDOUS	SEQ #: 021□	10610	S	VINCENNES	AVE	19	Open
08/30/2023	EL1817	CONTINUITY OF RACEWAYS	Provide ground continuity for electrical cable, raceway, and enclosure. (14E-3-300.10, 14E-3-300.13)	LOOSE FITTINGS. ENSURE GROUND CONTINUITY WHERE REQUIRED. DANGEROUS AND HAZARDOUS	SEQ #: 036□	10610	S	VINCENNES	AVE	19	Open
08/30/2023	EL1822	EXPOSED WIRING FIXTURES	Remove exposed wiring at light fixture. (14E-4-410.48)	REMOVE WHERE REQUIRED. DANGEROUS AND HAZARDOUS	SEQ #: 035□	10610	S	VINCENNES	AVE	19	Open
08/30/2023	EL1827	RESTORE EXIT AND EM	Restore exit and emergency lighting system and related equipment to working condition. (14E-7-700.6)	INSUFFICIENT EMERGENCY LIGHTING SYSTEM. INSTALL WEHRE REQUIRED. DANGEROUS AND HAZARDOUS	SEQ #: 040□	10610	S	VINCENNES	AVE	19	Open
08/30/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	THROUGHOUT ENTIRE PREMISES. REMOVE WHERE REQUIRED. DANGEROUS AND HAZARDOUS	SEQ #: 024□	10610	S	VINCENNES	AVE	19	Open
08/30/2023	EL1833	SECURE RACEWAY	Strap and secure raceway and armored cable. (14E-1-110.13(a))	UNSUPPORTED FALLING RACEWAYS VARIOUS AREAS. SECURE WHERE REQUIRED. DANGEROUS AND hAZARDOUS	SEQ #: 031□	10610	S	VINCENNES	AVE	19	Open
08/30/2023	EL1834	LISTED FOR USE TEMP & LOCATION	temperature and location.(14E-1-110.2(B), 14E-1-110.11)	RACEWAYS MUST BE SUITABLE FOR WET LOCATIONS.	SEQ #: 038□	10610	S	VINCENNES	AVE	19	Open
08/30/2023	EL1839	CORRODED CONDUIT & EQUIP	Replace rusted, deteriorated, or corroded conduit, cabinet, electrical box, or fitting. (14E-3-300.13, 14E-1-110.12(b))	CORRODED EQUIPMENT VARIOUS AREAS THROUGHOUT PREMISES. REPLACE WHERE REQUIRED. DANGEROUS AND HAZARDOUS	SEQ #: 025□	10610	S	VINCENNES	AVE	19	Open
08/30/2023	EL1880	DETERIORATED CONDUCTORS	Replace conductors with damaged or deteriorated insulation.(14E-1-110.7)	DETERIORATED DAMAGED WIRE VISIBLE AT OPEN BOXES. REPLACE WHERE REQUIRED. DANGEROUS AND HAZARDOUS	SEQ #: 032□	10610	S	VINCENNES	AVE	19	Open

08/30/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	missing supports. Main disconnoect has loose breakers, appears deteriorated and has a makeshift metalcover welded and attached to front making disconnects completely unaccessible. Ensure service in approved condition. Dangeorous and Hazardous	SEQ #: 012☐	10620	S	VINCENNES	AVE	19	Open
08/30/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	No visible water ground. Ensure service grounded in approved manner. Dangerous and Hazardous	SEQ #: 013☐	10620	S	VINCENNES	AVE	19	Open
08/30/2023	EL1827	RESTORE EXIT AND EM	Restore exit and emergency lighting system and related equipment to working condition. (14E-7-700.6)	Emergency lighting system not operable at lobby. Possibly not wired correctly. Ensure in approved condition. Dangerous and Hazardous	SEQ #: 024☐	10620	S	VINCENNES	AVE	19	Open
08/30/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	Open wiring at front exit sign customer waiting area. Remove where required throughout premises. Dangerous and Hazardous	SEQ #: 018☐	10620	S	VINCENNES	AVE	19	Open
08/30/2023	EL1834	LISTED FOR USE TEMP & LOCATION	temperature and location.(14E-1-110.2(B), 14E-1-110.11)	Exterior light fixtures, boxes, fittings, racways must be suitable for wet locations.	SEQ #: 017☐	10620	S	VINCENNES	AVE	19	Open
08/30/2023	EL1834	LISTED FOR USE TEMP & LOCATION	temperature and location.(14E-1-110.2(B), 14E-1-110.11)	areas must be suitable for wet location and identified for use.	SEQ #: 016☐	10620	S	VINCENNES	AVE	19	Open
08/30/2023	EL1839	CORRODED CONDUIT & EQUIP	Replace rusted, deteriorated, or corroded conduit, cabinet, electrical box, or fitting. (14E-3-300.13, 14E-1-110.12(b))	Damaged disconnect front sign post. Repair/replace where required.	SEQ #: 022☐	10620	S	VINCENNES	AVE	19	Open
08/28/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	Damaged meter enclosures. Ensure services in approved condition. Dangeous and Hazardous	SEQ #: 001☐	8928	S	BURLEY	AVE	10	Open
08/28/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	Damaged meter enclosures. Ensure services in approved condition. Dangeous and Hazardous	SEQ #: 003☐	8928	S	BURLEY	AVE	10	Open
08/28/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	Main service disconnect modular meter enclosures modified with unproved covers. Ensure service in approved condition. Dangeous and Hazardous	SEQ #: 003☐	8736	S	BURLEY	AVE	10	Open
08/28/2023	EL1805	DEFECTIVE DISTRIBUTION	4-408.30, 14E-4-408.36, 14E-4-408.37, 14E-4-408.38, 14E-4-408.39, 14E-4-408.40, 14E-4-408.41)	panels fillers. Ensure districution in approved condition throughout premises. Dangerous and Hazardous	SEQ #: 004☐	8736	S	BURLEY	AVE	10	Open
08/28/2023	EL1817	CONTINUITY OF RACEWAYS	Provide ground continuity for electrical cable, raceway, and enclosure. (14E-3-300.10, 14E-3-300.13)	Damaged wire mold pulled away from box. Ensure ground continuity where required throughout premises. Dangerous and Hazardous	SEQ #: 007☐	8736	S	BURLEY	AVE	10	Open
08/28/2023	EL1827	RESTORE EXIT AND EM	and related equipment to working condition. (14E-7-700.6)	inoperable, unapproved, damaged. Dangerous and Hazardous	SEQ #: 010☐	8736	S	BURLEY	AVE	10	Open
08/28/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	Exposed wire near exit sign front entries. Remove where required. Dangerous and Hazardous	SEQ #: 011☐	8736	S	BURLEY	AVE	10	Open
08/28/2023	EL1839	CORRODED CONDUIT & EQUIP	Replace rusted, deteriorated, or corroded conduit, cabinet, electrical box, or fitting. (14E-3-300.13, 14E-1-110.12(b))	Corroded conduit exterior. Replace where required throughout premises.	SEQ #: 008☐	8736	S	BURLEY	AVE	10	Open
08/28/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	Damaged meter enclosures,bent covers, raceways pulled away from equipment, possibly damaged cable. Ensure services in approved condition throughout premises. Dangerous and Hazardous	SEQ #: 003☐	8922	S	BURLEY	AVE	10	Open
08/25/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	SERVICE NEEDS TO BE RETAPED.	SEQ #: 017☐	5943	W	63RD	ST	13	Open
08/25/2023	EL1825	SYSTEM III	Install system III emergency lighting. (14E-7-700.6, 14E-7-700.22)	THROUGHOUT	SEQ #: 018☐	5943	W	63RD	ST	13	Open
08/25/2023	EL1834	LISTED FOR USE TEMP & LOCATION	temperature and location.(14E-1-110.2(B), 14E-1-110.11)	NO SEAL TIGHT IN BRICK. EXTERIOR	SEQ #: 016☐	5943	W	63RD	ST	13	Open
08/25/2023	EL1839	CORRODED CONDUIT & EQUIP	Replace rusted, deteriorated, or corroded conduit, cabinet, electrical box, or fitting. (14E-3-300.13, 14E-1-110.12(b))	THROUGHOUT EXTERIOR	SEQ #: 015☐	5943	W	63RD	ST	13	Open
09/08/2023	EL1827	RESTORE EXIT AND EM	Restore exit and emergency lighting system and related equipment to working condition. (14E-7-700.6)	SYSTEM AND RELATED EQUIPMENT TO WORKING CONDITION. ALL EXIT AND EMERGENCY LIGHTING EQUIPMENT S/BE STEEL NOT PLASTIC	SEQ #: 012☐	2501	W	63RD	ST	16	Open

09/08/2023	EL1827	RESTORE EXIT AND EM	Restore exit and emergency lighting system and related equipment to working condition. (14E-7-700.6)	SYSTEM, NO ACCESS TO PANELS. INSUFFICIENT EMERGENCY LIGHTING SYSTEM 2ND FLOOR AS BEING USED AS VIP AREA PART OF 1ST FLOOR BUSINES.. EXIT SIGN NOT SUPPORTED IN APPROVED MANNER FIRST FLOOR FRONT. DANGEROUS AND	SEQ #: 015	5936	W	CHICAGO	AVE	29	Open
09/13/2023	EL1817	CONTINUITY OF RACEWAYS	Provide ground continuity for electrical cable, raceway, and enclosure. (14E-3-300.10, 14E-3-300.13)	EMT conduit at floor behind kitchen counter pulled away from box. Ensure ground continuity where required. Dangerous and Hazardous	SEQ #: 012	5107	W	MADISON	ST	28	Open
09/13/2023	EL1827	RESTORE EXIT AND EM	and related equipment to working condition. (14E-7-700.6)	Unable to test emergency lighting system. No access to panels. Dangerous and Hazardous	SEQ #: 006	5107	W	MADISON	ST	28	Open
09/13/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	base. Remove where required. Dangerous and Hazardous	SEQ #: 008	5107	W	MADISON	ST	28	Open
09/13/2023	EL1880	DETERIORATED CONDUCTORS	Replace conductors with damaged or deteriorated insulation.(14E-1-110.7)	Damaged wires at damaged raceway on floor behind kitchen counter. Replace where required. Dangerous and Hazardous	SEQ #: 014	5107	W	MADISON	ST	28	Open
09/14/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	head. Overhead service conductors appear damaged / deteriorated at service head. Trees laying on overhead service cables. Service disconnect buried beneath storage possibly damaged. Ensure service in approved condition. Dangerous and Hazardous	SEQ #: 001	505	E	67TH	ST	06	Open
09/14/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	head. Overhead service conductors appear damaged / deteriorated at service head. Trees laying on overhead service cables. Service disconnect buried beneath storage possibly damaged. Ensure service in approved condition. Dangerous and Hazardous	SEQ #: 022	505	E	67TH	ST	06	Open
09/14/2023	EL1805	DEFECTIVE DISTRIBUTION	4-408.30, 14E-4-408.36, 14E-4-408.37, 14E-4-408.38, 14E-4-408.39, 14E-4-408.40, 14E-4-408.41)	Panels appear corroded, deteriorated, loose covers. Ensure distribution throughout in approved condition. Dangerous and Hazardous	SEQ #: 003	505	E	67TH	ST	06	Open
09/14/2023	EL1805	DEFECTIVE DISTRIBUTION	4-408.30, 14E-4-408.36, 14E-4-408.37, 14E-4-408.38, 14E-4-408.39, 14E-4-408.40, 14E-4-408.41)	Panels appear corroded, deteriorated, loose covers. Ensure distribution throughout in approved condition. Dangerous and Hazardous	SEQ #: 024	505	E	67TH	ST	06	Open
09/14/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	No visible water ground. Ensure service grounded in approved manner. Dangerous and Hazardous	SEQ #: 002	505	E	67TH	ST	06	Open
09/14/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	No visible water ground. Ensure service grounded in approved manner. Dangerous and Hazardous	SEQ #: 023	505	E	67TH	ST	06	Open
09/14/2023	EL1817	CONTINUITY OF RACEWAYS	raceway, and enclosure. (14E-3-300.10, 14E-3-300.13)	ground continuity where required. Dangerous and Hazardous	SEQ #: 033	505	E	67TH	ST	06	Open
09/14/2023	EL1827	RESTORE EXIT AND EM	and related equipment to working condition. (14E-7-700.6)	Unable to test emergency lighting system. Panels inaccessible. Dangerous and Hazardous	SEQ #: 005	505	E	67TH	ST	06	Open
09/14/2023	EL1827	RESTORE EXIT AND EM	and related equipment to working condition. (14E-7-700.6)	Unable to test emergency lighting system. Panels inaccessible. Dangerous and Hazardous	SEQ #: 026	505	E	67TH	ST	06	Open
09/14/2023	EL1834	LISTED FOR USE TEMP & LOCATION	temperature and location.(14E-1-110.2(B), 14E-1-110.11)	Light fixtures, boxes, fittings, raceways must be suitable for wet locations.	SEQ #: 028	505	E	67TH	ST	06	Open
09/21/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	Service head deteriorated. Some overhead splice covers appear damaged. Main service equipment showing deterioration. Ensure all services in approved condition. Dangerous and Hazardous	SEQ #: 019	4314	S	WABASH	AVE	03	Open
09/21/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	Service head deteriorated. Some overhead splice covers appear damaged. Main service equipment showing deterioration. Ensure all services in approved condition. Dangerous and Hazardous	SEQ #: 022	4314	S	WABASH	AVE	03	Open
09/21/2023	EL1805	DEFECTIVE DISTRIBUTION	Replace defective distribution equipment. (14E-4-408.30, 14E-4-408.36, 14E-4-408.37, 14E-4-408.38, 14E-4-408.39, 14E-4-408.40, 14E-4-408.41)	panel doors. Loose covers. Varous panels throughout premises. Ensure distribution in approved conditon throughout premises. Dangerous and Hazardous	SEQ #: 020	4314	S	WABASH	AVE	03	Open

09/21/2023	EL1805	DEFECTIVE DISTRIBUTION	Replace defective distribution equipment. (14E-4-408.30, 14E-4-408.36, 14E-4-408.37, 14E-4-408.38, 14E-4-408.39, 14E-4-408.40, 14E-4-408.41)	panel doors. Loose covers. Varous panels throughout premises. Ensure distribution in approved conditon throughout premises. Dangerous and Hazardous	SEQ #: 023	4314	S	WABASH	AVE	03	Open
09/21/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	No visible water ground. Ensure service grounded in approved manner. Dangerous and Hazardous	SEQ #: 021	4314	S	WABASH	AVE	03	Open
09/21/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	No visible water ground. Ensure service grounded in approved manner. Dangerous and Hazardous	SEQ #: 024	4314	S	WABASH	AVE	03	Open
09/21/2023	EL1817	CONTINUITY OF RACEWAYS	Provide ground continuity for electrical cable, raceway, and enclosure. (14E-3-300.10, 14E-3-300.13)	Conduits pulled apart at fittings at rear exterior. Raceways pulled away from boxes various areas boiler room. Raceways not attached to box or light fixture various areas hallways and rooms. Ensure ground continuity where required throughout premises. Dangerous and Hazardous	SEQ #: 025	4314	S	WABASH	AVE	03	Open
09/21/2023	EL1817	CONTINUITY OF RACEWAYS	Provide ground continuity for electrical cable, raceway, and enclosure. (14E-3-300.10, 14E-3-300.13)	Conduits pulled apart at fittings at rear exterior. Raceways pulled away from boxes various areas boiler room. Raceways not attached to box or light fixture various areas hallways and rooms. Ensure ground continuity where required throughout premises. Dangerous and Hazardous	SEQ #: 028	4314	S	WABASH	AVE	03	Open
09/21/2023	EL1822	EXPOSED WIRING FIXTURES	Remove exposed wiring at light fixture. (14E-4-410.48)	Exposed wirin at light fixtures various areas ceilings and wall sconces. Bath shower area fixtures. Remove where required. Dangerous and Hazardou	SEQ #: 026	4314	S	WABASH	AVE	03	Open
09/21/2023	EL1822	EXPOSED WIRING FIXTURES	Remove exposed wiring at light fixture. (14E-4-410.48)	Exposed wirin at light fixtures various areas ceilings and wall sconces. Bath shower area fixtures. Remove where required. Dangerous and Hazardou	SEQ #: 029	4314	S	WABASH	AVE	03	Open
09/21/2023	EL1827	RESTORE EXIT AND EM	Restore exit and emergency lighting system and related equipment to working condition. (14E-7-700.6)	The existing emergency lighting system exit signs and generator are not being maintained. There are damaged exit signs, insufficiently illuminated exit signs, insufficiently supported exit signs. The emergency generator is in a state of disrepair with deteriorated exhaust piping, extension cord tied to the generator enclosure, open wiring and corroded disconnect. There is no evidence of yearly load bank tests. Restore required emergency lighting system to approved condition. Dangerous and Hazardous	SEQ #: 023	4314	S	WABASH	AVE	03	Open
09/21/2023	EL1827	RESTORE EXIT AND EM	Restore exit and emergency lighting system and related equipment to working condition. (14E-7-700.6)	The existing emergency lighting system exit signs and generator are not being maintained. There are damaged exit signs, insufficiently illuminated exit signs, insufficiently supported exit signs. The emergency generator is in a state of disrepair with deteriorated exhaust piping, extension cord tied to the generator enclosure, open wiring and corroded disconnect. There is no evidence of yearly load bank tests. Restore required emergency lighting system to approved condition. Dangerous and Hazardous	SEQ #: 026	4314	S	WABASH	AVE	03	Open
09/21/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	Exposed wiring various areas boiler room and walk in coolers. Remove where required throughout premises. Dangerous and Hazardous	SEQ #: 030	4314	S	WABASH	AVE	03	Open
09/21/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	Exposed wiring various areas boiler room and walk in coolers. Remove where required throughout premises. Dangerous and Hazardous	SEQ #: 033	4314	S	WABASH	AVE	03	Open
09/21/2023	EL1834	LISTED FOR USE TEMP & LOCATION	Electrical equipment shall be listed for use, temperature and location.(14E-1-110.2(B), 14E-1-110.11)	Light fixtures, boxes, fittings, raceways at walk in coolers must be suitable for wet locations and identirified for use. Dangerous and Hazardous	SEQ #: 029	4314	S	WABASH	AVE	03	Open
09/21/2023	EL1834	LISTED FOR USE TEMP & LOCATION	Electrical equipment shall be listed for use, temperature and location.(14E-1-110.2(B), 14E-1-110.11)	Light fixtures, boxes, fittings, raceways at walk in coolers must be suitable for wet locations and identirified for use. Dangerous and Hazardous	SEQ #: 032	4314	S	WABASH	AVE	03	Open

09/21/2023	EL1834	LISTED FOR USE TEMP & LOCATION	Electrical equipment shall be listed for use, temperature and location.(14E-1-110.2(B), 14E-1-110.11)	Light switches and non-wet locations shower light fixtures installed inside shower areas. Remove where required throughout premises. Dangerous and Hazardous	SEQ #: 033☐	4314	S	WABASH	AVE	03	Open
09/21/2023	EL1834	LISTED FOR USE TEMP & LOCATION	Electrical equipment shall be listed for use, temperature and location.(14E-1-110.2(B), 14E-1-110.11)	Light switches and non-wet locations shower light fixtures installed inside shower areas. Remove where required throughout premises. Dangerous and Hazardous	SEQ #: 036☐	4314	S	WABASH	AVE	03	Open
09/21/2023	EL1834	LISTED FOR USE TEMP & LOCATION	Electrical equipment shall be listed for use, temperature and location.(14E-1-110.2(B), 14E-1-110.11)	Missing equipment covers various areas boiler room. Install where required throughout premises. Dangerous and Hazardous	SEQ #: 001☐	4314	S	WABASH	AVE	03	Open
09/21/2023	EL1834	LISTED FOR USE TEMP & LOCATION	Electrical equipment shall be listed for use, temperature and location.(14E-1-110.2(B), 14E-1-110.11)	Missing equipment covers various areas boiler room. Install where required throughout premises. Dangerous and Hazardous	SEQ #: 036☐	4314	S	WABASH	AVE	03	Open
09/21/2023	EL1839	CORRODED CONDUIT & EQUIP	Replace rusted, deteriorated, or corroded conduit, cabinet, electrical box, or fitting. (14E-3-300.13, 14E-1-110.12(b))	Corroded equipment various areas boiler room and throughout premises. Replace where required. Dangerous and Hazardous	SEQ #: 031☐	4314	S	WABASH	AVE	03	Open
09/21/2023	EL1839	CORRODED CONDUIT & EQUIP	Replace rusted, deteriorated, or corroded conduit, cabinet, electrical box, or fitting. (14E-3-300.13, 14E-1-110.12(b))	Corroded equipment various areas boiler room and throughout premises. Replace where required. Dangerous and Hazardous	SEQ #: 034☐	4314	S	WABASH	AVE	03	Open
09/21/2023	EL1850	RESTORE GENERATOR	Restore emergency generator to operating condition and provide logbook of required tests. (14E-7-701.1, 14E-7-701.3)	Back up emergency system generator in deteriorated condition. No record of yearly load bank test. Dangerous and Hazardous	SEQ #: 028☐	4314	S	WABASH	AVE	03	Open
09/21/2023	EL1850	RESTORE GENERATOR	Restore emergency generator to operating condition and provide logbook of required tests. (14E-7-701.1, 14E-7-701.3)	Back up emergency system generator in deteriorated condition. No record of yearly load bank test. Dangerous and Hazardous	SEQ #: 031☐	4314	S	WABASH	AVE	03	Open
09/22/2023	EL1827	RESTORE EXIT AND EM	and related equipment to working condition. (14E-7-700.6)	AND RELATED EQUIPMENT TO WORKING CONDITION	SEQ #: 006☐	300	S	CICERO	AVE	28	Open
09/22/2023	EL1827	RESTORE EXIT AND EM	and related equipment to working condition. (14E-7-700.6)	SYSTEM AND RELATED EQUIPMENT TO WORKING CONDITION	SEQ #: 007☐	324	S	CICERO	AVE	28	Open
09/22/2023	EL1827	RESTORE EXIT AND EM	Restore exit and emergency lighting system and related equipment to working condition. (14E-7-700.6)	SYSTEMS AND RELATED EQUIPMENT TO WORKING CONDITION. BATTERY PACKS S/BE METAL NOT PLASTIC. (2) FRONT AND (2) rear inoperable	SEQ #: 005☐	4751	W	HARRISON	ST	24	Open
09/22/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	PANELS THROUGHOUT BUILDING NEED TO SUPPORTED.	SEQ #: 010☐	200	E	75TH	ST	06	Open
09/22/2023	EL1804	DEFECTIVE FEEDER	Replace defective feeder. (14E-2-215)	PIPE AND CABLE ARE BAD NEED TO BE REPLACE	SEQ #: 045☐	200	E	75TH	ST	06	Open
09/22/2023	EL1805	DEFECTIVE DISTRIBUTION	4-408.30, 14E-4-408.36, 14E-4-408.37, 14E-4-408.38, 14E-4-408.39, 14E-4-408.40, 14E-4-408.41)	DISTRIBUTION IS CORRODED , COVERS MISSING .	SEQ #: 044☐	200	E	75TH	ST	06	Open
09/22/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)		SEQ #: 043☐	200	E	75TH	ST	06	Open
09/22/2023	EL1822	EXPOSED WIRING FIXTURES	Remove exposed wiring at light fixture. (14E-4-410.48)	THROUGHOUT	SEQ #: 036☐	200	E	75TH	ST	06	Open
09/22/2023	EL1827	RESTORE EXIT AND EM	and related equipment to working condition. (14E-7-700.6)	THROUGHOUT	SEQ #: 038☐	200	E	75TH	ST	06	Open
09/22/2023	EL1828	UNAPPROVED EM	from emergency lighting system. (14E-7-700.63)	PLASTIC EXIT SIGNS THROUGHOUT.	SEQ #: 037☐	200	E	75TH	ST	06	Open
09/22/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	THROUGHOUT	SEQ #: 015☐	200	E	75TH	ST	06	Open
09/22/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	THROUGHOUT	SEQ #: 023☐	200	E	75TH	ST	06	Open
09/22/2023	EL1833	SECURE RACEWAY	Strap and secure raceway and armored cable. (14E-1-110.13(a))	THROUGHOUT	SEQ #: 011☐	200	E	75TH	ST	06	Open
09/22/2023	EL1833	SECURE RACEWAY	Strap and secure raceway and armored cable. (14E-1-110.13(a))	THROUGHOUT	SEQ #: 020☐	200	E	75TH	ST	06	Open

09/22/2023	EL1839	CORRODED CONDUIT & EQUIP	Replace rusted, deteriorated, or corroded conduit, cabinet, electrical box, or fitting. (14E-3-300.13, 14E-1-110.12(b))	THROUGHOUT	SEQ #: 041☐	200	E	75TH	ST	06	Open
09/22/2023	EL1872	SPLICE IN CORD	Remove splice in flexible cord. (14E-4-400.13)	THROUGHOUT	SEQ #: 026☐	200	E	75TH	ST	06	Open
09/25/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	PANELS THROUGHOUT BUILDING NEED TO SUPPORTED.	SEQ #: 019☐	200	E	75TH	ST	06	Open
09/20/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	service in approved condition. Dangerous and Hazardous	SEQ #: 011☐	517	S	CICERO	AVE	24	Open
09/20/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	service in approved condition. Dangerous and Hazardous	SEQ #: 012☐	517	S	CICERO	AVE	24	Open
09/20/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	Clutter and furniture in front of electrical panel 1st floor. Dangerous and Hazardous	SEQ #: 011☐	517	S	CICERO	AVE	24	Open
09/20/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	Clutter and furniture in front of electrical panel 1st floor. Dangerous and Hazardous	SEQ #: 013☐	517	S	CICERO	AVE	24	Open
09/20/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	No visible water ground. Ensure service grounded in approved manner. Dangerous and Hazardous	SEQ #: 012☐	517	S	CICERO	AVE	24	Open
09/20/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	No visible water ground. Ensure service grounded in approved manner. Dangerous and Hazardous	SEQ #: 013☐	517	S	CICERO	AVE	24	Open
09/20/2023	EL1827	RESTORE EXIT AND EM	and related equipment to working condition. (14E-7-700.6)	test. No panel schedules. Dangerous and Hazardous	SEQ #: 015☐	517	S	CICERO	AVE	24	Open
09/20/2023	EL1834	LISTED FOR USE TEMP & LOCATION	temperature and location.(14E-1-110.2(B), 14E-1-110.11)	Exterior light fixtures, boxes, fittings, raceways must be suitable for wet locations.	SEQ #: 017☐	517	S	CICERO	AVE	24	Open
09/27/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	Main service panel has unapproved cover. Cover does not fit and does not completely cover live parts. Ensure service in approved condition. Dangerous and Hazardous	SEQ #: 007☐	5155	W	LAKE	ST	28	Open
09/27/2023	EL1827	RESTORE EXIT AND EM	and related equipment to working condition. (14E-7-700.6)	Emergency lighting system not operating in approved manner. Dangerous and Hazardous	SEQ #: 008☐	5155	W	LAKE	ST	28	Open
09/20/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	masts rear exterior. Deteriorated wood service masts rear exterior. Overhead service splices deteriorated. Neter enclosures covered by metal grating. Ensure services in approved condition. Dangerous and Hazardous	SEQ #: 032☐	4757	W	MADISON	ST	28	Open
09/20/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	adjacent overhead serive cables. Open jumped electrical meters at common area. Missing servcie equipment cover. Metal grate over exterior mogul fittings. Ensure service in approved condition. Dangerous and Hazardous	SEQ #: 018☐	4757	W	MADISON	ST	28	Open
09/20/2023	EL1827	RESTORE EXIT AND EM	Restore exit and emergency lighting system and related equipment to working condition. (14E-7-700.6)	57-59 Emergency lighting system not operating at 57 store and 57-59 common areas or basement. Dangerous and Hazardous	SEQ #: 023☐	4757	W	MADISON	ST	28	Open
09/20/2023	EL1827	RESTORE EXIT AND EM	Restore exit and emergency lighting system and related equipment to working condition. (14E-7-700.6)	57-59 Emergency lighting system not operating at 57 store and 57-59 common areas or basement. Dangerous and Hazardous	SEQ #: 024☐	4757	W	MADISON	ST	28	Open
09/20/2023	EL1834	LISTED FOR USE TEMP & LOCATION	temperature and location.(14E-1-110.2(B), 14E-1-110.11)	57 Exterior light fixtures boxes fittings must be suitable for wet locations.	SEQ #: 023☐	4757	W	MADISON	ST	28	Open
09/20/2023	EL1834	LISTED FOR USE TEMP & LOCATION	temperature and location.(14E-1-110.2(B), 14E-1-110.11)	57 Exterior light fixtures boxes fittings must be suitable for wet locations.	SEQ #: 024☐	4757	W	MADISON	ST	28	Open
09/22/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	FEED FOR GARAGE NOT WITHIN FIVE FEET OF METER .	SEQ #: 015☐	3036	E	87TH	ST	10	Open
09/22/2023	EL1801	DEFECTIVE SERVICE	Replace defective service. (14E-2-230)	SERVICE HEAD MISSING - PIPE TO GARAGE IS DISCONNECTED WIRES JUST HANGING WITH NO SUPPORT. FROM METER SOCKET.	SEQ #: 009☐	3036	E	87TH	ST	10	Open
09/22/2023	EL1833	SECURE RACEWAY	Strap and secure raceway and armored cable. (14E-1-110.13(a))	SUPPORT RISER AND GARAGE FEED	SEQ #: 010☐	3036	E	87TH	ST	10	Open
09/22/2023	EL1834	LISTED FOR USE TEMP & LOCATION	temperature and location.(14E-1-110.2(B), 14E-1-110.11)	COVERS AND BOXES NOT RATED FOR EXTERIOR USE .	SEQ #: 011☐	3036	E	87TH	ST	10	Open

09/25/2023	EL1817	CONTINUITY OF RACEWAYS	raceway, and enclosure. (14E-3-300.10, 14E-3-300.13)	ELECTRICAL CABLE, RACEWAY, AND ENCLOSURE CONDUIT ETC	SEQ #: 005□	7900	S	ASHLAND	AVE	17	Open
09/25/2023	EL1817	CONTINUITY OF RACEWAYS	raceway, and enclosure. (14E-3-300.10, 14E-3-300.13)	ELECTRICAL CABLE, RACEWAY, AND ENCLOSURE CONDUIT ETC	SEQ #: 015□	7900	S	ASHLAND	AVE	17	Open
09/25/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	REMOVE EXPOSED WIRING IN (COOLERS ENTRANCE DOORS)	SEQ #: 006□	7900	S	ASHLAND	AVE	17	Open
09/25/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	REMOVE EXPOSED WIRING IN (COOLERS ENTRANCE DOORS)	SEQ #: 016□	7900	S	ASHLAND	AVE	17	Open
09/25/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	REMOVE EXPOSED WIRING IN COOLERS FRONT DOORS	SEQ #: 006□	7900	S	ASHLAND	AVE	17	Open
09/25/2023	EL1806	PROPER SIZE GRD ELECTRODE COND	Install proper sized grounding conductor. (14E-2-250.20, 14E-2-250.66)	INSTALL PROPER SIZE GROUNDING ELECTRODE	SEQ #: 009□	9304	S	ESCANABA	AVE	07	Open
09/25/2023	EL1822	EXPOSED WIRING FIXTURES	Remove exposed wiring at light fixture. (14E-4-410.48)	D&H REMOVE EXPOSED WIRING AT FIXTURES *****LIVE WIRE*****	SEQ #: 016□	9304	S	ESCANABA	AVE	07	Open
09/25/2023	EL1829	EXPOSED WIRING	Remove exposed wiring. (14E-3-300.4)	D&H**LIVE WIRE** REMOVE EXPOSED LIVE WIRE IN BASEMENT RUNNING THROUGH-OUT	SEQ #: 018□	9304	S	ESCANABA	AVE	07	Open
09/25/2023	EL1833	SECURE RACEWAY	Strap and secure raceway and armored cable. (14E-1-110.13(a))	STRAP AND SECURE RACEWAY, ARMORED CABLE AND CONDUIT THROUGH-OUT	SEQ #: 019□	9304	S	ESCANABA	AVE	07	Open
09/29/2023	EL1827	RESTORE EXIT AND EM	and related equipment to working condition. (14E-7-700.6)	SYSTEM AND RELATED EQUIPMENT TO WORKING CONDITION	SEQ #: 005□	8106	S	RACINE	AVE	17	Open
09/29/2023	EL1827	RESTORE EXIT AND EM	Restore exit and emergency lighting system and related equipment to working condition. (14E-7-700.6)	RESTORE EXIT AND EMERGENCY LIGHTING SYSTEM AND RELATED EQUIPMENT TO WORKING CONDITION	SEQ #: 005□	7701	S	RACINE	AVE	17	Open



CITY OF CHICAGO

DEPARTMENT OF BUILDINGS

MEMORANDUM

To: The Honorable Jason Ervin
Chairman, Committee on the Budget and Government Operations

From: Matthew Beudet
Commissioner
Department

CC: Elizabeth Beatty
Mayor's Office of Intergovernmental Affairs

Date: **November 8, 2023**

Re: Request for Information from Annual Appropriation Committee Hearing

ID#: 67-08

The following information is provided in response to questions posed at our department's hearing on October 25, 2023, to discuss the proposed 2024 budget.

Alderman Lopez asked the list of vacant buildings and the time to demolish (please see below). The department has a list of buildings that have an order from Circuit Court that gives the department authority to demolish a building. The department prioritizes buildings with the following dangerous and hazardous conditions:

1. Foundations that have been undermined.
2. Lack of or inadequate lateral support of exterior walls.
3. Floor systems that are structurally compromised.
4. Roofing systems structurally compromised including missing roofing.
5. Center support beams that are structurally compromised.
6. Exterior and interior stair systems and/or porches structurally compromised.
7. Chronic nuisance due to ongoing criminal activity

Buildings with an order from Circuit Court that do not have any of the conditions listed above are not prioritized as we want to preserve as much of our housing stock located on the south and west sides of the City. These areas have been decimated due to all the demolition activity that occurred over the past 10 years. As a department we are committed to stabilizing the community and the courts are allowing people to file motions to stay the demolition so that they are able to reinvest in their properties.

Display Address	Ward	Census Tract	Police District
6140 N PULASKI RD CHICAGO IL 60646-	39	130200	17

As always, please let me know if you have any further questions.



CITY OF CHICAGO

DEPARTMENT OF BUILDINGS

MEMORANDUM

To: The Honorable Jason Ervin
Chairman, Committee on the Budget and Government Operations

From: Matthew Beaudet
Commissioner
Department

CC: Elizabeth Beatty
Mayor's Office of Intergovernmental Affairs

Date: **November 11, 2023**

Re: Request for Information from Annual Appropriation Committee Hearing

ID#: 67-09

The following information is provided in response to questions posed at our department's hearing on October 25, 2023, to discuss the proposed 2024 budget.

Alderman Lopez asked for a list of properties boarded up by ward, the department does not track boards up by ward only by address (listed below). The department will ask the vendor who tracks board ups to begin adding the ward associated with the property in on their monthly reports that they submit.

Address	Date of Service
1419-21 W 64th St	1/3/2023
1843 W 62nd St	1/3/2023
1610 S Pulaski Rd	1/4/2023
7535 S Coles Ave	1/4/2023
8357 S Hermitage Ave	1/5/2023
8343 S Buffalo Ave	1/5/2023
5921 S Carpenter St	1/5/2023
8136 S Avalon Ave	1/5/2023
3009 E 83rd St	1/5/2023
8136 S Avalon Ave	1/5/2023
10323 S Indiana Ave	1/5/2023
1247 N California Ave	1/6/2023
3512 W 38th Pl	1/6/2023

3910 W Wilcox St	1/6/2023
3017 W Cullerton St	1/6/2023
3512 W 38th Pl	1/6/2023
5722 S Union Ave	1/6/2023
2515 W Congress Pkwy	1/6/2023
6643 S Sangamon St	1/6/2023
6948 S Stewart Ave	1/6/2023
7114 S Lafayette Ave	1/6/2023
2834 W Arthington St	1/6/2023
7024 S Racine Ave	1/7/2023
7936 S Vernon Ave	1/7/2023
13403 S Brandon Ave	1/7/2023
5000 S Princeton Ave	1/7/2023
7843 S Lowe Ave	1/9/2023
7114 S Green St	1/9/2023
6702 S Throop	1/10/2023
2251 S Trumbull Ave	1/10/2023
6206 S Elizabeth St	1/10/2023
6001 S Honore St	1/10/2023
1836 W Marquette	1/11/2023
1417 E 75th St	1/11/2023
7223 S Hermitage Ave	1/11/2023
4008 W North Ave	1/12/2023
733-35 S Lavergne Ave	1/12/2023
1847 S Spaulding	1/12/2023
4755 N Lotus Ave	1/12/2023
1621 S Lawndale	1/12/2023
6727 S Eberhart Ave	1/12/2023
6333 S Parnell Ave	1/12/2023
6939 S Green St	1/12/2023
5006-08 W Chicago Ave	1/12/2023
10325 S Indiana Ave	1/12/2023
1220 S Lawndale Ave	1/13/2023
5961 N McCook Ave	1/13/2023
1247 N California Ave	1/13/2023
2835 W Cullerton St	1/13/2023
6020 S Michigan Ave	1/13/2023
9145 S Laflin St	1/14/2023
7843 S Lowe Ave	1/17/2023
7845 S Lowe Ave	1/17/2023
7847 S Lowe Ave	1/17/2023

232 W 108th Pl	1/17/2023
9056 S Harper Ave	1/19/2023
6354 S May St	1/19/2023
7050 S Eggleston Ave	1/19/2023
7116 S Woodlawn Ave	1/19/2023
2342 W 22nd Pl	1/20/2023
5724 W Armitage Ave	1/20/2023
7212 S Dobson Ave	1/20/2023
1467-69 E 67th St	1/20/2023
6530 S Carpenter St	1/20/2023
3659 W Grenshaw St	1/20/2023
3926 W Arthington St	1/21/2023
5659 S Kildare Ave	1/23/2023
834 W Garfield Blvd	1/23/2023
353 W 106th Pl	1/23/2023
6409 S Albany Ave	1/23/2023
2128 S Harding Ave	1/23/2023
3824 W Flornoy St	1/23/2023
1247 N California Ave	1/23/2023
3659 W Grenshaw St	1/24/2023
5621 S Perry Ave	1/24/2023
7444 S Blackstone Ave	1/24/2023
7319 S Green St	1/24/2023
1259 W 73rd Place	1/24/2023
8227 S Commercial Ave	1/24/2023
3037 W Lexington St	1/25/2023
7455 S Merrill Ave	1/25/2023
5325 S May St	1/25/2023
421 S Kilbourn Ave	1/25/2023
6017 S Morgan St	1/25/2023
6505 S Laflin St	1/27/2023
6503 S Laflin St	1/27/2023
342 S Kostner Ave	1/27/2023
7024 S Racine Ave	1/28/2023
1517 S Keeler Ave	1/30/2023
6029 S Bishop St	1/30/2023
6029 S Bishop St	1/30/2023
541 W 44th Place	1/31/2023
3347 W Irving Park Road	1/31/2023
3219 S Green St	1/31/2023
3627 W 5th Ave	1/31/2023

7933 S Champlain Ave	1/31/2023
3740 S Kedzie Ave	2/1/2023
4833 W Lake St	2/1/2023
6725 S Paxton Ave	2/1/2023
1403 N Lockwood Ave	2/1/2023
10035 S Peoria St	2/1/2023
311 W 109th Place	2/1/2023
436 W 111th St	2/1/2023
11256 S Bishop St	2/1/2023
8124 S Elizabeth St	2/2/2023
3704 W Ferdinand St	2/2/2023
2308 N Lister Ave	2/2/2023
7758 S St Lawrence Ave	2/2/2023
828 E 90th Pl	2/3/2023
124 N Hamlin Ave	2/4/2023
6401 S Whipple St	2/6/2023
6950 S Bishop St	2/6/2023
6832 S Loomis Blvd	2/6/2023
6950 S Bishop St	2/6/2023
4727 S Wood St	2/7/2023
10718 S Perry Ave	2/7/2023
9004 S Oglesby Ave	2/7/2023
8934 S Luella Ave	2/7/2023
9055 S Clyde Ave	2/7/2023
9549 S Bennett Ave	2/7/2023
7150 S Aberdeen St	2/8/2023
9156 S Colfax Ave	2/8/2023
8031 S Euclid Ave	2/8/2023
1522 N Avers Ave	2/9/2023
4528 W Maypole Ave	2/9/2023
4136 W Van Buren St	2/9/2023
7840 S Avalon Ave	2/10/2023
8017 S Langley Ave	2/10/2023
6207 S Wood St	2/10/2023
8258 S Calumet Ave	2/10/2023
10509 S Edbrooke Ave	2/10/2023
6945 S Yale Ave	2/10/2023
3720 W Lexington St	2/10/2023
6405 S Parnell Ave	2/14/2023
6832 S Loomis Blvd	2/14/2023
9515 S Ave N	2/14/2023

363 E 89th St	2/14/2023
5750 S Marshfield Ave	2/14/2023
6523 N Campbell Ave	2/15/2023
5750 S Elizabeth St	2/15/2023
6744-46 S Lafayette Ave	2/15/2023
843 W 74th St	2/15/2023
4117 W Van Buren St	2/15/2023
9145 S Laflin St	2/15/2023
6642 S Union Ave	2/16/2023
5845 S Union Ave	2/16/2023
6647 S Stewart Ave	2/16/2023
1034 W 87th St #C	2/17/2023
7136 S Bell Ave	2/17/2023
1845 S Springfield Ave	2/17/2023
7026 S Aberdeen St	2/17/2023
2707 W Warren Blvd	2/17/2023
745 S Kolmar Ave	2/17/2023
3834 W Lexington St	2/17/2023
1947 S Trumbull Ave	2/17/2023
6525 S Morgan St	2/21/2023
8743 S Carpenter St	2/21/2023
11749 S Union Ave	2/21/2023
3525 W Van Buren St	2/22/2023
10235 S Carpenter St	2/22/2023
7933 S Champlain Ave	2/22/2023
2702 S Union Ave	2/23/2023
7526 S Aberdeen St	2/23/2023
5604 S Morgan St	2/23/2023
5547 S Emerald Ave	2/23/2023
5604 S Morgan St	2/23/2023
5744 S Sangamon St	2/23/2023
722 W 71st St	2/23/2023
3449 W 23rd St	2/24/2023
5602 S Wolcott Ave	2/24/2023
1234 S Central Park Ave	2/24/2023
5649 S Wolcott Ave	2/24/2023
7409 S Stewart Ave	2/24/2023
217 N Keystone Ave	2/24/2023
9145 S Laflin St	2/25/2023
808 S Kedvale Ave	2/27/2023
6319 S Wood St	2/27/2023

5127 S Hermitage Ave	2/27/2023
4041 N Melvina Ave	2/28/2023
1410 E 75th St	2/28/2023
3102 E 91st St	3/1/2023
8909 S Houston Ave	3/1/2023
4820 N Western Ave	3/1/2023
8342 S Buffalo Ave	3/1/2023
9519 S Wentworth Ave	3/1/2023
6613 S Langley Ave	3/2/2023
1110 N Lawndale Ave	3/2/2023
2243 W 71st St	3/2/2023
5307 S Marshfield Ave	3/2/2023
3334 W Congress Pkwy	3/2/2023
3037 W Lexington St	3/2/2023
3029 S Christiana	3/2/2023
739 E 90th St	3/2/2023
135 W 113th Pl	3/3/2023
9215 S Forest Ave	3/3/2023
1507 S Kostner Ave	3/3/2023
6552 S Oakley Ave	3/3/2023
5521 S Monitor Ave	3/3/2023
458 W 127th St	3/7/2023
6947 S Bishop St	3/7/2023
12017 S State St	3/7/2023
5121 S Union Ave	3/7/2023
7933 S Champlain Ave	3/7/2023
1517 S Keeler Ave	3/7/2023
7933 S Champlain Ave	3/8/2023
2554 N Rutherford Ave	3/8/2023
9664 S Van Vliissingen Rd	3/8/2023
5144 S Hermitage Ave	3/8/2023
11949 S Stewart Ave	3/8/2023
5938 S Parnell Ave	3/8/2023
6738 S Hermitage Ave	3/9/2023
6242 S Marshfield Ave	3/9/2023
6133 S Bishop St	3/9/2023
7933 S Champlain Ave	3/9/2023
2251 S Trumbull Ave	3/9/2023
3530 S Parnell Ave	3/9/2023
2640 W Iowa St	3/9/2023
534 N Lavergne Ave	3/10/2023

922 E 42nd St	3/10/2023
2707 W Warren Blvd	3/10/2023
11358 S Throop St	3/10/2023
7527 S Chappel Ave	3/10/2023
7933 S Champlain Ave	3/10/2023
5427 S Princeton Ave	3/10/2023
828 E 90th Pl	3/13/2023
1626 N Harding Ave	3/13/2023
8411 S Cregier Ave	3/13/2023
1315 S Homan Ave	3/13/2023
3857 W 14th St	3/13/2023
6937 S Carpenter St	3/14/2023
3913 W Polk St	3/14/2023
4940 W Superior St	3/14/2023
6518 S Vernon Ave	3/14/2023
6128 S Evans Ave	3/14/2023
7137 S Sangamon St	3/14/2023
1450 W 79th St	3/14/2023
7732 S Saginaw Ave	3/15/2023
2321 S Kirkland Ave	3/15/2023
819 E 89th St	3/15/2023
6242 S Honore St	3/15/2023
1431 N Austin Blvd	3/15/2023
7917 S Colfax Ave	3/15/2023
1403 N Lockwood Ave	3/15/2023
5004-14 W Chicago Ave	3/15/2023
7918 S Escanaba Ave	3/16/2023
5817 S Carpenter St	3/16/2023
6717 S Union Ave	3/16/2023
2650 E 77th St	3/16/2023
9696 S Oglesby Ave	3/16/2023
6717 S Union Ave	3/16/2023
7400 S Princeton Ave	3/16/2023
7440 S Ellis Ave	3/16/2023
2539-2545 East 75th Street	3/20/2023
7509 S Kingston Ave	3/20/2023
7939 S Cottage Grove Ave	3/20/2023
7136 S Wolcott Ave	3/20/2023
1902 S Pulaski Rd	3/20/2023
828 E 90th Pl	3/20/2023
2252 E 100th St	3/21/2023

1422 E 70th St	3/21/2023
9952 S Luella Ave	3/21/2023
2254 E 100th St	3/21/2023
5926 S Winchester Ave	3/21/2023
7139 S Prairie Ave	3/22/2023
6223 S St Lawrence Ave	3/22/2023
5726 S Elizabeth St	3/22/2023
1701 W 79th St	3/22/2023
2254 E 100th St	3/22/2023
2009 W 70th Pl	3/22/2023
7933 S Champlain Ave	3/22/2023
8429 S Sangamon St	3/22/2023
7713 S Green St	3/22/2023
9551 S Wentworth Ave	3/22/2023
1110 S Sacramento Blvd	3/23/2023
2628 W 25th St	3/23/2023
1132 N Waller Ave	3/23/2023
1407 W 73rd Pl	3/23/2023
7509 S Cottage Grove Ave	3/23/2023
1246 S Central Park Ave	3/23/2023
5500 W Warwick Ave	3/23/2023
6232 S Wabash Ave	3/23/2023
2628 W 25th St	3/23/2023
1110 S Sacramento Blvd	3/23/2023
8635 S Essex Ave	3/23/2023
7509 S Cottage Grove Ave	3/23/2023
3704 W Ferdinand St	3/24/2023
6434 S Damen Ave	3/24/2023
1450 W 72nd Pl	3/24/2023
121 S Menard Ave	3/24/2023
7014 S Wallace St	3/24/2023
1446 N Talman Ave	3/24/2023
4119 W 57th Pl	3/27/2023
7359 S May St	3/27/2023
6027 S Damen Ave	3/27/2023
1951 E 79th St	3/28/2023
3926 W Arthington St	3/28/2023
2023 N Drake Ave	3/28/2023
5356 S Morgan St	3/28/2023
8100 S Hoyne Ave	3/28/2023
11572 S La Salle St	3/28/2023

11841 S Lafayette Ave	3/28/2023
1446 N Talman Ave	3/29/2023
10725 S Whipple St	3/29/2023
126 W 110th Place	3/29/2023
7806 S Greenwood Ave	3/29/2023
7800 S Greenwood Ave	3/29/2023
10739 S Ridgeway Ave	3/29/2023
1832 N Kimball Ave	3/29/2023
10725 S Whipple St	3/29/2023
10739 S Ridgeway Ave	3/29/2023
5802 W Ohio St	3/29/2023
11941-43 S Emerald Ave	3/30/2023
1953 S Christiana Ave	3/30/2023
1953 S Christiana Ave	3/30/2023
8714 S Crandon Ave	3/31/2023
3547 W 111th St	3/31/2023
5744 S Wabash Ave	3/31/2023
7127 S Oakley Ave	3/31/2023
5744 S Wabash Ave	3/31/2023
5033 W Wabansia Ave	4/3/2023
4727 S Princeton Ave	4/3/2023
4521 S Hermitage Ave	4/3/2023
4525 S Hermitage Ave	4/3/2023
4539 S Justine St	4/3/2023
7550 S Perry Ave	4/4/2023
335 W 106th St	4/4/2023
11654 S Wallace St	4/4/2023
11624 S Harvard Ave	4/4/2023
6938 S Carpenter St	4/4/2023
5227 N Broadway	4/4/2023
7148 S Carpenter St	4/5/2023
560 N Laramie Ave	4/5/2023
722 W 19th Street	4/5/2023
3409 S Lituanica Ave	4/5/2023
6351 S Parnell Ave	4/5/2023
5646 S Union Ave	4/5/2023
1531 S Harding Ave	4/6/2023
7036 S Parnell Ave	4/6/2023
6608 S Lowe Ave	4/6/2023
1538 S Homan Ave	4/6/2023
4143 W 21st St	4/6/2023

5803 S Bishop St	4/6/2023
8452 S Dante Ave	4/6/2023
1234 S Central Park Ave	4/7/2023
2730 N Mason Ave	4/7/2023
6922 S Loomis Blvd	4/7/2023
10722 S Langley Ave	4/7/2023
10736 S Langley Ave	4/7/2023
10728 S Langley Ave	4/7/2023
6632 S Marshfield Ave	4/10/2023
10413 S Ewing Ave	4/10/2023
5659 S Kildare Ave	4/10/2023
5148 S Hermitage Ave	4/10/2023
4246 W 57th St	4/10/2023
5157 S Hermitage Ave	4/10/2023
8059 S Halsted St	4/11/2023
1233 West 96th St	4/11/2023
6612 S Hermitage Ave	4/11/2023
55 West 77th Place	4/11/2023
305-307 West 105th Place	4/11/2023
6800 S Carpenter St	4/11/2023
1444 S Sawyer Ave	4/11/2023
10635 S State St	4/11/2023
1054 W 63rd St	4/11/2023
2519 W 71st St	4/11/2023
2447 W Marquette Rd	4/11/2023
6738 S Marshfield Ave	4/12/2023
334 West 61st Street	4/12/2023
9126 S Commercial Ave	4/12/2023
6214-6216 S Martin Luther King Dr	4/12/2023
9023 S Mackinaw Ave	4/13/2023
8448 S Exchange Ave	4/13/2023
7810 S Drexel Ave	4/13/2023
331 W 58th St	4/13/2023
5926 S Morgan St	4/13/2023
4024 W Arthington St	4/13/2023
7048 S Wabash Ave	4/14/2023
10718 S Perry Ave	4/14/2023
5242 S Princeton Ave	4/14/2023
6948 S Normal Blvd	4/14/2023
6045 S Halsted St	4/14/2023
5033 W Wabansia Ave	4/15/2023

1400 E 75th St	4/15/2023
8508 S Stony Island	4/15/2023
9149 S Blackstone	4/15/2023
9145 S Laflin	4/15/2023
7939 S Cottage Grove Ave	4/17/2023
4109 N Lawndale Ave	4/17/2023
5604 S Justine St	4/18/2023
9358 S Peoria St	4/18/2023
12638 S Harvard Ave	4/18/2023
7551-53 S Stewart Ave	4/18/2023
11723 S Harvard	4/18/2023
1539 S Harding Ave	4/18/2023
1717 W Montvale Ave	4/18/2023
7647 S Phillips Ave	4/18/2023
7527 S Ellis Ave	4/18/2023
6757 S Cregier Ave	4/18/2023
6454 S Morgan St	4/19/2023
1320 S Harding Ave	4/19/2023
6552 S Oakley Ave	4/19/2023
1535 W Roosevelt	4/19/2023
9428 S Lafayette Ave	4/19/2023
11588 S State St	4/19/2023
7560 S Cottage Grove Ave	4/19/2023
3641 E 99th St	4/20/2023
5933 S Sangamon St	4/20/2023
5707 S Lowe Ave	4/20/2023
834 W Garfield Blvd	4/20/2023
3641 E 99th St	4/20/2023
5007 S Bishop St	4/20/2023
118 E 110th St	4/20/2023
121 S Menard Ave	4/20/2023
5933 S Sangamon St	4/20/2023
3900 N Central Ave/5608 W Byron St	4/20/2023
10839 S Forest Ave	4/20/2023
13329 S Brandon Ave	4/21/2023
1937 S Christiana Ave	4/21/2023
13353 S Avenue O	4/21/2023
325 S Whipple St	4/21/2023
6409 S Albany Ave	4/21/2023
6700 S Hermitage Ave	4/21/2023
9927 S Lafayette Ave	4/21/2023

5845 S Union Ave	4/21/2023
8934 S Luella Ave	4/21/2023
6301 S Western Ave	4/22/2023
3824 W Fulton St	4/24/2023
3824 W Fulton St	4/24/2023
2200 N Mango Ave	4/24/2023
3056 N Narragansett Ave	4/24/2023
2044 W Melrose St	4/24/2023
1537 W Roosevelt Rd	4/24/2023
941 W 50th St	4/24/2023
2024 W 69th St	4/25/2023
2022 W 69th St	4/25/2023
110 W 119th St	4/25/2023
11749 S Union Ave	4/25/2023
7329 S Princeton Ave	4/25/2023
514 N Lawler Ave	4/25/2023
4815 W Haddon Ave	4/25/2023
216 N Leamington Ave	4/26/2023
4826 W Potomac Ave	4/26/2023
1037 E 75th St	4/26/2023
919-25 E 79th St	4/26/2023
5127 S Hermitage Ave	4/26/2023
9252 S Wabash Ave	4/26/2023
321 E 136th St	4/26/2023
1426 W 71st Place	4/26/2023
5621 S Perry Ave	4/27/2023
230 W 22nd Pl	4/27/2023
10756 S Green Bay Ave	4/27/2023
1505 S Spaulding Ave	4/27/2023
2041 W 69th Place	4/27/2023
5642 S Mason Ave	4/28/2023
652-56 N Lotus Ave	4/28/2023
2139 W 50th Pl	5/1/2023
6323 S Wood St	5/2/2023
6741 S Campbell Ave	5/2/2023
2118 W 54th St	5/2/2023
3910 N Harlem Ave	5/2/2023
5231-37 S Indiana Ave	5/2/2023
1204 W 69th St	5/2/2023
4240 W Monroe St	5/2/2023
8000 S Wood St	5/3/2023

8022-24 S Ellis Ave	5/3/2023
6451 S Honore St	5/3/2023
8561 S Oglesby Ave	5/3/2023
7948 S Muskegon Ave	5/3/2023
10413 S Ewing Ave	5/3/2023
8312 S Phillips Ave	5/3/2023
7457 S Cottage Grove Ave	5/3/2023
11807 S Morgan St	5/4/2023
1625 E 74th St	5/4/2023
9226 S Harper Ave	5/4/2023
3449 W 23rd St	5/5/2023
6625 S Aberdeen St	5/5/2023
8020 S Coles Ave	5/5/2023
2108 W 70th Pl	5/5/2023
7328 S University Ave	5/5/2023
7923 S Manistee Ave	5/5/2023
1511 S Ridgeway Ave	5/6/2023
162 N Pine Ave	5/6/2023
764 S Kenneth Ave	5/6/2023
5531 S Hamilton Ave	5/8/2023
12253 S Parnell Ave	5/8/2023
11523 S Yale Ave	5/8/2023
9901 S Exchange Ave	5/8/2023
418 W 118th St	5/8/2023
12137 S Green St	5/9/2023
13547 S Indiana Ave	5/9/2023
7939 S Cottage Grove Ave	5/9/2023
5231-37 S Indiana Ave	5/9/2023
1231 S Komensky Ave	5/9/2023
6430 S Honore St	5/9/2023
6561 N Seeley Ave	5/10/2023
4143 W 21st St	5/10/2023
808 S Kedvale Ave	5/10/2023
4700 W Montrose Ave	5/10/2023
4343 S Ellis Ave	5/10/2023
2321 W Foster Ave	5/10/2023
3816 W Marquette Rd	5/11/2023
710 N Central Ave	5/11/2023
2433 W 63rd St	5/11/2023
5640 S Union Ave	5/11/2023
8524 S Essex Ave	5/12/2023

36 W 95th St	5/12/2023
11317 S Eggleston Ave	5/12/2023
6552 S Oakley Ave	5/12/2023
5659 S Kildare Ave	5/12/2023
8524 S Essex Ave	5/12/2023
6001 S Hermitage Ave	5/15/2023
6758 S Winchester Ave	5/15/2023
11611 S Lafayette Ave	5/15/2023
6235 N Ridgeway Ave	5/16/2023
9456 S Eggleston Ave	5/16/2023
8548 S Marquette Ave	5/16/2023
9246 S Lowe Ave	5/16/2023
7515 S Luella Ave	5/16/2023
7841 S Burnham Ave	5/16/2023
7044 S Normal Ave	5/17/2023
1727 W 106th St	5/17/2023
2618 W Wilcox St	5/17/2023
7021 S Justine St	5/17/2023
9401 S Ashland Ave	5/18/2023
11915 S Michigan Ave	5/18/2023
4412 S Shields Ave	5/18/2023
6531 S May St	5/18/2023
7309 S Evans Ave	5/18/2023
8217 S Rhodes Ave	5/18/2023
4019 W Monroe St	5/18/2023
5651 W Pensacola Ave	5/18/2023
6319 S Wood St	5/18/2023
2136-48 E 75th St/7449-55 S Merrill Ave	5/18/2023
7251 S Union Ave	5/19/2023
62 W 72nd St	5/19/2023
822 E 89th St	5/19/2023
7221 S Emerald Ave	5/19/2023
714 W 72nd St	5/19/2023
7000 S Normal Blvd	5/19/2023
9540 S Yale Ave	5/19/2023
718 W 72nd St	5/19/2023
4401 S Talman Ave	5/19/2023
2730 N Mason Ave	5/19/2023
10141 S Emerald Ave	5/19/2023
1833 S Komensky Ave	5/22/2023
5613 S Carpenter St	5/22/2023

139 W 113th Pl	5/22/2023
5732 S Sangamon St	5/23/2023
7029 S Throop St	5/23/2023
6637 S Lowe Ave	5/23/2023
2815-17 E 80th St	5/23/2023
7329 S Princeton Ave	5/23/2023
6938 S Carpenter St	5/23/2023
6736 S Justine St	5/23/2023
5602 S Wolcott Ave	5/23/2023
5610 S Morgan St	5/24/2023
6348 S Evans Ave	5/24/2023
738 W 60th Pl	5/24/2023
737 W 60th Pl	5/24/2023
2650 E 77th St	5/24/2023
8008 S Muskegon Ave	5/24/2023
5746 S Laflin St	5/24/2023
7119 S Emerald Ave	5/24/2023
5610 S Morgan St	5/24/2023
7240 S May St	5/25/2023
318 W 112th Pl	5/25/2023
10222 S State St	5/25/2023
6001 S Hermitage Ave	5/26/2023
1406 W 72nd Pl	5/26/2023
8421 S Escanaba Ave	5/26/2023
2944 N Sawyer Ave	5/26/2023
18 N Laramie Ave	5/26/2023
7046 S Normal Blvd	5/30/2023
5729 S Aberdeen St	5/30/2023
3103 W 25th St	5/30/2023
7158 S South Chicago Ave	5/31/2023
4412 S Shields Ave	5/31/2023
5046 S Prairie Ave	5/31/2023
11840 S Lafayette Ave	5/31/2023
13049 S Brandon Ave	5/31/2023
1521 N Keystone Ave	6/1/2023
825 E 48th St	6/1/2023
2309 S Marshall Blvd	6/1/2023
10546 S Ave J	6/1/2023
7042 S Morgan St	6/1/2023
9838 S King Dr	6/2/2023
6801 S Bennett Ave	6/2/2023

323 S Albany Ave	6/2/2023
2711 W Harrison St	6/2/2023
5030 W Ohio St	6/2/2023
5601 S Halsted St	6/2/2023
2966 N Lincoln Ave	6/2/2023
3316 W Maypole Ave	6/2/2023
1620 N Nagle Ave	6/2/2023
710 N Central Ave	6/2/2023
1526 S Springfield Ave	6/2/2023
7223 S Hermitage Ave	6/2/2023
5440 W Drummond Pl	6/3/2023
6844 S Throop	6/5/2023
254 N California Ave	6/5/2023
3003 S Kenneth Ave	6/5/2023
4550 S Michigan Ave	6/6/2023
4309 W Gladys Ave	6/6/2023
6219 S Champlain Ave	6/6/2023
8000 S Manistee Ave	6/6/2023
1444 S Sawyer Ave	6/6/2023
4000 S Cottage Grove Ave	6/7/2023
7800 S Peoria St	6/7/2023
7315 S Indiana Ave	6/7/2023
9056 S Harper Ave	6/7/2023
10739 S Ridgeway Ave	6/7/2023
302 W 112th Pl	6/7/2023
8838 S Wood St	6/7/2023
2423 W Gunnison St #1	6/8/2023
9801 S Clyde Ave	6/8/2023
5747 S La Salle St	6/8/2023
2423 W Gunnison St #1	6/8/2023
1038 W 103rd St	6/8/2023
10218 S Carpenter	6/8/2023
6036 S Marshfield	6/8/2023
7915 S Coles Ave	6/8/2023
5747 S La Salle St	6/8/2023
8524 S Essex Ave	6/8/2023
8136 S Avalon Ave	6/8/2023
8013-8015 S Champlain Ave	6/8/2023
1646 S Homan Ave	6/8/2023
5744 S Wabash Ave	6/8/2023
6402 S Aberdeen St	6/8/2023

2423 W Gunnison St #1	6/9/2023
7226 S Green St	6/9/2023
509 W 104th St	6/9/2023
4355 W Thomas St	6/9/2023
6521 S Green St	6/9/2023
6934 S Rockwell St	6/9/2023
4427 N Sacramento Ave	6/9/2023
4646 S Kedvale Ave	6/9/2023
4210 W West End Ave	6/9/2023
4210 W West End Ave	6/9/2023
4117 W Van Buren St	6/9/2023
2423 W Gunnison St #1	6/10/2023
4539 S Justine St	6/12/2023
5259 S Bishop St	6/12/2023
7238 S May St	6/12/2023
6319 S Woods	6/13/2023
11318 S Homewood Ave	6/13/2023
7843 S Langley Ave	6/13/2023
7306 S Paulina St	6/13/2023
7711 S Prairie Ave	6/13/2023
6410 S Winchester Ave	6/13/2023
5435 S Damen Ave	6/13/2023
5203 S Ashland Ave	6/13/2023
10351 S Green St	6/14/2023
5629 S Artesian Ave	6/14/2023
8259 S Commercial Ave	6/14/2023
9600 S Sangamon St	6/14/2023
8946 S Dorchester Ave	6/14/2023
838 E 90th St	6/14/2023
5242 S Princeton Ave	6/15/2023
928 N Leclair Ave	6/15/2023
7747 S Cregier Ave	6/15/2023
2044 W Melrose St	6/15/2023
1432 W 72nd Place	6/15/2023
7747 S Cregier Ave	6/15/2023
8549 S Kingston Ave	6/15/2023
1434 W 72nd Pl	6/16/2023
9993 S Winston Ave	6/16/2023
1836 W Marquette Rd	6/16/2023
6401 S Whipple St	6/20/2023
1334 W 87th St	6/20/2023

5216 N Osceola Ave	6/20/2023
409 W 117th St	6/20/2023
1012 W 115th St	6/20/2023
2139 W 50th Pl	6/20/2023
1203 W 47th St	6/20/2023
1406 W 72nd Pl	6/20/2023
6610 S Halsted St	6/21/2023
4949 W Byron St	6/21/2023
220 N Lorel Ave	6/21/2023
6749 S Marshfield Ave	6/21/2023
6200 S Maplewood Ave	6/21/2023
6236 S Marshfield Ave	6/21/2023
6610 S Halsted St	6/21/2023
10854 S State St	6/22/2023
10542 S Avenue O	6/22/2023
4240 W Monroe St	6/22/2023
8553 S Burley Ave	6/22/2023
8526 S Burley Ave	6/22/2023
6331 S Lowe Ave	6/22/2023
9638 S Avenue M	6/22/2023
846 W 119th St	6/22/2023
7010 S Marshfield Ave	6/22/2023
307 W 109th St	6/22/2023
652 N Lotus Ave	6/22/2023
2208 E 97th St	6/22/2023
7843 S Langley Ave	6/22/2023
6331 S Lowe Ave	6/22/2023
1820 W Cullerton St	6/23/2023
6618 S Perry Ave	6/23/2023
5935 S Justine St	6/23/2023
5615 S Hermitage Ave	6/23/2023
3334 W Congress Pkwy	6/23/2023
9314 S Jeffery Blvd	6/23/2023
2436 W Lithuanian Plaza Ct	6/23/2023
656 E 105th Place	6/23/2023
10756 S Green Bay Ave	6/23/2023
8524 S Essex Ave	6/23/2023
7927 S Manistee Ave	6/23/2023
3916 W Wilcox St	6/23/2023
7123 S Seeley Ave	6/23/2023
3334 W Congress Pkwy	6/23/2023

5659 S Kildare Ave	6/24/2023
2116 S Fairfield Ave	6/24/2023
4638 N Kasson Ave	6/24/2023
3619 W Grenshaw St	6/24/2023
3037 W Lexington St	6/24/2023
3944 W Dakin St	6/26/2023
6513 S Mozart St	6/26/2023
7829 S Constance Ave	6/26/2023
11346 S Throop St	6/26/2023
8435 S Racine Ave	6/27/2023
7047 S Carpenter St	6/27/2023
6051 S Honore St	6/27/2023
11951 S Normal Ave	6/27/2023
7353 S Hoyne Ave	6/27/2023
7538 S Wolcott Ave	6/28/2023
903 N Trumbull Ave	6/28/2023
6444 S Wood St	6/28/2023
4027 W 5th Ave	6/28/2023
6747 S Prairie Ave	6/28/2023
8127 S Burnham Ave	6/28/2023
11806 S Parnell Ave	6/28/2023
1851 W Marquette Rd	6/28/2023
1402 W 72nd Pl	6/28/2023
8034 S Morgan St	6/29/2023
2653 W Gregory St	6/29/2023
10854 S State St	6/29/2023
7735 S Kedzie Ave	6/29/2023
7815 S Merrill Ave	6/29/2023
7518 S Peoria St	6/29/2023
8136 S Avalon Ave	6/29/2023
11752 S Indiana Ave	6/29/2023
2044 W Melrose St	6/29/2023
9614 S Dobson Ave	6/29/2023
144 S Sacramento Blvd	6/30/2023
2433 W 63rd St	7/1/2023
6339 S Central Ave	7/3/2023
2934 N Lawndale Ave	7/3/2023
6331 S Kolin Ave	7/3/2023
652-56 N Lotus Ave	7/4/2023
1447 E 65th St	7/5/2023
7515 S Luella Ave	7/5/2023

5802 W Ohio St	7/5/2023
9815 S Carpenter St	7/5/2023
7248 S Green St	7/5/2023
5823 S Shields Ave	7/5/2023
5953 S Artesian Ave	7/5/2023
3946 N Merrimac Ave	7/6/2023
1521 N Lawndale Ave	7/6/2023
8200 S Talman Ave	7/6/2023
33 W 110th St	7/6/2023
8023 S Yates Blvd	7/6/2023
4205 W Cullerton St	7/6/2023
35 W 110th St	7/6/2023
2858 W Wilson Ave	7/7/2023
7007 S Ada St	7/7/2023
8816 S Hermitage Ave	7/7/2023
7744 S Marshfield Ave	7/7/2023
7900 S Ingleside Ave	7/7/2023
4830 W Arthington	7/8/2023
33 W 110th St	7/9/2023
2211 E 71st St	7/10/2023
2922 W Lexington St	7/10/2023
6207 S Wood St	7/11/2023
2149 W Warren Blvd	7/11/2023
220 N Francisco Ave	7/11/2023
5345 S Lawndale Ave	7/11/2023
11308 S Indiana Ave	7/11/2023
656 W 59th St	7/11/2023
652 W 59th St	7/11/2023
3619 W Grenshaw St	7/11/2023
3626 W Grenshaw St	7/11/2023
6100 S Elizabeth St	7/11/2023
942 N Harding Ave	7/11/2023
732 S Karlov Ave	7/11/2023
4726 S Indiana Ave	7/11/2023
12250 S Green	7/11/2023
2035 W 70th St	7/12/2023
6824 S Union Ave	7/12/2023
6651 S Racine Ave	7/12/2023
1154 W Marquette Rd	7/12/2023
11819 S Harvard Ave	7/12/2023
11821 S Harvard Ave	7/12/2023

7056 S Throop St	7/12/2023
6827 S Emerald Ave	7/12/2023
2730 N Mason Ave	7/12/2023
2730 N Mason Ave	7/12/2023
4726 S Indiana Ave	7/12/2023
6433 S Sangamon St	7/12/2023
6337 W Cornelia Ave	7/13/2023
6940 S Normal	7/13/2023
7252 S Sawyer Ave	7/13/2023
1512 W Wilson Ave	7/13/2023
5214 S Marshfield Ave	7/14/2023
5531 S Hamilton Ave	7/14/2023
4107 W Cermak Rd	7/15/2023
8452 S Dante Ave	7/17/2023
1622 S Central Park Ave	7/17/2023
11951 S Normal Ave	7/17/2023
7835 S Sangamon St	7/17/2023
1110 N Lawndale Ave	7/17/2023
2944 N Sawyer Ave	7/17/2023
7747 S Cregier Ave	7/17/2023
1522 W Wilson Ave	7/18/2023
5750 S Bishop St	7/18/2023
5640 S Union Ave	7/18/2023
6159 S Artesian Ave	7/18/2023
7147 S Seeley Ave	7/18/2023
7955 S Harvard Ave	7/18/2023
13450 S Burley Ave	7/18/2023
1015 W 103rd Pl	7/18/2023
1037 W 103rd Pl	7/18/2023
406 E 63rd St	7/19/2023
7550-7556 S Kingston Ave	7/19/2023
10008 S Lowe Ave	7/19/2023
353 W 106th Pl	7/19/2023
321 W 106th Pl	7/19/2023
2041 W 69th Pl	7/19/2023
12111 S Normal Ave	7/19/2023
12109 S Normal Ave	7/19/2023
6811 S Justine St	7/19/2023
9942 S Wentworth Ave	7/19/2023
9942 S Wentworth Ave	7/19/2023
52 W 110th St	7/19/2023

610 N Troy St	7/20/2023
6618 S Perry Ave	7/20/2023
10051 S Lowe Ave	7/20/2023
10240 S Yale Ave	7/20/2023
10406 S Indiana Ave	7/20/2023
10129 S Rhodes Ave	7/20/2023
9215 S Forest Ave	7/20/2023
12206 S Emerald Ave	7/20/2023
11616 S Harvard Ave	7/20/2023
63 W 113th St	7/20/2023
10537 S Corliss Ave	7/20/2023
12214 S Emerald Ave	7/20/2023
7106 S Eggleston Ave	7/20/2023
6702 S Throop St	7/20/2023
6050 S Hermitage Ave	7/20/2023
5724 S Princeton Ave	7/20/2023
2139 W 50th Pl	7/20/2023
10618 S Wabash Ave	7/21/2023
6626 S Carpenter	7/21/2023
6933 S Honore St	7/21/2023
6405 S Carpenter St	7/21/2023
7608 S Phillips Ave	7/21/2023
8439 S Colfax Ave	7/21/2023
410 E 63rd St	7/22/2023
1412 W 61st St	7/24/2023
10829 S Eggleston Ave	7/24/2023
6934 S Rockwell St	7/24/2023
10632 S May St	7/24/2023
1517 S Homan Ave	7/24/2023
7826 S Christiana Ave	7/25/2023
1940 S Trumbull Ave	7/25/2023
632 E 100th Pl	7/25/2023
2342 N Lorel Ave	7/25/2023
2116 S Fairfield Ave	7/25/2023
6641 S Karlov Ave	7/25/2023
1110 S Sacramento Blvd	7/25/2023
6715 S Oakley Ave	7/25/2023
1531 S Harding Ave	7/25/2023
3619 W Greshaw St	7/25/2023
507 E 83rd St	7/25/2023
1316 W 109th St	7/25/2023

8844 S Carpenter St	7/25/2023
6300-08 S Eberhart Ave	7/25/2023
6300-08 S Eberhart Ave	7/25/2023
8844 S Carpenter St	7/25/2023
1316 W 109th St	7/25/2023
11624 S Harvard Ave	7/25/2023
654 W 117th St	7/25/2023
507 E 83rd St	7/25/2023
2631 W 24th St	7/26/2023
2453 N Albany Ave	7/26/2023
3759 W Ohio St /555-57 N Hamlin	7/26/2023
6401 S Whipple St	7/26/2023
5406 W Walton St	7/27/2023
11001 S Wentworth Ave	7/27/2023
357 E 75th St	7/27/2023
7345 S Princeton Ave	7/27/2023
7029 S Emerald Ave	7/28/2023
5739 S Throop St	7/28/2023
28 W 113th Pl	7/28/2023
44 W 112th Pl	7/28/2023
103 W 112th St	7/28/2023
139 W 112th St	7/28/2023
7608 S Phillips Ave	7/28/2023
355 W 105th Pl	7/28/2023
38 E 91st St	7/28/2023
9614 S Dobson Ave	7/28/2023
9949 S Yates Ave	7/28/2023
3311 N Ridgeway Ave	7/29/2023
3922 W Arthington St	7/29/2023
1544 W Washburne Ave	7/29/2023
357 E 75th St	7/31/2023
1541 S St Louis Ave	7/31/2023
3758 W Palmer St	7/31/2023
3134 E 92nd St	7/31/2023
8713 S Exchange Ave	7/31/2023
423 S Cicero Ave	8/1/2023
5659 S Kildare Ave	8/1/2023
9156 S Colfax Ave	8/1/2023
1923 S Christiana Ave	8/1/2023
432 W 42nd Pl	8/1/2023
3621 S Wallace St	8/1/2023

6306-08 S Eberhart Ave	8/1/2023
7337 S Green St	8/1/2023
355 W 105th Pl	8/1/2023
12234 S Carpenter St	8/1/2023
10551 S La Salle St	8/1/2023
6410 S Winchester Ave	8/1/2023
2023 W 69th Pl	8/1/2023
6410 S Winchester Ave	8/1/2023
7116 S Lafayette Ave	8/1/2023
903 N Trumbull Ave	8/2/2023
1333 S Tripp Ave	8/2/2023
1203 W 47th St	8/3/2023
7253 S Prairie Ave	8/3/2023
8539 S Carpenter St	8/3/2023
10324 S Longwood Dr	8/4/2023
10727 S Michigan Ave	8/4/2023
5527 S Oakley Ave	8/4/2023
10727 S Michigan Ave	8/4/2023
5435 S Damen Ave	8/4/2023
5117 S Paulina St	8/4/2023
5203 S Ashland Ave	8/4/2023
5259 S Bishop St	8/4/2023
9419 S Burnside Ave	8/4/2023
1915 E 79th St	8/5/2023
1541 S St Louis Ave	8/7/2023
7826 S Christiana Ave	8/7/2023
6609 S Paulina St	8/7/2023
446 W 37th Pl	8/7/2023
10635 S State St	8/7/2023
8109 S Chappel Ave	8/7/2023
6749 S Marshfield Ave	8/8/2023
3910 W Wilcox St	8/8/2023
324 W 117th St	8/8/2023
3840 W Wilcox St	8/8/2023
3529 W Lexington	8/8/2023
9315 S Cregier Ave	8/8/2023
837 N Lawndale	8/8/2023
4643 S Rockwell St	8/8/2023
1812 W 47th St	8/8/2023
1812 W 47th St	8/8/2023
10526 S Perry Ave	8/8/2023

452 W 104th St	8/8/2023
11823 S Lowe Ave	8/8/2023
837 N Lawndale Ave	8/9/2023
10259 S Michigan Ave	8/9/2023
5435 S Justine St	8/9/2023
230 W 22nd Pl	8/9/2023
2238 S Keeler Ave	8/9/2023
406 E 63rd St	8/9/2023
3913 W Polk St	8/9/2023
4442 N Menard Ave	8/10/2023
9237 S Blackstone	8/10/2023
1314 E 71st pl	8/10/2023
5340 W Washington Blvd	8/10/2023
6548 S Damen Ave	8/10/2023
6401 S Whipple St	8/10/2023
1515 W Garfield Blvd	8/10/2023
235 W 104th St	8/10/2023
8223 S Houston Ave	8/10/2023
852 N St Louis Ave	8/11/2023
4913 W Jackson Blvd	8/11/2023
7854 S Ellis Ave	8/11/2023
9217 S Perry Ave	8/11/2023
13110 S Brandon	8/11/2023
6755 S Throop St	8/11/2023
9319 S Throop St	8/11/2023
9559 S Perry Ave	8/11/2023
5659 S Kildare Ave	8/11/2023
1938 W Garfield Blvd	8/11/2023
5732 S Honore St	8/11/2023
7137 S Sangamon St	8/11/2023
6927 S Parnell Ave	8/11/2023
6121 S Racine Ave	8/11/2023
6017 S Throop St	8/13/2023
1158 W 47th Pl	8/13/2023
638 W 47th St	8/13/2023
1119 N Cleveland Ave	8/14/2023
8013 S Vincennes Ave	8/14/2023
8112 S Vincennes Ave	8/14/2023
5724 S Princeton Ave	8/14/2023
1412 W 61st St	8/14/2023
11541 S Church St	8/14/2023

7023 S Emerald Ave	8/14/2023
2658 East 78th Street	8/14/2023
7042 S Marshfield Ave	8/14/2023
4227 W Adams St	8/15/2023
5447 W Potomac Ave	8/15/2023
5035 N Lincoln Ave	8/15/2023
2412 E 91st St	8/16/2023
12256 S Ada St	8/16/2023
9326 S King Dr	8/16/2023
6620 S Laflin St	8/16/2023
5747 S La Salle St	8/16/2023
4756 S Ada St	8/16/2023
7322 S Green St	8/16/2023
3857 W 14th St	8/17/2023
2833 W Adams St	8/17/2023
8611 S Drexel Ave	8/17/2023
5114 W Madison St	8/18/2023
9761 S Ingleside Ave	8/18/2023
910 E 92nd Pl	8/18/2023
2730 N Mason Ave	8/18/2023
18 West 109th Place	8/18/2023
210 W 110th St	8/18/2023
2352 S Marshall Blvd	8/18/2023
306 W 113th St	8/18/2023
320 N Menard Ave	8/19/2023
7450 S Colfax Ave	8/21/2023
7220 S Champlain Ave	8/21/2023
232 W 106th Pl	8/21/2023
7953 S Union Ave	8/21/2023
1539 S Harding Ave	8/22/2023
434 E 133rd St	8/22/2023
9536 S Wentworth Ave	8/22/2023
10126 S Exchange Ave	8/22/2023
3831 W 108th Pl	8/22/2023
2200 N Ashland Ave	8/22/2023
6118 W Waveland Ave	8/23/2023
660 W 116th St	8/23/2023
5707 S Damen Ave	8/23/2023
2252 E 100th St	8/24/2023
2436 S Albany Ave	8/24/2023
6416 S Bishop St	8/24/2023

6720 S Marshfield Ave	8/24/2023
3633-35 W 16th St	8/25/2023
5917-5919 W Midway Park	8/25/2023
4832 W Arthington	8/25/2023
10514 S Vincennes Ave	8/25/2023
10442 S Maryland Ave	8/25/2023
5300 S Peoria St	8/25/2023
5325 S Racine Ave	8/25/2023
4918 N Rockwell St	8/28/2023
8330 S Kerfoot Ave	8/28/2023
9729 S Woodlawn Ave	8/28/2023
9207 S Woodlawn Ave	8/28/2023
9348 S Forest Ave	8/28/2023
1320 S Harding Ave	8/28/2023
8407 S Kerfoot Ave	8/29/2023
6924 S Woodlawn Ave	8/29/2023
11931 S Yale Ave	8/29/2023
912 W 87th St	8/29/2023
318 E 73rd St	8/29/2023
3512 W Congress Pkwy	8/30/2023
5743 N Mulligan Ave	8/30/2023
4022 W Carroll Ave	8/30/2023
837 N Lawndale Ave	8/30/2023
1700 N Kimball Ave	8/30/2023
8647 S Manistee Ave	8/31/2023
4139 W Adams St	8/31/2023
7119 S Emerald Ave	8/31/2023
36 E 111th St	8/31/2023
8516 S Euclid Ave	8/31/2023
36 W 95th St	8/31/2023
8627 S St Lawrence Ave	8/31/2023
1407 W 73rd Pl	8/31/2023
11957-59 S Halsted St	8/31/2023
7446 S Harvard Ave	9/1/2023
1739 N Drake Ave	9/1/2023
2023 N Drake Ave	9/1/2023
2512 W 69th St	9/1/2023
4726 W Arthington St	9/1/2023
1541 S St Louis Ave	9/5/2023
6948 S Normal Blvd	9/5/2023
8207 S Clyde Ave	9/5/2023

12150 S Parnell Ave	9/5/2023
12130 S Lowe Ave	9/5/2023
8000 S Wood St	9/6/2023
7847 S Escanaba Ave	9/6/2023
9351 S Throop St	9/6/2023
7660 S Halsted St	9/6/2023
7902 S Cottage Grove Ave	9/6/2023
742 E 92nd St	9/6/2023
2240 S Sawyer Ave	9/7/2023
532 N Pine Ave	9/7/2023
9122 S La Salle St	9/7/2023
3142 S Wells St	9/7/2023
8116 S Michigan Ave	9/7/2023
8238 S La Salle St	9/7/2023
641 W 60th St	9/7/2023
5614 S Aberdeen St	9/7/2023
5524 W Iowa St	9/8/2023
11612 S Yale Ave	9/8/2023
7010 S Marshfield Ave	9/8/2023
1444 S Sawyer Ave	9/8/2023
4739 W Polk St	9/8/2023
2250 E 100th St	9/8/2023
4649 W Washington Blvd	9/8/2023
4618 S Evans Ave	9/8/2023
1443 N Ashland Ave	9/8/2023
4649 W Washington Blvd	9/8/2023
1443 N Ashland Ave	9/8/2023
2203 W Lunt Ave	9/9/2023
746 W 103rd St	9/9/2023
1549 W 94th St	9/11/2023
3512 W Congress Pkwy	9/11/2023
8529 S Constance Ave	9/12/2023
9427 S La Salle St	9/12/2023
9056 S Harper Ave	9/12/2023
9014 S University Ave	9/12/2023
2321 W Foster Ave	9/12/2023
6835 S May St	9/12/2023
11745 S Wentworth Ave	9/12/2023
4832 W Arthington St	9/12/2023
2023 W 69th Pl	9/12/2023
1650 W 51st St	9/12/2023

10616 S Lafayette Ave	9/13/2023
43 N Long Ave	9/13/2023
8900 S Emerald Ave	9/13/2023
211 W 112th Pl	9/13/2023
7230 S Champlain Ave	9/13/2023
10616 S Lafayette Ave	9/13/2023
7955 S Union Ave	9/13/2023
7942 S Lafayette Ave	9/13/2023
8839 S Colfax Ave	9/13/2023
8608 S Colfax Ave	9/13/2023
12035 S Wentworth Ave	9/13/2023
5851 W Chicago Ave	9/14/2023
9609 S Chappel Ave	9/14/2023
2625 S Karlov Ave	9/14/2023
3401 W Chicago Ave	9/14/2023
2300 S Indiana Ave	9/14/2023
7251 S Union Ave	9/15/2023
1480 W 73rd Pl	9/15/2023
145 E 111th St	9/15/2023
3335 S May St	9/15/2023
1315 W 111th Pl	9/15/2023
11256 S Bishop St	9/15/2023
10541 S Normal Ave	9/15/2023
7048 S Perry Ave	9/15/2023
7226 S Halsted St	9/15/2023
7048 S Perry Ave	9/15/2023
6940 S Normal Blvd	9/15/2023
6824 S Union Ave	9/15/2023
9121 S Drexel Ave	9/18/2023
9237 S Blackstone Ave	9/18/2023
5435 S Justine St	9/19/2023
2247 S Springfield Ave	9/19/2023
8220 S Maryland Ave	9/19/2023
735 S Lavergne Ave	9/19/2023
1154 W 88th St	9/19/2023
7034 S Marshfield	9/19/2023
8124 S Elizabeth St	9/19/2023
1445 W 52nd St	9/19/2023
837 N Lawndale Ave	9/20/2023
8315 S Green St	9/20/2023
9222 S Ada St	9/20/2023

6335 S Evans Ave	9/20/2023
10035 S Peoria St	9/20/2023
5316 S Lowe Ave	9/20/2023
6318 S Artesian Ave	9/20/2023
7225 S Langley Ave	9/20/2023
856 W 87th St	9/20/2023
1342 W 107th Pl	9/20/2023
11429 S Normal Ave	9/20/2023
11744 S Wentworth Ave	9/21/2023
9719 S Genoa Ave	9/21/2023
11701 S Peoria St	9/21/2023
8128 S King Dr	9/21/2023
8128 S King Dr	9/21/2023
9901 S Exchange Ave	9/21/2023
5001 W Montrose Ave	9/22/2023
6401 S Whipple St	9/22/2023
2040 W Washington Blvd	9/22/2023
6643 S Sangamon St	9/22/2023
7141 S Emerald Ave	9/22/2023
4662 N Laramie Ave	9/23/2023
6043-45 S Halsted St	9/23/2023
1744 W 17th St	9/24/2023
5659 S Kildare Ave	9/25/2023
9818 S Dobson Ave	9/25/2023
10626 S Calhoun Ave	9/25/2023
2748 S Homan Ave	9/26/2023
5545 S Shields Ave	9/26/2023
8613 S Colfax Ave	9/26/2023
3529 W Lexington St	9/26/2023
1932 S Ridgeway Ave	9/26/2023
1848 S Kedzie Ave	9/26/2023
3926 W Arthington St	9/26/2023
4830 W Arthington St	9/26/2023
4832 W Arthington St	9/26/2023
6319 S Wood St	9/26/2023
7137 S Sangamon St	9/26/2023
1236 W 64th St	9/26/2023
6319 S Wood St	9/26/2023
6225 S Kolin Ave	9/26/2023
10240 S Eggleston Ave	9/26/2023
4521 S Hermitage Ave	9/27/2023

2832 W Estes Ave	9/27/2023
12805 S Union Ave	9/27/2023
3835 W Madison St	9/27/2023
6124 S Honore St	9/27/2023
4733 S Lavergne Ave	9/28/2023
4452 S Leclaire Ave	9/28/2023
1520 S Trumbull Ave	9/28/2023
8439 S Colfax Ave	9/28/2023
7811 S Burnham Ave	9/28/2023
8439 S Colfax Ave	9/28/2023
1857 E 81st St	9/28/2023
5452 S Halsted St	9/29/2023
5601 S Halsted St	9/29/2023
3345 N Oleander Ave	9/29/2023
6426 S Sangamon St	9/29/2023
6426 S Sangamon St	9/29/2023

As always, please let me know if you have any further questions.



CITY OF CHICAGO

DEPARTMENT OF BUILDINGS

MEMORANDUM

To: The Honorable Jason Ervin
Chairman, Committee on the Budget and Government Operations

From: Matthew Beaudet
Commissioner
Department

CC: Elizabeth Beatty
Mayor's Office of Intergovernmental Affairs

Date: **November 8, 2023**

Re: Request for Information from Annual Appropriation Committee Hearing

ID#: 67-10

The following information is provided in response to questions posed at our department's hearing on October 25, 2023, to discuss the proposed 2024 budget.

Alderman Lopez asked for the Receivership RFP's. This is not a contract or service managed by the department.

As always, please let me know if you have any further questions.



CITY OF CHICAGO

DEPARTMENT OF BUILDINGS

MEMORANDUM

To: The Honorable Jason Ervin
Chairman, Committee on the Budget and Government Operations

From: Matthew Beaudet
Commissioner
Department

CC: Elizabeth Beatty
Mayor's Office of Intergovernmental Affairs

Date: **November 8, 2023**

Re: Request for Information from Annual Appropriation Committee Hearing

ID#: 67-11

The following information is provided in response to questions posed at our department's hearing on October 25, 2023, to discuss the proposed 2024 budget.

Alderman Lopez requested how many of the vacancies have been vacant all year. Of the 58 vacancies, 33 have been vacant all year. Detailed below is the status for 25 of these vacancies.

We have a Plumbing Inspector starting on 11/1/2023.

We have extended contingent offers:

- 3 Electrical Inspectors
- 1 Boiler Inspector
- 1 Construction Equipment Inspector

We have interviewed and will selecting candidates for:

- 2 Mason Inspectors
- 1 Ventilation & Furnace Inspector

We will be interviewing 16 candidates for Building Construction Inspector on 10/31, 11/1, 11/2.

We are scheduling testing for the Administrative Assistant III and Staff Assistant.

As always, please let me know if you have any further questions.